

Lukhanyo Mgadle Chief Air Quality Officer Buffalo City Metropolitan Municipality 2 Beaconsfield Road North End East London 5201

Date: 2 March 2023

Enquiries: Hilton Westman (021) 9415856

Ref: PRX/2023/02

Dear Mr Mgadle

ESKOM PORT REX POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF FEBRAUARY 2023

Atmospheric Emissions License: ECBC_000603

This serves as the monthly report and the information is applicable for the month of February 2023.

1. Raw Materials and Products (Licence 6.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit	
Fuel type: Diesel			
Total Fuel Consumption	154.391	Tons	
Electricity Produced	515	MWh	
Average Fuel Consumption	0.299	Tons / MWh	
Maximum fuel consumption rate	9649	Kg / per hour	

2. Operating times of units (Licence 5.4)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production	
	Hours and minutes	Litres	MWh	
Unit One	06hrs 00		111.00	
Unit Two	05hrs 00	180 090	205.00	
Unit Three	05hrs 00		199.00	

b. Detailed operating times

See Annexure 1

3. Complaints Register (Licence 7.6)

No complaints were registered for the month of February 2023.

4. General

Port Rex was requested to generate for the grid to supplement power availability and minimise national load shedding.

We trust that the above information complies with your requirements.

Yours sincerely

EMM+

Pamela Mrubata Plant Manager **PORT REX POWER STATION**

Annexure1. Hours of Operation

	Unit One			Unit two			Unit 3		
Date	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20 21									
21	16:00:00	21:00:00	05:00:00	16:00:00	21:00:00	05:00:00	16:00:00	21:00:00	05:00:00
22	16:00:00	17:00:00	01:00:00						
23									
25									
26									
27									
28									

Load Factor 2.38%