



Mrs Mpho Nembilwi
Nkangala District
P.O Box 437
MIDDLEBERG
1050
By email: nembilwim@nkangaladm.gov.za'

Date:
18 October 2022

Enquiries: S Chokoe
Tel +27 13 647 6970

Dear Mrs. Mpho Nembilwi

Ref: Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF July 2022.

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:


Irene Motswenyane
ENVIRONMENTAL OFFICER- KENDAL

Date: 18 / 10 / 2022

Supported by:


Solly Chokoe
ENVIRONMENTAL MANAGER- KENDAL

Date: 18 / 10 / 2022

Generation Division (Cluster 1)
(Kendal Power Station)
N12 Balmoral Off Ramp, Emalahleni
Private Bag x7272, Emalahleni 1035 SA
Tel +27 13 647 6970 Fax +27 13 647 6904 www.eskom.co.za

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF JULY 2022


Verified by:



Fulufhelo Nganke
BOILER ENGINEERING: SYSTEM ENGINEER- KENDAL

18/10/2022
Date:

Validated by:



Tendani Rasivhetshela
ACTING BOILER ENGINEERING MANAGER-KENDAL

Date: 20/10/2022

Supported by:



Malibongwe Mabizela
ENGINEERING MANAGER-KENDAL

21/10/2022
Date:

Approved by:



Kobus Steyn
GENERAL MANAGER-KENDAL

21 Oct 2022
Date:



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Jul-2022
	Coal	Tons	2 260 000	883 833
	Fuel Oil	Tons	5 000	4250.81

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Production Rate Jul-2022
	Energy	GWh(MW)	(3,153,600)4380	1 436 866.00
	Ash	Tons	770 000	274 253.4
	RE Ash	kg/MWh	not specified	0.28

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	<1 (%)	0.840
Ash Content	%	40 (%)	31.030

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jul-2022	Technology Type	SO ₂ Utilization Jul-2022
Unit 1	ESP + SO ₂	98.312%	SO ₂	0.0%
Unit 2	ESP + SO ₂	97.376%	SO ₂	0.0%
Unit 3	ESP + SO ₂	99.669%	SO ₂	9.0%
Unit 4	ESP + SO ₂	97.682%	SO ₂	0.0%
Unit 5	ESP + SO ₂	97.209%	SO ₂	0.0%
Unit 6	ESP + SO ₂	98.221%	SO ₂	0.0%

Unit 1-6 sulphur utilization readings not available because CAPDATAA04 and CAPDATAA05 failed. The hardware is being replaced.

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100.0	81.6	82.9	94.7
Unit 2	88.6	65.4	33.1	100.0
Unit 3	92.5	100.0	0.0	95.3
Unit 4	99.6	100.0	96.7	71.2
Unit 5	99.3	100.0	97.4	100.0
Unit 6	93.3	100.0	98.5	100.0

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

Note: Unit 2 SO₂ & NO, Unit 3 NO and Unit 4 O₂ monitor's reliability is low due to defective monitors.

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of July 2022

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	698.5	2 553	899
Unit 2	1 298.7	1 654	1 049
Unit 3	141.8	2 048	963
Unit 4	567.5	948	283
Unit 5	826.7	1 068	382
Unit 6	563.1	1 322	602
SUM	4 096.31	9 593	4 178

Table 6.2: Operating days in compliance to PM AEL Limit - July 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	4	6	3	12	21	556.6
Unit 2	7	7	15	0	22	542.2
Unit 3	16	4	2	8	14	107.9
Unit 4	1	5	7	7	19	985.9
Unit 5	0	4	0	14	18	954.7
Unit 6	0	4	0	17	21	316.5
SUM	28	30	27	58	115	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - July 2022

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	26	0	0	0	0	2 697.7
Unit 2	30	0	0	0	0	1 084.9
Unit 3	30	0	0	0	0	1 643.7
Unit 4	21	0	0	0	0	1 910.6
Unit 5	21	0	0	0	0	1 589.4
Unit 6	23	0	0	0	0	1 732.5
SUM	151	0	0	0	0	



Table 6.4: Operating days in compliance to NOx AEL Limit - July 2022





Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	26	0	0	0	0	946.9
Unit 2	30	0	0	0	0	687.1
Unit 3	30	0	0	0	0	771.9
Unit 4	21	0	0	0	0	567.2
Unit 5	21	0	0	0	0	568.3
Unit 6	23	0	0	0	0	785.7
SUM	151	0	0	0	0	




Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂





Table 6.5: Legend Description






Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contra-vention	Red	Emissions above ELV but outside grace or S30 incident conditions











7 COMPLAINTS

There were no complaints for this month

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures Implemented to prevent reoccurrence

Abatement Technology-Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☑ Coal ash content (%) and burnt rate mass
- ☑ Fly : Coarse ash ratio of 80:20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- ☑ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission From AQR Report Dust Monitor (tons)} \times 100)}{(\text{Coal Burnt (tons)} \times \% \text{Ash Content} \times 80\%)}$$

Monitor Reliability-Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average.

The monitor reliability refers to data reliability because the assumed value of 99.325% reliability is compared to the dust concentration signal. If the dust concentration signal is above 99.325% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 99.325% over a period of time e.g 24 hours

The formula is as follows:

$$= (1 - (\text{count hours above } 99.325\% / 24 \text{ hours})) \times 100$$

Emissions Performance:

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2,4,5 &6 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Unit 5 Monitor still using the old monitor correlation. After new correlations are done, new correlation factors will be implemented and backfitted to the date of monitor installation.
- Surrogate values were used for Unit 2,3,5 and 6 where dust monitors were maxing out (>99.325%). Surrogate values were taken from the upset test condition reports.
- Average emissions for Unit 2 NOx, CO2 and Unit 3 NOx were used from QAL 2 report.
- For Unit 2 SOx, Unit 4 CO2, Unit 4, Unit 5 and Unit 6 moisture, Unit 4 and Unit 6 pressure where the monitors were frozen; average values from the available data were used.
- Unit 1
- Findings: The high emissions can be attributed to SO3 plant on hold mode due to low steam temperature, SO3 plant trip due to low sulphur flow and DHP off due to high compartment levels.
- Resolution: Plant repaired
- Unit 2
- Findings: High emissions can attributed to DHP trip due to an ash leak at stream 1 bucket elevator, DHP off due to compartment levels full, SO3 plant on hold due to low sulfur flow, precip conveyor 13,14, 22, 24 chocked, SO3 plant trip due to converter temp high, SO3 plant on hold mode due to steam temp low, and DHP trip due to stream 2 second collecting conveyor motor trip.
- Resolution: Plant repaired.
- Unit 3
- Findings: High PM emissions can be attributed to DHP trip due to high compartment levels, various precip fields under performing, SO3 plant trip and on hold mode due to steam leak and sulphur flow low, and precip conveyor 14 chocked.
- Resolution: The plant was repaired.
- Unit 4
- High PM emissions can be attributed to DHP off due to stream 2 bucket elevator blocked chute, precip conveyor 14 trip on overload, SO3 plant on hold mode due to steam leak, SO3 plant trip due to no sulphur flow, precip conveyor 22 and 24 tripping, and precip chain conveyor 11 failing to start.
- Resolution: The plant was repaired.
- Unit 5
- Findings: High PM emissions can be attributed to DHP trip due to high compartments level, precip conveyor 14, 24 kept on tripping, and SO3 plant trip due to low back end temperatures.
- Resolution: The plant was repaired.
- Unit 6
- Findings: High PM emissions can be attributed to SO3 plant on hold mode due to low precip inlet temp, and DHP off due to high compartment levels resulting in ash backlogs.
- Resolution: The plant was repaired.