

	Matimba Power Station Emissions report	Matimba Power Station
---	---	------------------------------

Title: **Matimba Power Station December
2022 emissions report**

Document Identifier: **RP/247/029**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area
Applicability: **Environment**

Revision: **1**

Total Pages: **39**

Report Date: **December 2022**

Disclosure
Classification: **Controlled**

Compiled by

Functional Responsibility

Authorized by





**KH Ramahlare
Environmental Officer**

**MC Mamabolo
Environmental Manager**

**Obakeng Mabotja
General Manager**

Date: 2023-02-03

Date: 03/02/2023

Date: 2023-02-03

Content

	Page
1. Report Summary	5
2. Emission information	6
2.1 Raw materials and products.....	6
2.2 Abatement technology.....	6
2.3 Energy source characteristics	7
2.4 Emissions reporting.....	7
2.4.1 Particulate Matter Emissions	7
2.4.2 Gaseous Emissions	13
2.4.3 Total Volatile Organic Compounds	25
2.4.4 Greenhouse gas (CO ₂) emissions	26
2.5 Daily power generated	26
2.6 Pollutant tonnages	33
2.7 Reference values	33
2.8 Continuous Emission Monitors.....	34
2.8.1 Reliability.....	34
2.8.2 Changes, downtime, and repairs	34
2.8.3 Sampling dates and times.....	35
2.9 Units Start-up information	35
2.10 Emergency generation	37
2.11 Complaints register	37
2.12 Air quality improvements and social responsibility conducted	37
2.12.1 Air quality improvements.....	37
2.12.2 Social responsibility conducted.....	37
2.13 Ambient air quality monitoring.....	38
2.14 Electrostatic precipitator and Sulphur plant status.....	38
2.15 General.....	39
3. Attachments.....	39
4. Report Conclusion	39
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	6
Table 2: Abatement Equipment Control Technology Utilised.....	6
Table 3: Energy Source Material Characteristics.	7
Table 4: Total volatile compound estimates	25
Table 5: Daily power generated per unit in MWh for the month of December 2022	26
Table 6: Pollutant tonnages for the month of December 2022.....	33
Table 7: Reference values for data provided, December 2022.....	33
Table 8: Average percentage (%) availability of monitors for the month of December 2022.....	34
Table 9: Dates of last conducted CEMS verification tests for PM, SO ₂ and NO _x	35

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Start-up information	35
Table 11: Emergency generation	37
Table 12: Complaints.....	37

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of December 2022	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of December 2022	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of December 2022	9
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of December 2022	10
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of December 2022	11
Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of December 2022	12
Figure 7: SO ₂ daily average emissions against emission limit for unit 1 for the month of December 2022	13
Figure 8: SO ₂ daily average emissions against emission limit for unit 2 for the month of December 2022	14
Figure 9: SO ₂ daily average emissions against emission limit for unit 3 for the month of December 2022	15
Figure 10: SO ₂ daily average emissions against emission limit for unit 4 for the month of December 2022	16
Figure 11: SO ₂ daily average emissions against emission limit for unit 5 for the month of December 2022	17
Figure 12: SO ₂ daily average emissions against emission limit for unit 6 for the month of December 2022	18
Figure 13: Figure 14: NO _x daily average emissions against emission limit for unit 1 for the month of December 2022	19
Figure 15: NO _x daily average emissions against emission limit for unit 2 for the month of December 2022	20
Figure 16: NO _x daily average emissions against emission limit for unit 3 for the month of December 2022	21
Figure 17: NO _x daily average emissions against emission limit for unit 4 for the month of December 2022	22
Figure 18: NO _x daily average emissions against emission limit for unit 5 for the month of December 2022	23
Figure 19: NO _x daily average emissions against emission limit for unit 6 for the month of December 2022	24
Figure 20: Unit 1 daily generated power in MWh for the month of December 2022	27
Figure 21: Unit 2 daily generated power in MWh for the month of December 2022	28

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Figure 22: Unit 3 daily generated power in MWh for the month of December 2022	29
Figure 23: Unit 4 daily generated power in MWh for the month of December 2022	30
Figure 24: Unit 5 daily generated power in MWh for the month of December 2022	31
Figure 25: Unit 6 daily generated power in MWh for the month of December 2022	32

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for December 2022.



During the period under review, 17 exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$) occurred. All exceedances remained within the 48-hour grace period. No exceedances of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$) or the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$) occurred in the month of December 2022.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	1 114 147
	Fuel Oil	Tons/month	1 200	767,516
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	2538,44086

The consumption rates for the month of December 2022 were within the permitted maximum limits.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,84%
Unit 2	Electrostatic Precipitator	100%	99,87%
Unit 3	Electrostatic Precipitator	100%	99,92%
Unit 4	Electrostatic Precipitator	100%	99,89%
Unit 5	Electrostatic Precipitator	100%	99,87%
Unit 6	Electrostatic Precipitator	100%	99,90%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	99,51%
Unit 2	SO ₃ Plant	100%	98,04%
Unit 3	SO ₃ Plant	100%	97,98%
Unit 4	SO ₃ Plant	100%	98,18%
Unit 5	SO ₃ Plant	100%	93,78%
Unit 6	SO ₃ Plant	100%	99,06%

Flue gas conditioning plant availability was below the required 100% for all six (06) units due to maintenance activities and unplanned breakdowns. Defects were addressed and plants returned to services.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,26%
	Ash Content	40%	34,46%

Energy source characteristics remained within the ranges stipulated in the license.

2.4 Emissions reporting

2.4.1 Particulate Matter Emissions

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of December 2022

Interpretation:

Unit 1 exceeded the daily particulate emission limit of 50mg/Nm³ on 13, 24 and 26 December 2022. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The plant was repaired, and emissions returned to below the set limit. The exceedance remained within the 48-hour grace period. The unit was taken off load on the 26 December 2022 for interim repairs outage.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of December 2022

Interpretation:

Unit 2 exceeded the daily particulate emission limit of 50mg/Nm³ on 7, 12, 21, 24, 28 and 29 December 2022. The exceedances on 7, 12, 24, 28 and 29 December were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The plant was repaired, and emissions returned to below the set limit. The exceedance on 21 December was due to the extended light-up conditions. The exceedance remained within the 48-hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of December 2022

Interpretation:

Unit 3 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 24 December 2022. The exceedance was due to breakdowns on the ash removal system leading to ash backlog within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The defective plants were repaired, and the exceedances remained within the 48-hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of December 2022

Interpretation:

Unit 4 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 10, 12, 19 and 23 December 2022. The unit was off load from the 4 to 10 December and the exceedance on the 10 December was due to extended light-up conditions. The exceedances on 12, 19, 23 December 2022 were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The plant was repaired, and emissions returned to below the set limit. The defective plants were repaired, and the exceedances remained within the 48-hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of December 2022

Interpretation:

Unit 5 exceeded the daily particulate matter limit of 50mg/Nm³ on the 5th and 27th of December 2022. The unit experienced upset conditions on the 5th of December 2022 due to high ESP hoppers, and the exceedance on the 27th of December 2022 was a result of extended unit light-up following short outage.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of December 2022

Interpretation:

Unit 6 emissions performance was fairly acceptable with an exception on the 28th of December 2022 where the limit was exceeded as a result of upset conditions caused by high hopper levels.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.2 Gaseous Emissions

Unit 1 SO₂ Emissions




Figure 7: SO₂ daily average emissions against emission limit for unit 1 for the month of December 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 SO₂ Emissions

Figure 8: SO₂ daily average emissions against emission limit for unit 2 for the month of December 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 SO₂ Emissions

Figure 9: SO₂ daily average emissions against emission limit for unit 3 for the month of December 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 SO₂ Emissions

Figure 10: SO₂ daily average emissions against emission limit for unit 4 for the month of December 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 SO₂ Emissions

Figure 11: SO₂ daily average emissions against emission limit for unit 5 for the month of December 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 SO₂ Emissions

Figure 12: SO₂ daily average emissions against emission limit for unit 6 for the month of December 2022

Interpretation:

All daily averages remained below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 1 NO_x Emissions

Figure 13: Figure 14: NO_x daily average emissions against emission limit for unit 1 for the month of December 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO_x Emissions

Figure 15: NO_x daily average emissions against emission limit for unit 2 for the month of December 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 NO_x Emissions

Figure 16: NO_x daily average emissions against emission limit for unit 3 for the month of December 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 NO_x Emissions

Figure 17: NO_x daily average emissions against emission limit for unit 4 for the month of December 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 NO_x Emissions

Figure 18: NO_x daily average emissions against emission limit for unit 5 for the month of December 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 NO_x Emissions

Figure 19: NO_x daily average emissions against emission limit for unit 6 for the month of December 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Monday, 23 January 2023	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the blue cells below</p> <p align="center">Choose from a dropdown menu in the green cells</p> <p align="center">The total VOC emissions for the month are in the red cells</p> <p align="center">IMPORTANT: Do not change any other cells without consulting the AQ CoE</p>		
MONTH:	December	
GENERAL INFORMATION:		
	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	767,516	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH		
	Data	Unit
Daily average ambient temperature	27,35	°C
Daily maximum ambient temperature	33,26	°C
Daily minimum ambient temperature	21,97	°C
Daily ambient temperature range	11,30	°C
Daily total insolation factor	6,12	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
FINAL OUTPUT:		
	Result	Unit
Breathing losses:	0,57 kg/month	
Working losses:	0,02 kg/month	
TOTAL LOSSES (Total TVOC Emissions for the month):	0,59 kg/month	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.5 Daily power generated

Table 5: Daily power generated per unit in MWh for the month of December 2022

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2022/12/01	11895	11850	10680	11230	10860	12395
2022/12/02	11652	11244	10118	10752	10382	12705
2022/12/03	10285	11016	9860	8188	10658	11658
2022/12/04	11015	11178	10344	0	11997	12260
2022/12/05	11613	11353	10312	0	11634	12723
2022/12/06	11922	11578	10936	0	12267	12614
2022/12/07	12048	11545	11727	0	13539	13176
2022/12/08	11862	10712	12353	0	12661	13010
2022/12/09	11863	11135	11552	5333	13192	13157
2022/12/10	11502	10836	10847	12347	12828	13145
2022/12/11	11230	10572	11906	12041	12303	12702
2022/12/12	11344	9941	12204	10838	12606	13066
2022/12/13	10989	10184	11838	10028	13048	13404
2022/12/14	10688	10649	11836	11855	12132	13018
2022/12/15	11186	10474	11464	10266	11349	12593
2022/12/16	10344	6443	11945	9559	12479	12571
2022/12/17	10614	0	12018	10188	12328	11999
2022/12/18	10338	0	11590	10039	12037	11253
2022/12/19	11423	0	12094	10907	12058	12117
2022/12/20	10705	457	11832	9893	11250	12201
2022/12/21	10704	9915	12327	11008	4928	12581
2022/12/22	11538	10405	12578	11335	9324	12883
2022/12/23	11415	10629	12362	10873	3044	12783
2022/12/24	10121	10337	10682	9387	0	12101
2022/12/25	8966	9629	10818	9677	0	12046
2022/12/26	3861	8937	10639	9783	9140	11992
2022/12/27	0	9559	11377	10191	11992	12658
2022/12/28	0	9088	11227	10136	9856	10690
2022/12/29	0	8493	11044	10445	9616	10429
2022/12/30	0	8495	11775	11713	11286	11908
2022/12/31	0	10517	12304	10340	12657	11215

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 1 daily generated power in MWh for the month of December 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 21: Unit 2 daily generated power in MWh for the month of December 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 22: Unit 3 daily generated power in MWh for the month of December 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 23: Unit 4 daily generated power in MWh for the month of December 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 24: Unit 5 daily generated power in MWh for the month of December 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 25: Unit 6 daily generated power in MWh for the month of December 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Pollutant Tonnages

The emitted pollutant tonnages for December 2022 are provided in table 6. CO₂ values for units 2, 3 and 5 were calculated per balance, from O₂ values, due to analyser providing unreliable data. Averaged quality assurance level 2 test values for O₂ were used for Unit 1 to 6 due to the analysers being providing unreliable data. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

Table 6: Pollutant tonnages for the month of December 2022

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	78,8	4 114,1	594,5
Unit 2	68,0	6 083,8	809,4
Unit 3	46,2	6 144,8	865,9
Unit 4	49,2	3 889,8	718,2
Unit 5	74,6	3 713,0	482,6
Unit 6	79,3	6 071,5	881,7
SUM	396,1	30 017,1	4 352,3

2.7 Reference values

Table 7: Reference values for data provided, December 2022

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	5,08	8,20	4,71	7,28	7,28	6,93
Moisture	%	4,86	4,38	6,11	3,68	5,21	2,86
Velocity	m/s	24,4	33,9	25,4	22,5	27,2	29,0
Temperature	°C	138,8	122,3	128,6	132,3	121,4	124,1
Pressure	mBar	931,4	935,1	914,8	906,1	931,9	914,1

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Continuous Emission Monitors

2.8.1 Reliability

Continuous emission monitors were available for more than 80% of the reporting period. The emitted pollutant tonnages for December 2022 are provided in table 6. CO₂ values for units 2, 3 and 5 were calculated per balance, from O₂ values, due to analyser providing unreliable data. Averaged quality assurance level 2 test values for O₂ were used for Unit 1 to 6 due to the analysers being providing unreliable data. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

Table 8: Average percentage (%) availability of monitors for the month of December 2022.

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	100,0	99,8	99,8
Unit 2	100,0	95,4	81,5
Unit 3	100,0	99,7	99,7
Unit 4	100,0	99,8	99,8
Unit 5	100,0	99,9	98,4
Unit 6	100,0	91,9	91,8

2.8.2 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 5

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 6

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

2.8.3 Sampling dates and times

Table 9: Dates of last conducted CEMS verification tests for PM, SO₂ and NO_x

Name of service provider:		Stacklabs Environmental Services CC		
Address of service provider:		10 Chisel Street Boltonia Krugersdorp 1739		
Stack/ Unit	PM	SO ₂	NO _x	CO ₂
1	2020/09/30 06h04	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00
2	2021/01/26 04h52	2021/01/27 13h00	2021/01/27 13h00	2021/01/27 13h00
3	2021/08/10 12h05	2020/09/24 07h00	2020/09/24 07h00	2020/09/24 07h00
4	2021/07/13 14h31	2020/09/16 02h00	2020/09/16 02h00	2020/09/16 02h00
5	2020/10/06 05h39	2020/10/08 02h30	2020/10/08 02h30	2020/10/08 02h30
6	2020/09/09 06h41	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00

2.9 Units Start-up information

Table 10: Start-up information

Unit	2	
Fires in	2022/12/20	13h26
Synchronization with Grid	2022/12/20	20h40
Emissions below limit	2022/01/21	10h00
Fires in to synchronization	32,2	HOURS
Synchronization to < Emission limit	13,3	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	4	
Fires in	2022/12/08	23h38
Synchronization with Grid	2022/12/09	09h31
Emissions below limit	2022/01/21	10h00
Fires in to synchronization	9,8	HOURS
Synchronization to < Emission limit	0,48	HOURS

Unit	5	
Fires in	2022/12/21	11h20
Synchronization with Grid	2022/12/22	01h23
Emissions below limit	2022/12/22	01h23
Fires in to synchronization	14,05	HOURS
Synchronization to < Emission limit	0	HOURS

Unit	5	
Fires in	2022/12/25	21h30
Synchronization with Grid	2022/12/26	03h07
Emissions below limit	2022/12/26	03h07
Fires in to synchronization	5,6	HOURS
Synchronization to < Emission limit	0	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10 Emergency generation

Table 11: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control						
Emergency Hours declared including hours after stand down						
Days over the Limit during Emergency Generation						

During the period under review all Units were on emergency generation in force from 01 December 2022 until 31 December 2022.

2.11 Complaints register

Table 12: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
N/A					

2.12 Air quality improvements and social responsibility conducted

2.12.1 Air quality improvements

None

2.12.2 Social responsibility conducted

None

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.13 Ambient air quality monitoring

Ambient air quality monitoring report was not available at the time of publishing this report.

2.14 Electrostatic precipitator and Sulphur plant status

Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 2

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 3

- All precipitator fields in service. Unit shut down for outage
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 4

- 3 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 5

- 4 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 6

- 2 fields out of service, will be inspected next opportunity.
- Hole in burner casing and sulphur leak causing low availability. Preventative maintenance done during the month.

SO3 common plant

- No abnormalities on the sulphur storage plant.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.15 General

Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

None

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely

Wikus van Rensburg 2023-02-03

GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.