

	<b>Matimba Power Station Emissions report</b>	<b>Matimba Power Station</b>
---	---	------------------------------

Title: **Matimba Power Station February  
2023 emissions report**

Document Identifier: **RP/247/031**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area  
Applicability: **Environment**

Revision: **1**

Total Pages: **40**

Report Date: **February 2023**

Disclosure  
Classification: **Controlled**

**Compiled by**

**Functional Responsibility**

**Authorized by**





**KH Ramahlare  
Environmental Officer**

**MC Mamabolo  
Environmental Manager**

**Obakeng Mabotja  
General Manager**

Date: 2023-04-05

Date: 12/04/2023

Date: 2023/04/12

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics .....	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions .....	6
2.4.2 Gaseous Emissions .....	12
2.4.3 Total Volatile Organic Compounds .....	25
2.4.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	26
2.5 Daily power generated .....	26
2.6 Pollutant tonnages .....	33
2.7 Reference values .....	33
2.8 Continuous Emission Monitors.....	34
2.8.1 Reliability.....	34
2.8.2 Changes, downtime, and repairs .....	34
2.8.3 Sampling dates and times.....	35
2.9 Units Start-up information .....	35
2.10 Emergency generation .....	36
2.11 Complaints register .....	36
2.12 Air quality improvements and social responsibility conducted .....	37
2.12.1 Air quality improvements.....	37
2.12.2 Social responsibility conducted.....	37
2.13 Ambient air quality monitoring.....	38
2.14 Electrostatic precipitator and Sulphur plant status .....	38
2.15 General.....	39
3. Attachments.....	39
4. Report Conclusion .....	39
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics. ....	6
Table 4: Total volatile compound estimates .....	25
Table 5: Daily power generated per unit in MWh for the month of February 2023 .....	26
Table 6: Pollutant tonnages for the month of February 2023 .....	33
Table 7: Reference values for data provided, February 2023.....	33
Table 8: Average percentage (%) availability of monitors for the month of February 2023. ....	34
Table 9: Dates of last conducted CEMS verification tests for PM, SO <sub>2</sub> and NO <sub>x</sub> .....	35

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Start-up information .....	35
Table 11: Emergency generation .....	36
Table 12: Complaints.....	36

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of February 2023 .....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of February 2023 .....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of February 2023 .....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of February 2023 .....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of February 2023 .....	10
Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of February 2023 .....	11
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of February 2023 .....	13
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of February 2023 .....	14
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of February 2023 .....	15
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of February 2023 .....	16
Figure 11: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of February 2023 .....	17
Figure 12: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of February 2023 .....	18
Figure 13: Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 1 for the month of February 2023 .....	19
Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 2 for the month of February 2023 .....	20
Figure 16: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of February 2023 .....	21
Figure 17: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of February 2023 .....	22
Figure 18: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of February 2023 .....	23
Figure 19: NO <sub>x</sub> daily average emissions against emission limit for unit 6 for the month of February 2023 .....	24
Figure 20: Unit 1 daily generated power in MWh for the month of February 2023 .....	27
Figure 21: Unit 2 daily generated power in MWh for the month of February 2023 .....	28
Figure 22: Unit 3 daily generated power in MWh for the month of February 2023 .....	29
Figure 23: Unit 4 daily generated power in MWh for the month of February 2023 .....	30
Figure 24: Unit 5 daily generated power in MWh for the month of February 2023 .....	31
Figure 25: Unit 6 daily generated power in MWh for the month of February 2023 .....	32

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for February 2023.



During the period under review, Matimba experienced 30 exceedances of the daily particulate matter emission limit (50mg/Nm<sup>3</sup>), 7 of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence.

No exceedances of the monthly SO<sub>x</sub> limit (3500mg/Nm<sup>3</sup>) or the daily NO<sub>x</sub> emission limit (750mg/Nm<sup>3</sup>) occurred. The gaseous emissions monitors for all 6 units are providing unreliable data due to the movement of the Oxygen analyzer ports that were previously installed incorrectly to a new correct position. The project to relocate the Oxygen analyzer ports was completed in November 2022 as part of the activities to implement the changes on gaseous emission analyzers to improve the reliability of the data. The station is currently preparing to perform the quality assurance tests and calibrations on the monitors post the changes implemented as per the program shared under point 2.4.2 of this report.

The Sulphur conditioning plant for unit 2 and unit 3 did not achieve the required 100% availability due to the defects and breakdown experienced on the plants. The SO<sub>3</sub> plants were repaired and operating as normal.

More information regarding above mentioned issues is provided in the relevant sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	979 038
	Fuel Oil	Tons/month	1 200	774,442
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	2640,36756

The consumption rates for the month of February 2023 were within the permitted maximum limits.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,86%
Unit 2	Electrostatic Precipitator	100%	99,81%
Unit 3	Electrostatic Precipitator	100%	99,88%
Unit 4	Electrostatic Precipitator	100%	99,88%
Unit 5	Electrostatic Precipitator	100%	99,86%
Unit 6	Electrostatic Precipitator	100%	99,89%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	99%
Unit 2	SO <sub>3</sub> Plant	100%	87%
Unit 3	SO <sub>3</sub> Plant	100%	95%
Unit 4	SO <sub>3</sub> Plant	100%	99%
Unit 5	SO <sub>3</sub> Plant	100%	99%
Unit 6	SO <sub>3</sub> Plant	100%	99%

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was below the required 100% for all six (06) units due to maintenance activities and unplanned breakdowns. Defects were addressed and plants returned to services. Unit 2 SO<sub>3</sub> plant was taken out of service from the 31 January 2023 due to the defect on the air conditioning drainage pipe that was found broken and discharging the water into that panels. The plant was repaired and put back in service on the 04 February 2023. Notification for Unit 2 breakdown was sent to the authorities on the 02 February 2023. Unit 3 SO<sub>3</sub> plant was off for 12 hours on 27 February 2023 due to damaged Sulphur Burner inlet, the defects were addressed, and plants returned to services on the 28 February 2023.

## 2.3 Energy source characteristics

**Table 3:** Energy Source Material Characteristics.


	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,34%
	Ash Content	40%	34,06%

Energy source characteristics remained within the ranges stipulated in the license.

## 2.4 Emissions reporting

### 2.4.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions



**Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of February 2023**


**Interpretation:** Unit 1 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 14, 19, 21, 22, 24, 26 and 27 February 2023. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The plant was repaired, and emissions returned to below the set limit. The exceedance remained within the 48-hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of February 2023**

**Interpretation:**


Unit 2 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1, 2, 3, 4, 5, 12, 13, 14, 24, and 25 February 2023. 6 exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedance on 1 to 5 February 2023 were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields) and the unavailability of the SO<sub>3</sub> plant due to defects and breakdowns. The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes. The notification to the authorities for the unavailability of the SO<sub>3</sub> plant was done on the 02 February 2023.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 3 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of February 2023**

#### Interpretation:

Unit 3 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 28 February 2023. The exceedance was due to the unavailability of the SO<sub>3</sub> that was off for 12 hours on 27 February 2023 due to damaged Sulphur Burner inlet, the defects were addressed, and plants returned to services on the late hours of 28 February 2023.


#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of February 2023**

**Interpretation:**


Unit 4 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 27 and 28 February 2023. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of February 2023**

**Interpretation:**


Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 3, 4, 7, 8, 9, 12, 13, 14 and 26 February 2023. The exceedances on 14 February 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 6 Particulate Emissions



**Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of February 2023**

**Interpretation:**

Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 25 February 2023. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The exceedances remained within the 48-hour grace period.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.2 Gaseous Emissions


The gaseous emissions monitors for all 6 units are providing unreliable data due to the movement of the Oxygen analyser ports that were previously installed incorrectly to a new correct position. The project to relocate the Oxygen analyser ports was completed in November 2022 as part of the activities to implement the changes on gaseous emission analysers to improve the reliability of the data. The benefit of the movement of analyser ports will be seen once the O2 monitors are calibrated with the certified gas and valid gas parallel test done on all gas parameters. The station is currently preparing to perform the quality assurance tests and calibrations on the monitors post the changes implemented as per the below program.

Date	Stack/Point	Activity – 3 people	Requests and Comments
Tuesday, 11 April 2023		Travel to Matimba and setup	
Wednesday, 12 April 2023		QAL2 Correlation Tests 1-3 (100% MCR)	
Thursday, 13 April 2023		QAL2 Correlation Tests 4-7 (100% MCR)	
Friday, 14 April 2023		QAL2 Correlation Tests 8-11 (80% MCR)	
Saturday, 15 April 2023		QAL2 Correlation Tests 12-15 (60% MCR)	
Sunday, 16 April 2023		Off	
Monday, 17 April 2023		QAL2 & PM Correlation Tests 1-3 (100% MCR)	Eskom to send Gas data for unit 1
Tuesday, 18 April 2023		QAL2 & PM Correlation Tests 4-7 (100% MCR)	
Wednesday, 19 April 2023		QAL2 & PM Correlation Tests 8-11 (80% MCR)	
Thursday, 20 April 2023		QAL2 & PM Correlation Tests 12-15 (60% MCR)	
Friday, 21 April 2023		QAL2 & PM Correlation Tests 1-3 (100% MCR)	Eskom to send Gas and PM CEM data for unit 2
Saturday, 22 April 2023		Off	
Sunday, 23 April 2023		Off	
Monday, 24 April 2023		QAL2 & PM Correlation Tests 4-7 (100% MCR)	
Tuesday, 25 April 2023		QAL2 & PM Correlation Tests 8-11 (80% MCR)	
Wednesday, 26 April 2023		QAL2 & PM Correlation Tests 12-15 (60% MCR)	
Thursday, 27 April 2023		Relocate to another Stack	Eskom to send Gas and PM CEM data for unit 3
Friday, 28 April 2023		QAL2 & PM Correlation Tests 1-3 (100% MCR)	
Saturday, 29 April 2023		QAL2 & PM Correlation Tests 4-7 (100% MCR)	
Sunday, 30 April 2023		Off	
Monday, 01 May 2023		QAL2 & PM Correlation Tests 8-11 (80% MCR)	Unit 1 report due
Tuesday, 02 May 2023		QAL2 & PM Correlation Tests 12-15 (60% MCR)	Eskom to send Gas and PM CEM data for unit 4
Wednesday, 03 May 2023		QAL2 & PM Correlation Tests 1-3 (100% MCR)	
Thursday, 04 May 2023		QAL2 & PM Correlation Tests 4-7 (100% MCR)	
Friday, 05 May 2023		QAL2 & PM Correlation Tests 8-11 (80% MCR)	Unit 2 report due
Saturday, 06 May 2023		QAL2 & PM Correlation Tests 12-15 (60% MCR)	
Sunday, 07 May 2023		Site De-establishment and travel back to JHB	
Monday, 08 May 2023		Off	
Tuesday, 09 May 2023			Eskom to send Gas and PM CEM data for unit 6
Wednesday, 10 May 2023			
Thursday, 11 May 2023			
Friday, 12 May 2023			Unit 3 report due
Saturday, 06 May 2023			
Sunday, 07 May 2023			
Monday, 08 May 2023			
Tuesday, 09 May 2023			Unit 4 report due
Wednesday, 10 May 2023			
Thursday, 11 May 2023			
Friday, 12 May 2023			
Saturday, 13 May 2023			
Sunday, 14 May 2023			
Monday, 15 May 2023			
Tuesday, 16 May 2023			Unit 6 report due
Wednesday, 17 May 2023			
Thursday, 18 May 2023			
Friday, 19 May 2023			

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 SO<sub>2</sub> Emissions

**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of February 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO<sub>2</sub> Emissions

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of February 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO<sub>2</sub> Emissions

**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of February 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 4 SO<sub>2</sub> Emissions**

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of February 2023**

**Interpretation:**


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



Unit 5 SO<sub>2</sub> Emissions

**Figure 11: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of February 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Unit 6 SO<sub>2</sub> Emissions**

**Figure 12: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of February 2023**


**Interpretation:**

All daily averages remained below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 1 NO<sub>x</sub> Emissions**Figure 13: Matimba Unit 1 NO<sub>x</sub> Emissions - February 2023****Figure 13: Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of February 2023****Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO<sub>x</sub> Emissions

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of February 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO<sub>x</sub> Emissions

**Figure 16: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of February 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO<sub>x</sub> Emissions

**Figure 17: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of February 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO<sub>x</sub> Emissions

**Figure 18: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of February 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 NO<sub>x</sub> Emissions

**Figure 19: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of February 2023**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



### 2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
<b>CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*</b>		
Date:	Thursday, 16 March 2023	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <b>blue cells</b> below</p> <p align="center">Choose from a dropdown menu in the <b>green cells</b></p> <p align="center">The total VOC emissions for the month are in the <b>red cells</b></p> <p align="center">IMPORTANT: Do not change <b>any</b> other cells without consulting the AQ CoE</p>		
MONTH:	February	
<b>GENERAL INFORMATION:</b>		
	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	744,442	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>		
	Data	Unit
Daily average ambient temperature	26,20	°C
Daily maximum ambient temperature	32,94	°C
Daily minimum ambient temperature	20,71	°C
Daily ambient temperature range	12,24	°C
Daily total insolation factor	5,72	kWh/m <sup>2</sup> /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
<b>FINAL OUTPUT:</b>		
	Result	Unit
Breathing losses:	0,57 kg/month	
Working losses:	0,02 kg/month	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0,59 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.5 Daily power generated


**Table 5:** Daily power generated per unit in MWh for the month of February 2023

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2023/02/01	10444	10328	11308	12485	10957	12343
2023/02/02	10653	9747	11603	13204	10144	12459
2023/02/03	10625	8463	11137	13091	9679	12147
2023/02/04	10475	8494	11244	12329	8616	11054
2023/02/05	10408	8483	10796	12045	8618	10968
2023/02/06	9405	10098	11576	12975	9725	11832
2023/02/07	10342	10536	12153	12739	10334	12152
2023/02/08	10692	10239	11950	12644	8876	11117
2023/02/09	10294	9712	12589	12445	8735	11437
2023/02/10	10226	9850	12631	12643	8736	12287
2023/02/11	0	9887	12174	11548	8742	11950
2023/02/12	0	9529	10773	12066	9163	11810
2023/02/13	10311	9190	12890	12832	8741	11768
2023/02/14	12583	8904	12991	13063	8777	10580
2023/02/15	12098	9653	12531	12645	10334	12457
2023/02/16	12765	10813	11840	11963	10838	11965
2023/02/17	12476	11056	12194	12183	10210	11836
2023/02/18	12015	11054	12031	12230	9584	11864
2023/02/19	9900	11069	11851	12487	9789	11861
2023/02/20	10622	11125	12601	12723	10517	11602
2023/02/21	10142	11236	11764	11661	9753	10754
2023/02/22	9886	10683	12656	12595	10538	11298
2023/02/23	8969	10682	13125	10416	11075	10784
2023/02/24	11370	10390	12827	10166	10625	10395
2023/02/25	11927	9920	2039	10316	10873	9385
2023/02/26	11567	464	0	10339	10612	10231
2023/02/27	12069	0	5648	8907	10864	10827
2023/02/28	10928	0	12006	8554	10037	11265

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.


No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Figure 20: Unit 1 daily generated power in MWh for the month of February 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 21: Unit 2 daily generated power in MWh for the month of February 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 22: Unit 3 daily generated power in MWh for the month of February 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 23: Unit 4 daily generated power in MWh for the month of February 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 24: Unit 5 daily generated power in MWh for the month of February 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 25: Unit 6 daily generated power in MWh for the month of February 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.6 Pollutant Tonnages

The emitted pollutant tonnages for February 2023 are provided in table 6. Gaseous emissions analysers for all 6 units are providing unreliable data due to the movement of the Oxygen analyser port to a new position. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

**Table 6:** Pollutant tonnages for the month of February 2023

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	CO <sub>2</sub> (tons)
Unit 1	69,8	4 412,2	593,5	336 507
Unit 2	79,8	6 317,8	899,3	365 657
Unit 3	59,3	5 735,0	775,1	374 071
Unit 4	66,7	5 298,8	975,2	321 509
Unit 5	63,9	2 902,9	361,1	197 990
Unit 6	62,0	3 575,5	518,5	274 600
<b>SUM</b>	401,5	28 242,2	4 122,6	1 870 334

## 2.7 Reference values

**Table 7:** Reference values for data provided, February 2023

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	5,31	8,88	4,48	6,92	6,04	4,58
Moisture	%	5,35	4,25	6,38	3,93	4,70	1,77
Velocity	m/s	23,7	33,5	26,2	25,3	23,8	23,9
Temperature	°C	144,4	123,4	127,1	133,9	114,7	157,8
Pressure	mBar	931,4	935,9	915,4	905,9	934,2	899,5

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.8 Continuous Emission Monitors

### 2.8.1 Reliability

Continuous emission monitors were available for more than 80% of the reporting period. The emitted pollutant tonnages for February 2023 are provided in table 6. Gaseous emissions analysers for all 6 units are providing unreliable data due to the movement of the Oxygen analyser port to a new position. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

**Table 8:** Average percentage (%) availability of monitors for the month of February 2023.

Associated Unit/Stack	PM	SO <sub>2</sub>	NO
Unit 1	100,0	99,8	99,8
Unit 2	100,0	79,3	79,3
Unit 3	100,0	99,8	99,7
Unit 4	99,7	99,9	100,0
Unit 5	100,0	100,0	87,4
Unit 6	100,0	90,2	84,4

### 2.8.2 Changes, downtime, and repairs

#### Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 5

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 6

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- No downtime or repairs done on the particulate monitors

### 2.8.3 Sampling dates and times

**Table 9:** Dates of last conducted CEMS verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub>

<b>Name of service provider:</b>		Stacklabs Environmental Services CC		
<b>Address of service provider:</b>		10 Chisel Street Boltonia Krugersdorp 1739		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
1	2020/09/30 06h04	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00
2	2021/01/26 04h52	2021/01/27 13h00	2021/01/27 13h00	2021/01/27 13h00
3	2021/08/10 12h05	2020/09/24 07h00	2020/09/24 07h00	2020/09/24 07h00
4	2021/07/13 14h31	2020/09/16 02h00	2020/09/16 02h00	2020/09/16 02h00
5	2020/10/06 05h39	2020/10/08 02h30	2020/10/08 02h30	2020/10/08 02h30
6	2020/09/09 06h41	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00

## 2.9 Units Start-up information

**Table 10:** Start-up information

<b>Unit</b>	1	
<b>Fires in</b>	2023/02/12	21h10
<b>Synchronization with Grid</b>	2023/03/13	02h40
<b>Emissions below limit</b>	2023/03/13	12h01
<b>Fires in to synchronization</b>	5,30	HOURS
<b>Synchronization to &lt; Emission limit</b>	9,21	HOURS

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	3	
<b>Fires in</b>	2023/02/27	04h50
<b>Synchronization with Grid</b>	2023/02/27	08h43
<b>Emissions below limit</b>	2023/02/27	11h02
<b>Fires in to synchronization</b>	3,53	HOURS
<b>Synchronization to &lt; Emission limit</b>	2,19	HOURS

## 2.10 Emergency generation

**Table 11:** Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
<b>Emergency Generation hours declared by national Control</b>						
<b>Emergency Hours declared including hours after stand down</b>						
<b>Days over the Limit during Emergency Generation</b>						

During the period under review all Units were on emergency generation in force from 01 February 2023 until 28 February 2023.

## 2.11 Complaints register

**Table 12:** Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
N/A					

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.12 Air quality improvements and social responsibility conducted**

### **2.12.1 Air quality improvements**

None

### **2.12.2 Social responsibility conducted**

None

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.13 Ambient air quality monitoring

Ambient air quality monitoring report was not available at the time of publishing this report.

## 2.14 Electrostatic precipitator and Sulphur plant status

### Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 2

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 3

- All precipitator fields in service.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 4

- 3 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 5

- 4 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 6

- 2 fields out of service, will be inspected next opportunity.
- Hole in burner casing and sulphur leak causing low availability. Preventative maintenance done during the month.

### SO3 common plant

- No abnormalities on the sulphur storage plant.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.15 General

### Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

### Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

None

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.