

|   |   |                              |
|---|---|------------------------------|
|  | <b>Matimba Power Station Emissions<br/>report</b> | <b>Matimba Power Station</b> |
|---|---|------------------------------|

Title: **Matimba Power Station January  
2023 emissions report**

Document Identifier: **RP/247/030**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area  
Applicability: **Environment**

Revision: **1**

Total Pages: **38**

Report Date: **January 2023**


Disclosure  
Classification: **Controlled**

**Compiled by**

**Functional Responsibility**

**Authorized by**





**KH Ramahlare  
Environmental Officer**

**MC Mamabolo  
Environmental Manager**

**Obakeng Mabotja  
General Manager**

Date: 2023-03-09

Date: 14/03/2023

Date: 2023-03-16

## Content

|  | Page |
|--|------|
| 1. Report Summary .....  | 4    |
| 2. Emission information .....  | 5    |
| 2.1 Raw materials and products.....  | 5    |
| 2.2 Abatement technology.....  | 5    |
| 2.3 Energy source characteristics .....  | 6    |
| 2.4 Emissions reporting.....   | 6    |
| 2.4.1 Particulate Matter Emissions .....   | 6    |
| 2.4.2 Gaseous Emissions .....  | 12   |
| 2.4.3 Total Volatile Organic Compounds .....   | 24   |
| 2.4.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....  | 25   |
| 2.5 Daily power generated .....  | 25   |
| 2.6 Pollutant Tonnages .....   | 32   |
| 2.7 Reference values .....   | 32   |
| 2.8 Continuous Emission Monitors.....  | 33   |
| 2.8.1 Reliability.....   | 33   |
| 2.8.2 Changes, downtime, and repairs .....   | 33   |
| 2.8.3 Sampling dates and times.....  | 34   |
| 2.9 Units Start-up information .....   | 34   |
| 2.10 Emergency generation .....  | 36   |
| 2.11 Complaints register .....   | 36   |
| 2.12 Air quality improvements and social responsibility conducted .....                                    | 36   |
| 2.12.1 Air quality improvements.....   | 36   |
| 2.12.2 Social responsibility conducted.....  | 36   |
| 2.13 Ambient air quality monitoring.....   | 37   |
| 2.14 Electrostatic precipitator and Sulphur plant status.....  | 37   |
| 2.15 General.....  | 38   |
| 3. Attachments.....  | 38   |
| 4. Report Conclusion .....   | 38   |
| Table 1: Quantity of Raw Materials and Products used/produced for the month.....                           | 5    |
| Table 2: Abatement Equipment Control Technology Utilised.....  | 5    |
| Table 3: Energy Source Material Characteristics. ....  | 6    |
| Table 4: Total volatile compound estimates .....   | 24   |
| Table 5: Daily power generated per unit in MWh for the month of January 2023.....                          | 25   |
| Table 6: Pollutant tonnages for the month of January 2023.....   | 32   |
| Table 7: Reference values for data provided, January 2023.....   | 32   |
| Table 8: Average percentage (%) availability of monitors for the month of January 2023.....                | 33   |
| Table 9: Dates of last conducted CEMS verification tests for PM, SO <sub>2</sub> and NO <sub>x</sub> ..... | 34   |

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

|                                      |    |
|--------------------------------------|----|
| Table 10: Start-up information ..... | 34 |
| Table 11: Emergency generation ..... | 36 |
| Table 12: Complaints.....            | 36 |

## Figures

|  |    |
|--|----|
| Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of January 2023.....          | 6  |
| Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of January 2023.....          | 7  |
| Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of January 2023.....          | 8  |
| Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of January 2023.....          | 9  |
| Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of January 2023.....          | 10 |
| Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of January 2023.....          | 11 |
| Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of January 2023 .....            | 12 |
| Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of January 2023 .....            | 13 |
| Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of January 2023 .....            | 14 |
| Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of January 2023 .....           | 15 |
| Figure 11: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of January 2023 .....           | 16 |
| Figure 12: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of January 2023 .....           | 17 |
| Figure 13: Figure 14: NO <sub>x</sub> daily average emissions against emission limit for unit 1 for the month of January 2023..... | 18 |
| Figure 15: NO <sub>x</sub> daily average emissions against emission limit for unit 2 for the month of January 2023 .....           | 19 |
| Figure 16: NO <sub>x</sub> daily average emissions against emission limit for unit 3 for the month of January 2023 .....           | 20 |
| Figure 17: NO <sub>x</sub> daily average emissions against emission limit for unit 4 for the month of January 2023 .....           | 21 |
| Figure 18: NO <sub>x</sub> daily average emissions against emission limit for unit 5 for the month of January 2023 .....           | 22 |
| Figure 19: NO <sub>x</sub> daily average emissions against emission limit for unit 6 for the month of January 2023 .....           | 23 |
| Figure 20: Unit 1 daily generated power in MWh for the month of January 2023 .....   | 26 |
| Figure 21: Unit 2 daily generated power in MWh for the month of January 2023 .....   | 27 |
| Figure 22: Unit 3 daily generated power in MWh for the month of January 2023 .....   | 28 |
| Figure 23: Unit 4 daily generated power in MWh for the month of January 2023 .....   | 29 |
| Figure 24: Unit 5 daily generated power in MWh for the month of January 2023 .....   | 30 |
| Figure 25: Unit 6 daily generated power in MWh for the month of January 2023 .....   | 31 |

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for January 2023.



During the period under review, Matimba experienced 22 exceedances of the daily particulate matter emission limit (50mg/Nm<sup>3</sup>), 3 of these exceedances occurred outside of the 48-hour grace period and were reported as section 30 incidents. No exceedances of the monthly SO<sub>x</sub> limit (3500mg/Nm<sup>3</sup>) or the daily NO<sub>x</sub> emission limit (750mg/Nm<sup>3</sup>) occurred.

The Sulphur conditioning plant for unit 6 and unit 2 did not achieve the required 100% availability due to the defects and breakdown experienced on the plants. The SO<sub>3</sub> plants were repaired and operating as normal.

More information regarding above mentioned issues is provided in the relevant sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

| Raw Materials and Products used | Raw Material Type        | Unit       | Maximum Permitted Consumption Rate (Quantity)    | Consumption Rate |
|---------------------------------|--------------------------|------------|--|------------------|
|                                 | Coal                     | Tons/month | 1 500 000  | 1 088 708        |
|                                 | Fuel Oil                 | Tons/month | 1 200  | 740,646          |
| Production Rates                | Product/ By-Product Name | Unit       | Maximum Production Capacity Permitted (Quantity) | Production Rate  |
|                                 | Energy                   | MW         | 4000   | 2612,008         |
|                                 |                          |            |  |                  |

The consumption rates for the month of January 2023 were within the permitted maximum limits.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

| Associated Unit | Technology Type            | Minimum utilisation (%) | Efficiency (%)         |
|-----------------|----------------------------|-------------------------|------------------------|
| Unit 1          | Electrostatic Precipitator | 100%                    | 99,86%                 |
| Unit 2          | Electrostatic Precipitator | 100%                    | 99,89%                 |
| Unit 3          | Electrostatic Precipitator | 100%                    | 99,92%                 |
| Unit 4          | Electrostatic Precipitator | 100%                    | 99,90%                 |
| Unit 5          | Electrostatic Precipitator | 100%                    | 99,86%                 |
| Unit 6          | Electrostatic Precipitator | 100%                    | 99,88%                 |
| Associated Unit | Technology Type            | Minimum utilisation (%) | Actual Utilisation (%) |
| Unit 1          | SO <sub>3</sub> Plant      | 100%                    | 100%                   |
| Unit 2          | SO <sub>3</sub> Plant      | 100%                    | 99%                    |
| Unit 3          | SO <sub>3</sub> Plant      | 100%                    | 98%                    |
| Unit 4          | SO <sub>3</sub> Plant      | 100%                    | 97%                    |
| Unit 5          | SO <sub>3</sub> Plant      | 100%                    | 95%                    |
| Unit 6          | SO <sub>3</sub> Plant      | 100%                    | 91%                    |

Flue gas conditioning plant availability was below the required 100% for all six (05) units due to maintenance activities and unplanned breakdowns. Defects were addressed and plants returned to services.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.3 Energy source characteristics

**Table 3:** Energy Source Material Characteristics.


|             | Characteristic  | Stipulated Range (Unit) | Monthly Average Content |
|-------------|-----------------|-------------------------|-------------------------|
| Coal burned | Sulphur Content | 1.6%                    | 1,34%                   |
|             | Ash Content     | 40%                     | 34,83%                  |

Energy source characteristics remained within the ranges stipulated in the license.

## 2.4 Emissions reporting

### 2.4.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions



**Figure 1:** Particulate matter daily average emissions against emission limit for unit 1 for the month of January 2023

#### Interpretation:


Unit 1 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 18, 19, 25, 26, 29 and 30 January 2023. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The plant was repaired, and emissions returned to below the set limit. The exceedance remained within the 48-hour grace period.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of January 2023**

#### Interpretation:


Unit 2 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 20, 29, and 30 January 2023. The exceedance on 20 January 2023 was due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The exceedances on the 29,30 and 31 January 2023 were due to the unavailability of the SO<sub>3</sub> plant due to defects and breakdowns. The 48 hours grace period for exceedance was reached on the 31 January 2023 01:00am and the incident was reported to the authorities.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 3 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of January 2023**

#### Interpretation:

Unit 3 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 30 January 2023. The exceedance was due to breakdowns on the ash removal system leading to ash backlog within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The defective plants were repaired, and the exceedances remained within the 48-hour grace period.


#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of January 2023**

**Interpretation:**


Unit 4 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 24,25 ,26 and 27 January 2023. The exceedances on 24 ,25, 26 & 27 January 2023 were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The 48 hours grace period for exceedance was reached on the 26 January 2023 01:00am and the incident was reported to the authorities.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of January 2023**

**Interpretation:**


Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 11, 20, 27, 28, and 29 January 2023. The exceedances on 11, 20, 27, 28 and 29 January 2023 were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The 48 hours grace period for exceedance was reached on the 29 January 2023 01:00am and the incident was reported to the authorities.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 6 Particulate Emissions



**Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of January 2023**

**Interpretation:**

Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 17 and 18 January 2023. The exceedances were due to the unavailability of the SO<sub>3</sub> plant due to defects and breakdowns. The defective plants were repaired and returned back in-service. The exceedances remained within the 48-hour grace period.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.4.2 Gaseous Emissions

### Unit 1 SO<sub>2</sub> Emissions




Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of January 2023


#### Interpretation:

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO<sub>2</sub> Emissions

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of January 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO<sub>2</sub> Emissions

**Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of January 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO<sub>2</sub> Emissions

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of January 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO<sub>2</sub> Emissions

**Figure 11: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of January 2023**

**Interpretation:**


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



Unit 6 SO<sub>2</sub> Emissions

**Figure 12: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of January 2023**


**Interpretation:**

All daily averages remained below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO<sub>x</sub> Emissions

**Figure 13: Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of January 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO<sub>x</sub> Emissions

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of January 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO<sub>x</sub> Emissions

**Figure 16: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of January 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO<sub>x</sub> Emissions

**Figure 17: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of January 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO<sub>x</sub> Emissions

**Figure 18: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of January 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 NO<sub>x</sub> Emissions

**Figure 19: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of January 2023**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.4.3 Total Volatile Organic Compounds

**Table 4:** Total volatile compound estimates

|  |  |             |
|--|--|-------------|
|   |  |             |
| <b>CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*</b>   |  |             |
| <b>Date:</b>   | Tuesday, 21 February 2023                  |             |
| <b>Station:</b>  | Matimba Power Station                      |             |
| <b>Province:</b>   | Limpopo Province                           |             |
| <b>Tank no.</b>  | 1-4  |             |
| <b>Description:</b>  | Outdoor fuel oil storage tank              |             |
| <b>Tank Type:</b>  | Vertical fixed roof (vented to atmosphere) |             |
| <b>Material stored:</b>  | Fuel Oil 150                               |             |
| <p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <b>blue cells</b> below</p> <p align="center">Choose from a dropdown menu in the <b>green cells</b></p> <p align="center">The total VOC emissions for the month are in the <b>red cells</b></p> <p align="center">IMPORTANT: Do not change <b>any</b> other cells without consulting the AQ CoE</p> |  |             |
| <b>MONTH:</b>  | January                                    |             |
| <b>GENERAL INFORMATION:</b>  | <b>Data</b>                                | <b>Unit</b> |
| Total number of fuel oil tanks:  | 4  | NA          |
| Height of tank:  | 13,34                                      | m           |
| Diameter of tank:  | 9,53                                       | m           |
| Net fuel oil throughput for the month:   | 740,646                                    |             |
| Molecular weight of the fuel oil:  | 166,00                                     | Lb/lb-mole  |
| <b>METEROLOGICAL DATA FOR THE MONTH</b>  | <b>Data</b>                                | <b>Unit</b> |
| Daily average ambient temperature  | 25,11                                      | °C          |
| Daily maximum ambient temperature  | 31,57                                      | °C          |
| Daily minimum ambient temperature  | 17,48                                      | °C          |
| Daily ambient temperature range  | 14,10                                      | °C          |
| Daily total insolation factor  | 5,87                                       | kWh/m²/day  |
| Tank paint colour  | Grey/medium                                | NA          |
| Tank paint solar absorbance  | 0,68                                       | NA          |
| <b>FINAL OUTPUT:</b>   | <b>Result</b>                              | <b>Unit</b> |
| Breathing losses:  | 0,60 kg/month                              |             |
| Working losses:  | 0,02 kg/month                              |             |
| <b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>  | <b>0,62 kg/month</b>                       |             |
| <p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>  |  |             |

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.4.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.5 Daily power generated


**Table 5:** Daily power generated per unit in MWh for the month of January 2023

| Date       | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|------------|--------|--------|--------|--------|--------|--------|
| 2023/01/01 | 0      | 11062  | 11646  | 10219  | 11032  | 10855  |
| 2023/01/02 | 0      | 10328  | 10607  | 10951  | 10469  | 11338  |
| 2023/01/03 | 0      | 10484  | 10434  | 10306  | 10385  | 11493  |
| 2023/01/04 | 0      | 10184  | 10895  | 10940  | 12038  | 11722  |
| 2023/01/05 | 0      | 10729  | 11938  | 12263  | 13245  | 12691  |
| 2023/01/06 | 0      | 10708  | 11141  | 11523  | 11870  | 11616  |
| 2023/01/07 | 0      | 10620  | 13026  | 12496  | 12899  | 12570  |
| 2023/01/08 | 0      | 11182  | 7765   | 11634  | 12168  | 12555  |
| 2023/01/09 | 0      | 10703  | 11764  | 10844  | 11896  | 12190  |
| 2023/01/10 | 7660   | 9764   | 10750  | 11046  | 12066  | 11663  |
| 2023/01/11 | 11011  | 9754   | 10595  | 10680  | 11338  | 11617  |
| 2023/01/12 | 11830  | 10511  | 10660  | 11324  | 10718  | 12097  |
| 2023/01/13 | 11606  | 10779  | 11187  | 11185  | 11786  | 11974  |
| 2023/01/14 | 12008  | 10466  | 11219  | 11696  | 12304  | 12440  |
| 2023/01/15 | 12491  | 10720  | 7422   | 11889  | 12121  | 11827  |
| 2023/01/16 | 12519  | 10597  | 10744  | 11972  | 12101  | 12356  |
| 2023/01/17 | 11769  | 11373  | 10992  | 11148  | 11713  | 10160  |
| 2023/01/18 | 11013  | 11157  | 11001  | 10869  | 12607  | 9891   |
| 2023/01/19 | 10502  | 11000  | 10957  | 10642  | 12841  | 11866  |
| 2023/01/20 | 4421   | 11058  | 10930  | 9875   | 12043  | 12303  |
| 2023/01/21 | 7664   | 10664  | 10927  | 10104  | 11054  | 12092  |
| 2023/01/22 | 9097   | 10622  | 10981  | 10288  | 11048  | 12377  |
| 2023/01/23 | 10619  | 11005  | 11055  | 10592  | 13047  | 12925  |
| 2023/01/24 | 10612  | 11262  | 11141  | 10483  | 13150  | 12720  |
| 2023/01/25 | 9057   | 10836  | 10731  | 9964   | 11934  | 12435  |
| 2023/01/26 | 8200   | 11124  | 11268  | 9375   | 10162  | 12448  |
| 2023/01/27 | 8175   | 10991  | 11420  | 8398   | 10209  | 12299  |
| 2023/01/28 | 9557   | 10306  | 10833  | 9821   | 9314   | 11722  |
| 2023/01/29 | 9158   | 9862   | 9454   | 10242  | 8447   | 11005  |
| 2023/01/30 | 9307   | 8480   | 11631  | 11431  | 8449   | 12296  |
| 2023/01/31 | 10060  | 10068  | 10558  | 11986  | 9027   | 12271  |

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 20: Unit 1 daily generated power in MWh for the month of January 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 21: Unit 2 daily generated power in MWh for the month of January 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 22: Unit 3 daily generated power in MWh for the month of January 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 23: Unit 4 daily generated power in MWh for the month of January 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 24: Unit 5 daily generated power in MWh for the month of January 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 25: Unit 6 daily generated power in MWh for the month of January 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.6 Pollutant Tonnages

The emitted pollutant tonnages for January 2023 are provided in table 6. CO<sub>2</sub> values for units 1, 2, 3, 4, 5 and 6 were calculated per balance, from O<sub>2</sub> values, due to analyser providing unreliable data. Averaged quality assurance level 2 test values for O<sub>2</sub> were used for Unit 1 to 6 due to the analysers being providing unreliable data. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

**Table 6:** Pollutant tonnages for the month of January 2023

| Associated Unit/Stack | PM (tons) | SO <sub>2</sub> (tons) | NO <sub>x</sub> (tons) | CO <sub>2</sub> (tons) |
|-----------------------|-----------|------------------------|------------------------|------------------------|
| Unit 1                | 58,2      | 3 447,4                | 481,3                  | 263 951                |
| Unit 2                | 64,5      | 7 500,5                | 1 096,7                | 730 016                |
| Unit 3                | 45,5      | 5 837,9                | 811,2                  | 413 483                |
| Unit 4                | 60,7      | 5 080,1                | 977,1                  | 388 317                |
| Unit 5                | 87,7      | 3 925,6                | 505,8                  | 448 583                |
| Unit 6                | 75,2      | 5 549,0                | 935,7                  | 552 457                |
| <b>SUM</b>            | 391,8     | 31 340,5               | 4 807,8                | 2 796 808              |

## 2.7 Reference values

**Table 7:** Reference values for data provided, January 2023

| Compound / Parameter | Units of Measure | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|----------------------|------------------|--------|--------|--------|--------|--------|--------|
| Oxygen               | %                | 8,72   | 7,63   | 7,77   | 8,03   | 9,03   | 8,05   |
| Moisture             | %                | 4,83   | 3,97   | 5,83   | 3,30   | 4,35   | 2,75   |
| Velocity             | m/s              | 23,4   | 34,7   | 25,1   | 23,2   | 27,2   | 28,5   |
| Temperature          | °C               | 147,4  | 124,3  | 129,0  | 131,8  | 121,8  | 124,1  |
| Pressure             | mBar             | 933,5  | 935,3  | 914,8  | 914,0  | 933,3  | 912,2  |

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.8 Continuous Emission Monitors

### 2.8.1 Reliability

Continuous emission monitors were available for more than 80% of the reporting period. The emitted pollutant tonnages for January 2023 are provided in table 6. CO<sub>2</sub> values for units 1, 2, 3, 4, 5 and 6 were calculated per balance, from O<sub>2</sub> values, due to analyser providing unreliable data. Averaged quality assurance level 2 test values for O<sub>2</sub> were used for Unit 1 to 6 due to the analysers being providing unreliable data. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

**Table 8:** Average percentage (%) availability of monitors for the month of January 2023.

| Associated Unit/Stack | PM    | SO <sub>2</sub> | NO    |
|-----------------------|-------|-----------------|-------|
| Unit 1                | 99,2  | 100,0           | 99,8  |
| Unit 2                | 100,0 | 99,7            | 97,2  |
| Unit 3                | 100,0 | 100,0           | 100,0 |
| Unit 4                | 100,0 | 99,9            | 99,9  |
| Unit 5                | 100,0 | 99,9            | 93,3  |
| Unit 6                | 100,0 | 78,8            | 78,8  |

### 2.8.2 Changes, downtime, and repairs

#### Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 5

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

#### Unit 6

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

### 2.8.3 Sampling dates and times

**Table 9:** Dates of last conducted CEMS verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub>

|                                     |                  |   |                       |                       |
|-------------------------------------|------------------|---|-----------------------|-----------------------|
| <b>Name of service provider:</b>    |                  | Stacklabs Environmental Services CC                 |                       |                       |
| <b>Address of service provider:</b> |                  | 10 Chisel Street<br>Boltonia<br>Krugersdorp<br>1739 |                       |                       |
| <b>Stack/ Unit</b>                  | <b>PM</b>        | <b>SO<sub>2</sub></b>                               | <b>NO<sub>x</sub></b> | <b>CO<sub>2</sub></b> |
| 1                                   | 2020/09/30 06h04 | 2020/09/09 13h00                                    | 2020/09/09 13h00      | 2020/09/09 13h00      |
| 2                                   | 2021/01/26 04h52 | 2021/01/27 13h00                                    | 2021/01/27 13h00      | 2021/01/27 13h00      |
| 3                                   | 2021/08/10 12h05 | 2020/09/24 07h00                                    | 2020/09/24 07h00      | 2020/09/24 07h00      |
| 4                                   | 2021/07/13 14h31 | 2020/09/16 02h00                                    | 2020/09/16 02h00      | 2020/09/16 02h00      |
| 5                                   | 2020/10/06 05h39 | 2020/10/08 02h30                                    | 2020/10/08 02h30      | 2020/10/08 02h30      |
| 6                                   | 2020/09/09 06h41 | 2020/09/09 13h00                                    | 2020/09/09 13h00      | 2020/09/09 13h00      |

## 2.9 Units Start-up information

**Table 10:** Start-up information

|   |            |       |
|---|------------|-------|
| <b>Unit</b>                                   | 1          |       |
| <b>Fires in</b>                               | 2023/01/09 | 17h19 |
| <b>Synchronization with Grid</b>              | 2023/01/10 | 04h08 |
| <b>Emissions below limit</b>                  | 2023/01/11 | 11h00 |
| <b>Fires in to synchronization</b>            | 10,41      | HOURS |
| <b>Synchronization to &lt; Emission limit</b> | 31         | HOURS |

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

|   |            |       |
|---|------------|-------|
| <b>Unit</b>                                   | 1          |       |
| <b>Fires in</b>                               | 2023/01/20 | 12h01 |
| <b>Synchronization with Grid</b>              | 2023/01/20 | 14h35 |
| <b>Emissions below limit</b>                  | 2023/01/20 | 17h10 |
| <b>Fires in to synchronization</b>            | 2,27       | HOURS |
| <b>Synchronization to &lt; Emission limit</b> | 2,35       | HOURS |

|   |            |       |
|---|------------|-------|
| <b>Unit</b>                                   | 3          |       |
| <b>Fires in</b>                               | 2023/01/08 | 14h10 |
| <b>Synchronization with Grid</b>              | 2023/01/08 | 16h10 |
| <b>Emissions below limit</b>                  | 2023/01/08 | 17h11 |
| <b>Fires in to synchronization</b>            | 2          | HOURS |
| <b>Synchronization to &lt; Emission limit</b> | 1,1        | HOURS |

|   |            |       |
|---|------------|-------|
| <b>Unit</b>                                   | 3          |       |
| <b>Fires in</b>                               | 2023/01/15 | 09h20 |
| <b>Synchronization with Grid</b>              | 2023/01/15 | 13h03 |
| <b>Emissions below limit</b>                  | 2023/01/15 | 14h00 |
| <b>Fires in to synchronization</b>            | 3          | HOURS |
| <b>Synchronization to &lt; Emission limit</b> | 0,57       | HOURS |

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.10 Emergency generation

**Table 11:** Emergency generation

|  | Unit 1 | Unit 2 | Unit 3 | Unit 4 | Unit 5 | Unit 6 |
|--|--------|--------|--------|--------|--------|--------|
| <b>Emergency Generation hours declared by national Control</b>   |        |        |        |        |        |        |
| <b>Emergency Hours declared including hours after stand down</b> |        |        |        |        |        |        |
| <b>Days over the Limit during Emergency Generation</b>           |        |        |        |        |        |        |

During the period under review all Units were on emergency generation in force from 01 January 2023 until 31 January 2023.

## 2.11 Complaints register

**Table 12:** Complaints

| Source Code/<br>Name | Root Cause<br>Analysis | Calculation of<br>Impacts/<br>emissions<br>associated<br>with the<br>incident | Dispersion<br>modelling of<br>pollutants<br>where<br>applicable | Measures<br>implemented<br>to prevent<br>reoccurrence | Date by which<br>measure will<br>be<br>implemented |
|----------------------|------------------------|---|---|---|--|
| N/A                  |                        |   |   |   |  |

## 2.12 Air quality improvements and social responsibility conducted

### 2.12.1 Air quality improvements

None

### 2.12.2 Social responsibility conducted

None

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.13 Ambient air quality monitoring

Ambient air quality monitoring report was not available at the time of publishing this report.

## 2.14 Electrostatic precipitator and Sulphur plant status

### Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 2

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 3

- All precipitator fields in service. Unit shut down for outage
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 4

- 3 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 5

- 4 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

### Unit 6

- 2 fields out of service, will be inspected next opportunity.
- Hole in burner casing and sulphur leak causing low availability. Preventative maintenance done during the month.

### SO3 common plant

- No abnormalities on the sulphur storage plant.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.15 General

### Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

### Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

None

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely

*Wikus van Rensburg*

pp

GENERAL MANAGER: MATIMBA POWER STATION

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.