

	Matimba Power Station Emissions report	Matimba Power Station
---	---	------------------------------

Title: **Matimba Power Station October
2022 emissions report**

Document Identifier: **RP/247/027**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area
Applicability: **Environment**

Revision: **1**

Total Pages: **36**

Report Date: **October 2022**

Disclosure
Classification: **Controlled**

Compiled by

Functional Responsibility

Authorized by





**KH Ramahlare
Environmental Officer**

**MC Mamabolo
Environmental Manager**

**Obakeng Mabotja
General Manager**

Date: 2022-12-05

Date: 5/12/2022

Date: 2022/12/07

Content

	Page
1. Report Summary	4
2. Emission information	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions	6
2.4.2 Gaseous Emissions	11
2.4.3 Total Volatile Organic Compounds	21
2.4.4 Greenhouse gas (CO ₂) emissions	22
2.5 Daily power generated	22
2.6 Pollutant Tonnages	28
2.7 Reference values	28
2.8 Continuous Emission Monitors.....	29
2.8.1 Reliability.....	29
2.8.2 Changes, downtime, and repairs	29
2.8.3 Sampling dates and times.....	29
2.9 Units Start-up information	30
2.10 Emergency generation	31
2.11 Complaints register	32
2.12 Air quality improvements and social responsibility conducted	32
2.12.1 Air quality improvements.....	32
2.12.2 Social responsibility conducted.....	32
2.13 Ambient air quality monitoring.....	32
2.14 Electrostatic precipitator and Sulphur plant status.....	32
2.15 General.....	33
3. Attachments.....	33
4. Report Conclusion	33
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics.	6
Table 4: Total volatile compound estimates	21
Table 5: Daily power generated per unit in MWh for the month of October 2022	22
Table 6: Pollutant tonnages for the month of October 2022.....	28
Table 7: Reference values for data provided, October 2022.....	28
Table 8: Average percentage (%) availability of monitors for the month of October 2022.....	29
Table 9: Dates of last conducted CEMS verification tests for PM, SO ₂ and NO _x	30

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Start-up information	30
Table 11: Emergency generation	31
Table 12: Complaints.....	32

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of October 2022.....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of October 2022.....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of October 2022.....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of October 2022.....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of October 2022.....	10
Figure 6: SO ₂ daily average emissions against emission limit for unit 1 for the month of October 2022.....	11
Figure 7: SO ₂ daily average emissions against emission limit for unit 2 for the month of October 2022.....	12
Figure 9: SO ₂ daily average emissions against emission limit for unit 4 for the month of October 2022.....	13
Figure 10: SO ₂ daily average emissions against emission limit for unit 5 for the month of October 2022.....	14
Figure 11: SO ₂ daily average emissions against emission limit for unit 6 for the month of October 2022.....	15
Figure 12: Figure 13: NO _x daily average emissions against emission limit for unit 1 for the month of October 2022.....	16
Figure 14: NO _x daily average emissions against emission limit for unit 2 for the month of October 2022.....	17
Figure 16: NO _x daily average emissions against emission limit for unit 4 for the month of October 2022.....	18
Figure 17: NO _x daily average emissions against emission limit for unit 5 for the month of October 2022.....	19
Figure 18: NO _x daily average emissions against emission limit for unit 6 for the month of October 2022.....	20
Figure 19: Unit 1 daily generated power in MWh for the month of October 2022.....	23
Figure 20: Unit 2 daily generated power in MWh for the month of October 2022.....	24
Figure 22: Unit 4 daily generated power in MWh for the month of October 2022.....	25
Figure 23: Unit 5 daily generated power in MWh for the month of October 2022.....	26
Figure 24: Unit 6 daily generated power in MWh for the month of October 2022.....	27

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for October 2022.



During the period under review, twelve exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$) occurred. One exceedance resulted in a Section 30 incident that was reported to your office on 17 October 2022. All other exceedances remained within the 48-hour grace period. No exceedances of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$) or the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$) occurred.

Emission trends and tonnages reported in this report were calculated based on correlation curves of October 2020. As per the letters sent to your office on 09 October 2022 and 28 October 2022, the new curves are in the process of being reviewed and implemented.

The sulphur dioxide analyser for unit 2 is defective and averaged daily emissions from the Quality Assurance Level 2 report was used for reporting purposes. Mitigation measure to repair the defective analyser are in progress.

For the month of October Matimba Power Station used a total of 1425,838 tons of fuel oil, exceeding the monthly limit of 1200 tons. The increased usage was due to multiple light-ups of unit 3 after an outage.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	982 544
	Fuel Oil	Tons/month	1 200	1425,838
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	2289,417

Matimba Power Station exceeded the monthly fuel oil usage limit of 1200 Tons per month. The exceedance was due to multiple light-ups for unit 3 after a general overall outage. Total fuel oil usage for October 2022 was 1425.838 Tons.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,91%
Unit 2	Electrostatic Precipitator	100%	99,88%
Unit 3	Electrostatic Precipitator	100%	Unit Off-line
Unit 4	Electrostatic Precipitator	100%	99,89%
Unit 5	Electrostatic Precipitator	100%	99,88%
Unit 6	Electrostatic Precipitator	100%	99,90%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	98
Unit 2	SO ₃ Plant	100%	99
Unit 3	SO ₃ Plant	100%	Unit Off-line
Unit 4	SO ₃ Plant	100%	94
Unit 5	SO ₃ Plant	100%	98
Unit 6	SO ₃ Plant	100%	99

Flue gas conditioning plant availability was below the required 100% for units 1, 2, 4, 5 and 6 due to maintenance activities and unplanned breakdowns. Defects were addressed and plants returned to services.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.31%
	Ash Content	40%	34,98%

Energy source characteristics remained within the ranges stipulated in the license.

2.4 Emissions reporting

2.4.1 Particulate Matter Emissions

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of October 2022

Interpretation:

All daily averages below Particulate matter emission daily limit of 50 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of October 2022

Interpretation:

Unit 2 exceeded the particulate matter emission daily limit of 50 mg/Nm³ on 23 October 2022. The exceedance was due to defects on the ash handling plant leading to ash build-up within the flue gas stream reducing the efficiency of the electrostatic precipitator fields. Exceedance remain within the 48 hours grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 Particulate Emissions**Interpretation:**

Unit 3 has been off load on outage from 13 August 2022.


Unit 4 Particulate Emissions

Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of October 2022

Interpretation:

Unit 4 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 07, 17, 19, 20, 26 and 29 October 2022. The exceedances on 07, 17, and 29 October were due to defects on the ash handling plant leading to ash build-up within the flue gas stream reducing the efficiency of the electrostatic precipitator fields. The exceedance on 19, 20, and 26 were due to unavailability of the flue gas conditioning plant. Respective plants defects were repaired, and emissions returned to normal. The exceedances remained within the 48-hour grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of October 2022

Interpretation:

Unit 5 exceeded the daily particulate matter limit of 50mg/Nm^3 on 6 and 7 October 2022. The exceedance was due to defects on the ash handling plant leading to ash build-up within the flue gas stream reducing the efficiency of the electrostatic precipitator fields. Exceedance remain within the 48 hours grace period.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of October 2022

Interpretation:

Unit 6 exceeded the daily particulate matter emission limit of 50mg/Nm³ from 13 to 15 October 2022. The exceedances were due to an equipment failure of the ash conveyancing plant creating an ash backlog within the flue gas cleaning system reducing the efficiency of the electrostatic precipitator plant. The defects on the ash conveyancing plant are primarily due to the lack of space available for ashing at the ash dumping facility. The 48 hours grace period was exceeded, and the Section 30 incident was reported to your office on 17 October 2022. Production loss was incurred, the ash conveyance system was repaired, and the emission returned to below the limit on the 16 October 2022.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.2 Gaseous Emissions

Unit 1 SO₂ Emissions




Figure 6: SO₂ daily average emissions against emission limit for unit 1 for the month of October 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 SO₂ Emissions

Figure 7: SO₂ daily average emissions against emission limit for unit 2 for the month of October 2022

Interpretation:

Averaged AMS values from the 2020 QAL 2 report was used to report unit 2 SO_x and Oxygen emissions due to unreliable readings received from the analyser since 1 October 2022. Investigation findings concluded that the analyser is experiencing significant drift. Corrective actions were put in place to repair the analyser including the movement of the Oxygen ports to make readings more reliable.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 SO₂ Emissions**Interpretation:**

Unit 3 has been off load on outage from 13 August 2022.


Unit 4 SO₂ Emissions

Figure 8: SO₂ daily average emissions against emission limit for unit 4 for the month of October 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 SO₂ Emissions

Figure 9: SO₂ daily average emissions against emission limit for unit 5 for the month of October 2022

Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 SO₂ Emissions

Figure 10: SO₂ daily average emissions against emission limit for unit 6 for the month of October 2022

Interpretation:

All daily averages remained below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 1 NO_x Emissions

Figure 11: NO_x daily average emissions against emission limit for unit 1 for the month of October 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO_x Emissions

Figure 12: NO_x daily average emissions against emission limit for unit 2 for the month of October 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO_x Emissions**Interpretation:**

Unit 3 has been off load on outage from 13 August 2022.


Unit 4 NO_x Emissions

Figure 13: NO_x daily average emissions against emission limit for unit 4 for the month of October 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 NO_x Emissions

Figure 14: NO_x daily average emissions against emission limit for unit 5 for the month of October 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 NO_x Emissions

Figure 15: NO_x daily average emissions against emission limit for unit 6 for the month of October 2022

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Tuesday, 15 November 2022	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the blue cells below</p> <p align="center">Choose from a dropdown menu in the green cells</p> <p align="center">The total VOC emissions for the month are in the red cells</p> <p align="center">IMPORTANT: Do not change any other cells without consulting the AQ CoE</p>		
MONTH:	October	
GENERAL INFORMATION:		Data Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	1432,899	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH		Data Unit
Daily average ambient temperature	26,19	°C
Daily maximum ambient temperature	33,65	°C
Daily minimum ambient temperature	19,11	°C
Daily ambient temperature range	14,54	°C
Daily total insolation factor	5,81	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
FINAL OUTPUT:		Result Unit
Breathing losses:	0,60 kg/month	
Working losses:	0,04 kg/month	
TOTAL LOSSES (Total TVOC Emissions for the month):	0,64 kg/month	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

The total fuel oil throughput for October 2022 was 1432,899 Tons, however, only 1425,838 tons of the total throughput was used during the combustion process. The remaining 7,061 Tons of fuel oil was lost due to a spillage that occurred during the unit 3 start-up within the fuel oil storage containment area. The spillage was contained within the pollution control infrastructure and cleaned immediately. Spilled oil was disposed of as hazardous waste.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.5 Daily power generated

Table 5: Daily power generated per unit in MWh for the month of October 2022

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2022/10/01	13122	12354	0	13255	0	13390
2022/10/02	13180	12168	0	13432	0	13661
2022/10/03	12663	11989	0	13468	0	13195
2022/10/04	12274	11580	0	12437	0	12781
2022/10/05	13373	14031	0	14331	3565	13791
2022/10/06	12647	13060	0	12788	11906	13458
2022/10/07	12513	12712	0	12647	12086	13245
2022/10/08	13255	13247	0	12442	12218	13883
2022/10/09	12823	12118	0	12835	13192	13540
2022/10/10	12606	11530	0	13186	13461	13106
2022/10/11	12562	11896	0	13288	13012	13534
2022/10/12	13313	11596	0	13224	11083	12119
2022/10/13	13963	11287	0	12463	11633	11047
2022/10/14	13742	11388	0	13136	11808	10339
2022/10/15	13564	11734	0	12816	12176	8976
2022/10/16	13363	12910	0	12357	13164	8814
2022/10/17	13204	12631	0	11460	15268	11931
2022/10/18	13410	11962	0	12167	15594	14229
2022/10/19	14232	12584	0	13867	12884	14364
2022/10/20	13991	12628	0	10903	11820	14071
2022/10/21	13888	11906	0	10745	11581	14129
2022/10/22	13983	11987	0	11108	10963	13608
2022/10/23	13253	12234	0	13090	12696	13335
2022/10/24	13579	12026	0	11529	12916	13882
2022/10/25	8248	11300	0	11385	11496	12334
2022/10/26	10491	11461	0	11438	11759	13589
2022/10/27	11316	12423	0	12186	13787	14290
2022/10/28	11626	11646	0	11894	12328	12155
2022/10/29	12499	11251	0	12889	11398	13722
2022/10/30	11663	11462	0	12143	0	13252
2022/10/31	12101	11130	0	12215	12372	13151

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 16: Unit 1 daily generated power in MWh for the month of October 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 17: Unit 2 daily generated power in MWh for the month of October 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 18: Unit 4 daily generated power in MWh for the month of October 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 19: Unit 5 daily generated power in MWh for the month of October 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 6 daily generated power in MWh for the month of October 2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Pollutant Tonnages

The emitted pollutant tonnages for October 2022 are provided in table 6. CO₂ values for units 2, 4 and 5 were calculated per balance, from O₂ values, due to analyser providing unreliable data. Averaged values for CO₂ were used for Unit 1 on 25-26 October 2022 due to unreliable data from analysers. Averaged quality assurance level 2 test values for O₂ were used for Unit 1 and 6 due to the analysers being providing unreliable data. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data. Unit 3 has been on Outage since August 2022.

Table 6: Pollutant tonnages for the month of October 2022

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	60,0	4 659,3	654,4
Unit 2	74,9	9 134,7	994,0
Unit 3	0,0	0,0	0,0
Unit 4	69,4	5 040,2	933,6
Unit 5	62,9	3 097,0	403,6
Unit 6	71,2	5 870,1	802,9
SUM	338,4	27 801,3	3 788,6

2.7 Reference values

Table 7: Reference values for data provided, October 2022

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	8,69	7,64		7,30	6,59	8,06
Moisture	%	4,55	4,09		3,16	4,32	2,85
Velocity	m/s	22,7	34,6		22,9	26,5	27,4
Temperature	°C	149,0	126,5		134,6	123,4	124,9
Pressure	mBar	933,8	935,6		916,3	929,6	914,2

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Continuous Emission Monitors

2.8.1 Reliability

The emitted pollutant tonnages for October 2022 are provided in table 6. CO₂ values for units 2, 4 and 5 were calculated per balance, from O₂ values, due to analyser providing unreliable data. Averaged values for CO₂ were used for Unit 1 on 25-26 October 2022 due to unreliable data from analysers. Averaged quality assurance level 2 test values for O₂ were used for Unit 1 and 6 due to the analysers being providing unreliable data. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data. Unit 3 has been on Outage since August 2022.

Table 8: Average percentage (%) availability of monitors for the month of October 2022.

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	100,0	100,0	98,7
Unit 2	100,0	0,0	89,8
Unit 3	Unit Off	Unit Off	Unit Off
Unit 4	100,0	100,0	100,0
Unit 5	100,0	100,0	96,9
Unit 6	100,0	99,6	99,6

2.8.2 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 3

- Unit on outage

Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 5

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 6

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- No downtime or repairs done on the particulate monitors

2.8.3 Sampling dates and times

Table 9: Dates of last conducted CEMS verification tests for PM, SO₂ and NO_x

Name of service provider:		Stacklabs Environmental Services CC		
Address of service provider:		10 Chisel Street Boltonia Krugersdorp 1739		
Stack/ Unit	PM	SO₂	NO_x	CO₂
1	2020/09/30 06h04	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00
2	2021/01/26 04h52	2021/01/27 13h00	2021/01/27 13h00	2021/01/27 13h00
3	2021/08/10 12h05	2020/09/24 07h00	2020/09/24 07h00	2020/09/24 07h00
4	2021/07/13 14h31	2020/09/16 02h00	2020/09/16 02h00	2020/09/16 02h00
5	2020/10/06 05h39	2020/10/08 02h30	2020/10/08 02h30	2020/10/08 02h30
6	2020/09/09 06h41	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00

Correlation curves for Unit 1, Unit 5, and Unit 6 are currently outstanding. Quality assurance level 2 curves are outstanding for unit 1, unit 3, unit 4, unit 5 and unit 6. The new tests have been completed however, due to errors and disputes identified in the test reports during the review process updated curves have not yet been implemented. The disputes and corrections are being addressed by Matimba and the service provider and new curves will be implemented as soon as they are confirmed to be correct.

2.9 Units Start-up information

Table 10: Start-up information

Unit	1	
Fires in	2022/10/25	04h46
Synchronization with Grid	2022/10/25	06h24
Emissions below limit	2022/10/25	06h24
Fires in to synchronization	1,63	HOURS
Synchronization to < Emission limit	0	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	5	
Fires in	2022/10/05	10h49
Synchronization with Grid	2022/10/05	15h51
Emissions below limit	2022/10/06	04h10
Fires in to synchronization	5.03	HOURS
Synchronization to < Emission limit	12.32	HOURS

Unit	5	
Fires in	2022/10/30	19h52
Synchronization with Grid	2022/10/31	01h34
Emissions below limit	2022/10/31	03h35
Fires in to synchronization	5.7	HOURS
Synchronization to < Emission limit	2,02	HOURS

2.10 Emergency generation

Table 11: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	420,4	422,0167	0	422,0167	422,0167	422,0167
Emergency Hours declared including hours after stand down	422,4	424,0167	0	424,0167	424,0167	424,0167
Days over the Limit during Emergency Generation	0	1	0	5	0	3

Unit 2 exceeded the 50mg/Nm³ limit for one day during emergency generation, on 23 October 2022. Unit 4 exceeded the 50mg/Nm³ limit for five days during emergency generation, on 17, 19, 20, 26 and 29 October 2022. Unit 6 exceeded the 50mg/Nm³ limit for three days during emergency generation, on 13, 14 and 15 October 2022.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.11 Complaints register

Table 12: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
N/A					

2.12 Air quality improvements and social responsibility conducted

2.12.1 Air quality improvements

None

2.12.2 Social responsibility conducted

None

2.13 Ambient air quality monitoring

Ambient air quality monitoring report was not available at the time of publishing this report. The report will be send through as soon as it is available.

2.14 Electrostatic precipitator and Sulphur plant status

Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 2

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 3

- Unit on outage

Unit 4

- 3 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 5

- 4 field out of service, will be inspected next opportunity.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 6

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

SO3 common plant

- No abnormalities on the sulphur storage plant.

2.15 General**Name and reference number of the monitoring methods used:**

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meters consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meters consist of 3 flues

3. Attachments

Marapong Monthly Report_October 2022

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.