

Ms. Nompumelelo Simelane Nkangala District Municipality PO Box 437 Middleburg 1050 Date

April 2023

Enquiries Lesiba Kgobe Tel +27 13 699 7817

Ref Kusile Power Station AEL (17/4/AEL/MP311/12/01)

Dear Ms Simelane

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR MARCH 2023

This serves as the monthly report required in terms of Section 7.6 in Kusile Power Station's Atmospheric Emission License 17/4/AEL/MP311/12/01. The emissions are for the month of March 2023. Please take note that Unit 1, 2 and 3 are off due to the flue gas duct collapse incident that occurred in Oct 2022.


Hoping the above will meet your satisfaction

Yours sincerely

Bongumusa A Mashazı GENERAL MANAGER DATE: OLI MAN

> Generation Division – Coal New Build Unit Management Department (Kusile Power Station) R545 Kendal/Balmoral Road, Haartebeesfontein Farm, Witbank Postnet Suite 283 Private Bag X 7297 Witbank 1035 SA Tel+27 13 693 4320 Fax +27 86 768 3030 www eskom co za

1. KUSILE POWER STATION MONTHLY EMISSIONS REPORT: Atmospheric Emission License 17/4/AEL/MP311/12/01



2 Raw Materials and Products

Raw	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rat Mar-2023	
Materials and Products	Coal	Tons	1 818 083	190 355	
	Fuel Oil	Tons	5 533	48.902	
	Limestone	Tons	72 917	7012	
	Product Name	Units	Capacity Permitted	Mar-2023	
	Product / By-	Units	Max. Production	Production Rate	
	Energy	GWh	3321.216	299.18	
Production Rates	Ash	Tons	663 583	51 205.4	
Rates	Gypsum	Tons	129 250	3 926.7	
	RE PM	kg/MWh	not specified	0.032	
	RE SOx	kg/MWh	not specified	0.424	

3 Energy source characteristics

Fuel Characteristic	Units	Stipulated Range	Monthly Average Content
Coal CV	MJ/kg	not specified	21.750
Coal Sulphur	%	1.3	0.680
Ash in Coal	%	38	26.900
Fuel Oil (FO) CV	MJ/kg	not specified	42.300
Fuel Oil Sulphur	%	3	2.740

4 Emissions Limits (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NOx
North	50	500	750
South	50	500	750

5 Abatement Technology (%)

Associated Unit/Stack	Technology Type	Efficiency Mar-2023	Technology Type	Efficiency Mar- 2023		
Unit 1	FFP			<u> </u>		
Unit 2	FFP	Units on outage				
Unit 3	FFP					
Unit 4	FFP	99 979%	FGD	99 946%		

Note Both the FFP and FGD does not have bypass mode operation, hence plant 100% Utilised

6. Monitoring reliability (%)

Associated Unit/Stack	РМ	SO₂	NO	O ₂
Unit 1				
Unit 2		Units	s on outage	
Unit 3				•
Unit 4	32 0	97 2	97 0	97 O

Note The dust monitor failed and needed to change the probe, hence the monitor was not working for some part of the month and the issue has been resolve

7. Emissions Performance

Table 7 1 Monthly tonnages for the month of Mar - 2023

Associated Unit/Stack	PM	SO ₂	NO _x			
Unit 1						
Unit 2	Units on outage					
Unit 3	1					
Unit 4	96	127	400			
SUM	96	127	400			

Table 7.2: Operating days in compliance to PM AEL Limit - March 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)	
Unit 1							
Unit 2	Units on outage						
Unit 3							
Unit 4	25	0	0	0	0	8.8	
SUM	25	0	0	0	0		

Table 7.3: Operating days in compliance to SO₂ AEL Limit - March 2023


Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm³)
Unit 1						
Unit 2	Units on outage					
Unit 3						
Unit 4	25	0	0	0	0	114.8
SUM	25	0	0	0	0	


Table 7.4: Operating days in compliance to NOx AEL Limit - March 2023


Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)	
Unit 1							
Unit 2	Units on outage						
Unit 3							
Unit 4	25	0	0	0	0	366,6	
	25	0	0	0	0		

Table 7.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions







8. Shut down and Light up information

Unit No. 4		Event 1
Breaker Open (BO)	1:25 am	2023/03/25
Draught Group (DG) Shut Down (SD)	3:00 am	2023/03/26
BO to DG SD (duration)	01:01:35	DD:HH:MM
Fires in time		
Synch. to Grid (or BC)		
Fires in to BC (duration)		DD;HH:MM
Emissions below limit from BC (end date)		
Emissions below limit from BC (duration)		DD:HH:MM

9. Complaints

No complaints reported for the month of March 2023

Date and time complaint was received	Complaint received	Source code name	Root cause analysis	Calculation of impact/emissions associated with incidents and dispersion modelling of pollutants where applicable.	Measures implemented or to be implemented to prevent recurrence	Date by which measures will be implemented
N/A						