


Empowering  
the future together

1923-2023



## 1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted Consumption Rate	Consumption Rate May-2023
	Coal	Tons	820 000	112 470.0
	Fuel Oil	Tons	3 200	1162.418

Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Production Rate May-2023
	Energy	GWh	1488	175.51
	Ash	Tons	290 000	28 534
	RE PM	kg/MWh	not specified	0.199

## 2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 to < 1	0.60
Ash Content	%	31 to < 35	25.37

3 EMISSION LIMITS (mg/Nm<sup>3</sup>)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>x</sub>
North	75	3500	1200
South	75	3500	1200

## 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency May-2023
Unit 1	Fabric Filter Plant (FFP)	Unit Off-line
Unit 2	Fabric Filter Plant (FFP)	Unit Off-line
Unit 3	Fabric Filter Plant (FFP)	Unit Off-line
Unit 4	Fabric Filter Plant (FFP)	Unit Off-line
Unit 5	Fabric Filter Plant (FFP)	Unit Off-line
Unit 6	Fabric Filter Plant (FFP)	100.000%
Unit 7	Fabric Filter Plant (FFP)	100.000%
Unit 8	Fabric Filter Plant (FFP)	Unit Off-line
Unit 9	Fabric Filter Plant (FFP)	Unit Off-line
Unit 10	Fabric Filter Plant (FFP)	100.000%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

## 5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>	CO <sub>2</sub>
North					
South	100.0	0.0	0.0	0.0	0

Note: NO<sub>x</sub> emissions is measured as NO in PPM. Final NO<sub>x</sub> value is expressed as total NO<sub>2</sub>

There is no emissions tons because boilers for the North Stack were all offline

## 6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of May-2023

Associated Unit/Stack	PM (tons)	SO <sub>x</sub> (tons)	NO <sub>x</sub> (tons)
North			
South	34.9	0.0	0.0
SUM	34.9	0.0	0.0

The number of number of days under normal operation for North Stack PM is zero because boilers for North Stack were all offline

The number of number of days under normal operation for North Stack and South Gaseous Emissions is zero because because Gaseous monitors faulty

Table 6.2: Operating days in compliance to PM AEL Limit - May 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
North						
South	30	0	0	0	0	37.3
SUM	30	0	0	0	0	

Table 6.3: Operating days in compliance to SO<sub>2</sub> AEL Limit - May 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO <sub>2</sub> (mg/Nm <sup>3</sup> )
North	0	0	0	0	0	
South	0	0	0	0	0	
SUM	0	0	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - May 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm <sup>3</sup> )
North						
South	0	0	0	0	0	
SUM	0	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Grey	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Green	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions




Figure 1: PM Emissions trends for North Stack- May 2023




Figure 2: PM Emissions trends for South Stack- May 2023




Figure 3: Sulphur dioxide Emissions trends for North Stack- May 2023




Figure 3: Sulphur dioxide Emissions trends for South Stack- May 2023




Figure 5: Nitrogen dioxide Emissions trends for North Stack- May 2023




Figure 6: Nitrogen dioxide Emissions trends for South Stack- May 2023

## 7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7 1 PM Start-up information for the month of May-2023

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No	Unit 6		Unit 7		Unit 7		Unit 10	
Breaker Open (BO)	8 25 am	2023/05/04	BO previously	BO previously	1 45 am	2023/05/31		
Draught Group (DG) Shut Down (SD)	8 25 am	2023/05/04	n/a	n/a	5 35 pm	2023/05/31		
BO to DG SD (duration)		DD HH MM	n/a	DD HH MM	00 15 50	DD HH MM		DD HH MM
Fires in time	6 50 pm	2023/05/04	2023/05/25	2023/05/25			2023/05/15	2023/05/15
Synch to Grid (or BC)	6 50 am	2023/05/05	9 00 pm	2023/05/25			5 50 am	2023/05/15
Fires in to BC (duration)	00 12 00	DD HH MM	00 12 00	DD HH MM		DD HH MM	00 05 00	DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit			not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD HH MM	n/a	DD HH MM		DD HH MM	n/a	DD HH MM


South Stack Continued	Event 1	
Unit No	Unit 10	
Breaker Open (BO)	12 00 am	2023/06/01
Draught Group (DG) Shut Down (SD)	12 00 am	2023/06/01
BO to DG SD (duration)		DD HH MM
Fires in time		
Synch to Grid (or BC)		
Fires in to BC (duration)		DD HH MM
Emissions below limit from BC (end date)		
Emissions below limit from BC (duration)		DD HH MM


## 8 Complaints register

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Date measure will be implemented	Measures implemented to prevent reoccurrence
There were no complaints related to air quality received during the month of May 2023					


11 General


North Stack units were offline for entire month of May 2023

 \_\_\_\_\_ 26/06/2023 \_\_\_\_\_  
 Compiled Environmental Officer Date

B Madiope  
 \_\_\_\_\_ 2023/06/30 \_\_\_\_\_  
 Authorised by GM Date  
 T Lekalakala

Compiled by Boiler Engineering Department  
 For Nkangala District Municipality  
 Copies Eskom Environmental Management  
  
 Group Technology Engineering  
  
 Hendrina Power Station

 \_\_\_\_\_ 27/06/2023 \_\_\_\_\_  
 Boiler/ FFP Date  
 Marco Cossa

 \_\_\_\_\_ 27/06/2023 \_\_\_\_\_  
 Validated by Manager Environmental Date  
 L Ntla

FFP SE/ Environmental Officer  
 Air Quality Officer  
 D Herbst  
 B Mccourt  
  
 R Rampiar  
 E Patel  
  
 Engineering Manager  
 Operating Manager  
 Maintenance Manager  
 Unit Production Manager  
 Boiler Engineering Manager  
 System Engineer Boiler Engineering  
 Environmental Officer  
 C & I Engineering Manager  
 Production Manager  
 Environmental Manager  
 PSM