

lan Gildenhuys Air Quality Management 246 Voortrekker Road Vasco 7460 Date: 3 *July 2023*

Enquiries: Hilton Westman (021) 9415856

Ref: ACP/2023/06

Dear Mr Gildenhuys

ACACIA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF JUNE 2023

This serves as the monthly report required in terms of Section 5.4.1 and Sections 8.1.1 of Acacia Power Station's Atmospheric Emission License **WCCT023**. The information is applicable for the month of June 2023.

1. Raw Materials and Products (Licence 5.4.1)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type : Kerosene		
Total Fuel Consumption	177.826	Tons
Electricity Produced	583	MWh
Average Fuel Consumption	0.305	Tons / MWh
Maximum fuel consumption rate	43 799	Kg per hour

2. Operating times of units (Licence 5.4.1)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production	
	Hours and minutes	Litres	MWh	
Unit One	3hrs 49min		194	
Unit Two	3hrs 42min	207 426	184	
Unit Three	4hrs 06 min		205	

b. Detailed operating times

See Annexure1.

3. Complaints Register (Licence reference 8.1.1)

No complaints were registered for the month of June 2023.

4. General

Acacia was not requested to generate for the grid to supplement power availability.

4 Monthly Routine C service performed and Grid Code Compliance Tests. Test Run was also performed on Koeberg's request.

The monthly Ambient Air Quality Report compiled by Argos Scientific for air quality monitoring at the Acacia AQM station, will be sent to your office as soon as it is received.

We trust that the above information complies with your requirements.

Yours sincerely

pp Pamela Mrubata
Plant Manager

ACACIA POWER STATION

Annexure 1. Acacia Hours of operation

	Unit One			Unit two			Unit 3		
Date	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18 19									
20									
21									
22	09:29:00	09:44:00	00:15:00						
23	03.23.00	03.44.00	00.13.00	15:10:00	18:52:00	03:42:00	10:50:00	11:22:00	00:32:00
24									
25									
26									
27									
28	15:21:00	18:55:00	03:34:00				15:21:00	18:55:00	03:34:00
29									
30									

Load Factor 0.57 %