

Air Quality Officer **DEDET** Private bag X11215 **NELSPRUIT** 1200

Date: 2023.09.20

Inquiries: Mariam Joseph Tel +27 13 297 9828 Fax + 27 86 661 7663

Dear Mr. Mahlangu

ARNOT POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF AUGUST 2023

This serves as the monthly report required in terms of Section 6 in Arnot Power Station's Atmospheric Emission License. The emissions are for August 2023, verified emissions of particulates; SO₂ and NO_x (as NO₂) are also included.

Raw Materials and Products

Table1: Quantity of Raw Materials and Products used/produced for the Month of August 2023

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of August 2023
	Coal	Tons/month	1 050 330	463 851.2
	Fuel Oil	Tons/month	10 000	2977.71
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of August 2023
	Energy	GWh	1 785 600	877 190
	Ash	Tons/month	421 000	105 341

Abatement Technology

Table 2.1 (a) Abatement Equipment Control Technology for month of August 2023

Associated Unit/Stack	Technology Type	Actual Efficiency (%) for the month of August 2023
North Stack	Fabric Filter Bags	99.7%
South Stack	Fabric Filter Bags	99.9%

Table 2.1 (b) Abatement Equipment Utilisation (%) for the month of August 2023

Associated Unit/Stack	Technology Type	Utilisation August 2023
North	Fabric Filter Plant (FFP)	100 %
South	Fabric Filter Plant (FFP)	100 %

Table 2.1 (c) Monitor Reliability (%)

Associated Unit/Stack	РМ	SO ₂	NO
Stack 1	98.1	64.0	63.0
Stack 2	100	96.1	96.4

Note: SO_2 and NO below 80% due to power failure from the monitor system, an averaging was used during the period

Energy Source Characteristics

Table 3: Energy Source Material Characteristics for the month of May 2023

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.5 to < 1 (%)	0.607
Ash Content	17 to < 40 (%)	22.71

Table 4 Operating days in compliance to PM AEL Limit –August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
North	31	0	0	3	0	63.5
South	31	0	0	0	0	39.4
SUM	62	0	0	0	0	

Table 5: Operating days in compliance to NOx AEL Limit – August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
North	31	0	0	0	0	785.4
South	31	0	0	0	0	771.3
SUM	62	0	0	0	0	

Table 6: Operating days in compliance to Sox AEL Limit –August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm³)
North	31	0	0	0	0	1262.5
South	31	0	0	0	0	1105.5
SUM	62	0	0	0	0	

Emissions Reporting




Figure 1: PM emissions (daily averages) for the month of August 2023 against the emission limit for the North Stack




Figure 2: PM emissions (daily averages) for the month of August 2023 against emission limit for the South Stack




Figure 3: SO₂ emissions (daily averages) for the month of August 2023 against emission limit for the North Stack




Figure 4: SO₂ emissions (daily averages) for the month of August 2023 against emission limit for the South Stack




Figure 5: NO₂ emissions (daily averages) for the month of August 2023 against emission limit for the North Stack




Figure 6: NO₂ emissions (daily averages) for the month of August 2023 against emission limit for the South Stack

Table 4: Monthly tonnages for the month of August 2023

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)
Total Tons			
(North &	221.8	5133	3309
South	221.0	3133	3309
Stack)			

Table 5: Each unit and respective days operating under normal operation, days in grace period, and section 30 days respectively

Unit	Days operating under normal operation	Days operating in grace period	Days operating under S 30
1	31	0	0
2	31	0	0
3	31	0	0
4	31	0	0
5	31	0	0
6	31	0	0

Light up information

Continuous reporting is being done even during start-ups emissions were not affected.

Complaints Register

Table 6. Complaints for the month of August 2023

No Noise, dust and offensive odors complaints registered in the month of August 2023.

Source Code/ Name		Calculation of impacts/ citilssions	'	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None	0	0	0	0	0

General

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

Note:

- 1. Parallel test have expired, Data will be back fitted and reported at the licensing office once the process is finalized.
- 2. Correlation Test was conducted on the 10th until the 15 of September 2023. Data will be back fitted and reported at the licensing office.
- 3. Arnot Power Station North Stack emissions exceeded the 48 hours allowable limit for Upset Conditions for three (3) consecutive days (18-20 August 2023) due to plant failures that were resolved, and emissions are back to below license limit.
- 4. **SO₂ and NO** below 80% due to power failure from the monitor system, an averaging was used during the period

Hoping the above will meet your satisfaction.		
Compiled by	Date: 2	0.09.2023
Lawrence Machebe ENVIRONMENTAL OFFICER: ARNOT		
Verified by	Date:	22.09.2023
Sandile Mbuyazi SYSTEM ENGINEER: ARNOT		
Supported by:	Date: 2	2023.09.20
He Wkouhos.		
Rofhiwa Tshikovha SENIOR ENVIRONMENTAL ADVISOR: ARNOT		
Yours sincerely		

Marcus Nemadodzi Date: 2023-09-28

GENERAL MANAGER: ARNOT POWER STATION