

Ms Nompumelelo Simelane
Nkangala District
P.O Box 437
MIDDLEBERG
1050
By email: Simelanenl@nkangaladm.gov.za

Date:
09 October 2023

Enquiries: S Chokoe
Tel +27 13 647 6970

Dear Ms. Nompumelelo Simelane

Ref: Kendal Power Station AEL (17/4/AEL/MP312/11/15)

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF AUGUST 2023.

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:


Irene Motswenyane
ENVIRONMENTAL OFFICER- KENDAL POWER STATION

Date: 09/10/2023

Supported by:


Solly Chokoe
ENVIRONMENTAL MANAGER- KENDAL POWER STATION

Date: 09/10/2023

Generation Division
(Kendal Power Station)
N12 Balmoral Off Ramp, Emalahleni
Private Bag x7272, Emalahlani 1035 SA
Tel +27 13 647 6970 Fax +27 13 647 6904 www.eskom.co.za

KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF AUGUST 2023

Verified by:



Jacob Zwane
BOILER ENGINEERING: SENIOR SYSTEM ENGINEER- KENDAL POWER STATION

Date: 11/10/2023

Validated by:



Tendani Rasivhetshela
BOILER ENGINEERING MANAGER-KENDAL POWER STATION

Date: 16-10-2023

Supported by:



Malibongwe Mabizela
ENGINEERING MANAGER-KENDAL POWER STATION

Date: 18/10/2023


Approved by:



Kobus Steyn
GENERAL MANAGER-KENDAL POWER STATION

Date: 20 Oct 2023

KENDAL POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/15



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Aug-2023
	Coal	Tons	2 260 000	547 601
	Fuel Oil	Tons	5 000	12310 450

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate Aug-2023
	Energy	GWh	3 062 304	878 105
	Ash	Tons	770 000	190 236 587
	RE Ash	kg/MWh	not specified	2 464

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24 (MJ/kg)	18 060
Sulphur Content	%	<1 (%)	0 880
Ash Content	%	40 (%)	34 740

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Aug-2023	Technology Type	SO ₂ Utilization Aug-2023
Unit 1	ESP + SO ₂	97.895%	SO ₂	73.2%
Unit 2	ESP + SO ₂	98.890%	SO ₂	77.9%
Unit 3	ESP + SO ₂	99.456%	SO ₂	0.0%
Unit 4	ESP + SO ₂	Off-line	SO ₂	Off-line
Unit 5	ESP + SO ₂	98.354%	SO ₂	26.9%
Unit 6	ESP + SO ₂	99.206%	SO ₂	40.3%

SO₃ plant for Unit 3 was in service and was injecting as required however the station was unable to archive the information to our PI system. It is the failure of the stations very old and obsolete windows 97 SCADA system which the station is looking to replace during the next GO outage on unit 3.

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

SO₃ trip due to burner out let temp high, SO₃ plant on hold mode due to low steam temperature, SO₃ plant tripped due to steam inlet.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	93.0	86.8	73.2	75.6
Unit 2	100.0	88.5	88.9	1.1
Unit 3	39.4	100.0	100.0	33.1
Unit 4	OFF	0.0	0.0	40.0
Unit 5	82.7	92.7	97.9	99.8
Unit 6	88.4	97.0	96.5	13.1

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Note: Unit 3 dust monitors reliability is low due to monitors maxing out. Unit 2 SO₂ & Nox, Unit 1, 2, 3, 4 and 6 O₂ monitors reliability low due to defective monitors

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of August 2023

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	759.5	3 159	1 212
Unit 2	276.4	1 259	459
Unit 3	86.7	779	276
Unit 4	OFF	60	15
Unit 5	875.2	1 713	754
Unit 6	165.9	751	455
SUM	2 163.84	7 720	3 171

Table 6.2: Operating days in compliance to PM AEL Limit - August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	1	6	0	18	24	571.1
Unit 2	0	3	0	13	16	373.1
Unit 3	0	2	0	7	9	178.5
Unit 4	OFF	OFF	OFF	OFF	Exempt	Exempt
Unit 5	1	4	0	21	25	549.9
Unit 6	3	6	0	5	11	246.8
SUM	5	21	0	64	85	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	26	0	0	0	0	1 983.7
Unit 2	19	0	0	0	0	1 536.2
Unit 3	9	0	0	0	0	1 860.3
Unit 4	5	0	0	0	0	1 761.1
Unit 5	27	0	0	0	0	1 649.6
Unit 6	15	0	0	0	0	1 327.6
SUM	101	0	0	0	0	


Table 6.4: Operating days in compliance to NOx AEL Limit - August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	26	0	0	0	0	763.7
Unit 2	19	0	0	0	0	566.5
Unit 3	9	0	0	0	0	656.4
Unit 4	5	0	0	0	0	452.6
Unit 5	27	0	0	0	0	720.0
Unit 6	15	0	0	0	0	802.6
SUM	101	0	0	0	0	


Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal	GREEN	Emissions below Emission Limit Value (ELV)
Grace	BLUE	Emissions above the ELV during grace period
Section 30	ORANGE	Emissions above ELV during a NEMA S30 incident
Contra-vention	RED	Emissions above ELV but outside grace or S30 incident conditions




High emissions can be attributed to Primary conveyor 14 knife gates closed for chain replacement, SO3 trip due to burner out let temp high, SO3 plant on hold mode due to low steam temperature, SO3 plant tripped due to steam inlet, Fuel oil support, Precip conveyor 12 tripped.



High emissions can be attributed to DHP off, Fuel oil support, DHP off due to PLC off, Unit Light up - hot start,

Figure 3: Kendal Unit 3 PM Emissions - August 2023



High PM emissions can be attributed to DHP off, Fuel oil support, Top bunker conveyor off awaiting for spares, First 5 hopper knife gates on precip conveyors 11 - 24 shut - No conditioners available for compartment 10. Stream 1 dust handling plant tripped - Compartment 10 level high - All precip hopper knife gates shut. DHP plant stopped due to compartment full.

Figure 4: Kendal Unit 4 PM Emissions - August 2023






Figure 5: Kendal Unit 5 PM Emissions - August 2023



High PM emissions can be attributed to Fuel oil support Light up condition - Hot start, Precip field 11,12,21,22,24,26,36,43 and 45 falling out and falls to reset. SO3 plant had no flow due to lower steam temperature, DHP stopped due high compartment levels. Precip conv 14 still keeps tripping, DHP off stream 2, second collector conveyor faulty, DHP stopped due high compartment levels, DHP tripped due to high FAB 3 compartments - all hoppers knife gates fully shut, DHP stream 1 trips due to compartments full.

Figure 6: Kendal Unit 6 PM Emissions - August 2023



High PM emissions can be attributed to High PM emissions can be attributed to fuel oil support, SO3 plant had no flow due to lower steam temperature, DHP stopped due high compartment levels precip field faulty.

Figure 7: Kendal Unit 1 SO₂ Emissions - August 2023




Figure 8: Kendal Unit 2 SO₂ Emissions - August 2023














Figure 9: Kendal Unit 3 SO₂ Emissions - August 2023







7 COMPLAINTS

There were no complaints for this month

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

Abatement Technology-Table 4

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☑ Coal ash content (%) and burnt rate mass
- ☑ Fly : Coarse ash ratio of 80:20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- ☑ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{DustEmissionFromAQR ReportDustMonitor(tons)} \times 100)}{(\text{CoalBurnt(tons)} \times \% \text{AshContent} \times 80\%)}$$

Monitor Reliability-Table 5

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average.

The **monitor reliability** refers to **data reliability** because the assumed value of 99.325% reliability is compared to the dust concentration signal. If the dust concentration signal is above 99.325% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g 24hours

The formula is as follows:

$$= (1 - (\text{count hours above } 99.325\%/24\text{hours})) \times 100$$

Emissions Performance:

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2,4,5 &6 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Unit 5 Monitor still using the old monitor correlation. After new correlations are done, new correlation factors will be implemented and backfitted to the date of monitor installation.
- U1 and 3 monitors maxed out, meaning the emission were higher than what the monitor was correlated for. In which case we use surrogate values. This is attributed to abnormal plant conditions including no DHP and No SO3 plant during the period.
- Please note the reported figures in tonnage calculation are an under estimate since the station did not use the Maxing out PM monitor quantification exercise which is the use of "surrogate values" on days when the monitor maxed out. The following are the days when the monitor was maxing out: Unit 1 from the 1st - 2nd, 4th - 7th, 10th - 11th,18th,24th,28 and 29th - 31st, Unit 3 on the 1st -8th. Figures will be restated based on updated upset testing and surrogate value determination that Kendal will conduct in September- October.
- Unit 1 NOx on the 7th, 14th -22nd,23rd and 24th,monitor was defective, data was deleted the tool will average itself.
-
- Unit 1
- Findings: The high emissions can be attributed to Primary conveyor 14 knife gates closed for chain replacement, SO3 trip due to burner out let temp high, SO3 plant on hold mode due to low steam temperature, SO3 plant tripped due to steam inlet, Fuel oil support, Precip convy 12 tripped.
- Resolution: Plant repaired
- Unit 2
- Findings: The high emissions can be attributed to DHP off, Fuel oil support, DHP off due to PLC off, Unit Light up - hot start,
- Resolution: Plant repaired.
- Unit 3
- Findings: The high PM emissions can be attributed to DHP off, Fuel oil support,Top bunker conveyor off awaiting for spares, First 5 hopper knife gates on precip conveyors 11 - 24 shut - No conditioners available for compartment 10. Stream 1 dust handling plant tripped - Compartment 10 level high - All precip hopper knife gates shut. DHP plant stopped due to compartment full.
- Resolution: Palnt repaired.
- Unit 4
- Findings: High PM emissions can be attributed to Light up condition - cold start, Fuel oil support
- Resolution: Plant repaired.
- Unit 5
- Findings: High PM emissions can be attributed to Fuel oil support Light up condition - Hot start, Precip field 11,12,21,22,24,26,36,43 and 45 falling out and fails to reset, SO3 plant had no flow due to lower steam temperature, DHP stopped due high compartment levels.Precip conv 14 still keeps tripping, DHP off stream 2, second collector conveyor faulty, DHP stopped due high compartment levels, DHP tripped due to high FAB 3 compartments - all hoppers knife gates fully shut,DHP stream 1 trips due to compartments full.
- Resolution: Plant repaired.
- Unit 6
- Findings: High PM emissions can be attributed to fuel oil support, SO3 plant had no flow due to lower steam temperature, DHP stopped due high compartment levels precip field faulty.
- Resolution: Plant repaired.