	<b>Technical and Generic Report</b>	<b>Matimba Power Station</b>
---	-------------------------------------	------------------------------

Title: **Matimba Power Station August 2023 emissions report**

Document Identifier: **RP/247/038**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **41**

Report Date: **August 2023**

Disclosure Classification: **Controlled**


Compiled by



**KH Ramahlare**  
**Senior Advisor**  
**Environment**

Date: 2023-10-02

Functional Responsibility



**MC Mamabolo**  
**Environmental Manager**

Date: 04/10/2023

Authorized by



**Obakeng Mabotja**  
**General Manager**

Date: 2023-10-04

## Content

	Page
1. Report Summary .....	4
2. Emission information .....	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics .....	5
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions .....	6
2.4.2 Gaseous Emissions .....	12
2.4.3 Total Volatile Organic Compounds .....	24
2.4.4 Greenhouse gas (CO <sub>2</sub> ) emissions .....	25
2.5 Daily power generated .....	25
2.6 Pollutant Tonnages .....	32
2.7 Operating days in compliance to PM AEL Limit .....	32
2.8 Operating days in compliance to SO <sub>x</sub> AEL Limit .....	32
2.9 Operating days in compliance to NO <sub>x</sub> AEL Limit .....	33
2.10 Reference values .....	33
2.11 Continuous Emission Monitors.....	33
2.11.1 Reliability.....	33
2.11.2 Changes, downtime, and repairs .....	34
2.11.3 Sampling dates and times.....	35
2.12 Units Start-up information .....	35
2.13 Emergency generation .....	38
2.14 Complaints register .....	39
2.15 Air quality improvements and social responsibility conducted .....	39
2.15.1 Air quality improvements.....	39
2.15.2 Social responsibility conducted.....	39
2.16 Ambient air quality monitoring.....	40
2.17 Electrostatic precipitator and Sulphur plant status .....	40
2.18 General.....	41
3. Attachments.....	41
4. Report Conclusion .....	41
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics. ....	6
Table 4: Total volatile compound estimates .....	24
Table 5: Daily power generated per unit in MWh for the month of August 2023.....	25
Table 6: Pollutant tonnages for the month of August 2023 .....	32

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 7: Operating days in compliance with PM AEL limit of August 2023.....	32
Table 8: Operating days in compliance with SOx AEL limit of August 2023 .....	32
Table 9: Operating days in compliance with NOx AEL limit of August 2023.....	33
Table 10: Reference values for data provided, August 2023 .....	33
Table 11: Average percentage (%) availability of monitors for the month of August 2023. ....	33
Table 12: Dates of last conducted CEMS verification tests for PM, SO <sub>2</sub> and NOx .....	35
Table 13: Start-up information .....	35
Table 14: Emergency generation .....	38
Table 15: Complaints.....	39

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of August 2023 .....	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of August 2023 .....	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of August 2023 .....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of August 2023 .....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of August 2023 .....	11
Figure 6: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of April 2023.....	12
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of August 2023 .....	13
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of August 2023 .....	14
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 4 for the month of August 2023 .....	15
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of August 2023 .....	17
Figure 11: NOx daily average emissions against emission limit for unit 1 for the month of August 2023 .....	18
Figure 12: NOx daily average emissions against emission limit for unit 2 for the month of August 2023 .....	19
Figure 13: NOx daily average emissions against emission limit for unit 3 for the month of August 2023 .....	20
Figure 14: NOx daily average emissions against emission limit for unit 4 for the month of August 2023 .....	21
Figure 15: NOx daily average emissions against emission limit for unit 6 for the month of August 2023 .....	23
Figure 16: Unit 1 daily generated power in MWh for the month of August 2023.....	26
Figure 17: Unit 2 daily generated power in MWh for the month of August 2023.....	27
Figure 18: Unit 3 daily generated power in MWh for the month of August 2023.....	28
Figure 19: Unit 4 daily generated power in MWh for the month of August 2023.....	29
Figure 20: Unit 6 daily generated power in MWh for the month of August 2023.....	30

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for August 2023.



During the period under review, Matimba experienced 49 exceedances of the daily particulate matter emission limit ( $50\text{mg}/\text{Nm}^3$ ), 26 of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. 23 of these exceedances occurred within the 48-hour grace period.

No exceedances of the monthly  $\text{SO}_x$  limit ( $3500\text{mg}/\text{Nm}^3$ ) or the daily  $\text{NO}_x$  emission limit ( $750\text{mg}/\text{Nm}^3$ ) occurred.

The flue gas conditioning plant ( $\text{SO}_3$  Plant) for all the units did not achieve the required 100% availability due to the defects and breakdown experienced on the plants throughout the month. The  $\text{SO}_3$  plants defects were repaired, and plants returned to operation.

For the month of August 2023 Matimba Power Station used a total of 1649,556 tons of fuel oil, exceeding the monthly limit of 1200 tons. The increased usage was due to multiple light-ups of units after outages.

More information regarding above mentioned issues is provided in the relevant sections within the report.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	968 519
	Fuel Oil	Tons/month	1 200	1649,556
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	2418,19086

The fuel oil consumption for the month of August 2023 exceeded the maximum permitted limits of 1200 Tons due to the multiple unit light ups that happened for unit 2,3,4 and 5.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,82%
Unit 2	Electrostatic Precipitator	100%	99,83%
Unit 3	Electrostatic Precipitator	100%	99,92%
Unit 4	Electrostatic Precipitator	100%	99,86%
Unit 5	Electrostatic Precipitator	100%	99,83%
Unit 6	Electrostatic Precipitator	100%	99,83%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	94,76%
Unit 2	SO <sub>3</sub> Plant	100%	90,29%
Unit 3	SO <sub>3</sub> Plant	100%	92,57%
Unit 4	SO <sub>3</sub> Plant	100%	94,88%
Unit 5	SO <sub>3</sub> Plant	100%	94,21%
Unit 6	SO <sub>3</sub> Plant	100%	94,62%

Flue gas conditioning plant availability was below the required 100% for all six (06) units due to maintenance activities and unplanned breakdowns. Defects were addressed and plants returned. Energy source characteristics

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Table 3: Energy Source Material Characteristics.**


	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,27%
	Ash Content	40%	35,40%

Energy source characteristics remained within the ranges stipulated in the license.

## 2.3 Emissions reporting

### 2.3.1 Particulate Matter Emissions

#### Unit 1 Particulate Emissions



**Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of August 2023**

#### Interpretation:


Unit 1 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1-5,7-8, 10-15, and 17 -27 August 2023. The exceedances of the 3 to 5,12 to 15 and 19 to 27 August 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due unavailability of the ash conveyance plant that led to accumulation of ash at the dust handling plant leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 2 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of August 2023**

#### Interpretation:

Unit 2 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 10,13 and 15 to 21 August 2023. The exceedances from the 15 to 21 August 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to unavailability of the ash conveyance plant that led to accumulation of ash at the dust handling plant leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measures put in place to correct the root causes.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of August 2023

**Interpretation:**

Unit 3 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 30 August 2023. The exceedance was due to unavailability of the ash conveyance system that led to ash accumulation on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The exceedances remained within the 48-hour grace period


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of August 2023**

#### Interpretation:


Unit 4 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 2-4, 6-10, 19-22, 24, 26, 29 and 30 August 2023. Exceedances of 4, 8 to 10, 21 and 22 August 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of August 2023**

#### Interpretation:


Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 1,3,4,11,14 to 26 August 2023. Exceedances from 1, and 16 to 26 August 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 6 Particulate Emissions



**Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of August 2023**

#### Interpretation:

Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 10 to 25 August 2023. The exceedances from 12 to 25 August 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.


No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.3.2 Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in August 2023 as per the AEL requirements.

The quality assurance spot tests were performed on the monitors in July 2023.

#### Unit 1 SO<sub>2</sub> Emissions



**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of August 2023**


#### Interpretation:

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO<sub>2</sub> Emissions

**Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of August 2023**

**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 SO<sub>2</sub> Emissions

Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of August 2023


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO<sub>2</sub> Emissions

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 4 for the month of August 2023**


**Interpretation:**

All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 SO<sub>2</sub> Emissions

**Figure 11: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of August 2023**

**Interpretation:**


All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Unit 6 SO<sub>2</sub> Emissions**

**Figure 12: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of August 2023**


**Interpretation:**

All daily averages remained below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 NO<sub>x</sub> Emissions

**Figure 13: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of August 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO<sub>x</sub> Emissions

**Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of August 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 NO<sub>x</sub> Emissions

**Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of August 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO<sub>x</sub> Emissions

**Figure 16: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of August 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO<sub>x</sub> Emissions

**Figure 17: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of August 2023**


**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 NO<sub>x</sub> Emissions

**Figure 18 NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of August 2023**

**Interpretation:**

All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.3.3 Total Volatile Organic Compounds

**Table 4:** Total volatile compound estimates

		
<b>CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*</b>		
<b>Date:</b>	Tuesday, 19 September 2023	
<b>Station:</b>	Matimba Power Station	
<b>Province:</b>	Limpopo Province	
<b>Tank no.</b>	1-4	
<b>Description:</b>	Outdoor fuel oil storage tank	
<b>Tank Type:</b>	Vertical fixed roof (vented to atmosphere)	
<b>Material stored:</b>	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <b>blue cells</b> below</p> <p align="center">Choose from a dropdown menu in the <b>green cells</b></p> <p align="center">The total VOC emissions for the month are in the <b>red cells</b></p> <p align="center">IMPORTANT: Do not change <b>any</b> other cells without consulting the AQ CoE</p>		
<b>MONTH:</b>	<b>August</b>	
<b>GENERAL INFORMATION:</b>	<b>Data</b>	<b>Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	<b>1649,556</b>	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>	<b>Data</b>	<b>Unit</b>
Daily average ambient temperature	20,46	°C
Daily maximum ambient temperature	28,86	°C
Daily minimum ambient temperature	12,76	°C
Daily ambient temperature range	16,09	°C
Daily total insolation factor	4,23	kWh/m²/day
Tank paint colour	<b>Grey/medium</b>	NA
Tank paint solar absorbance	0,68	NA
<b>FINAL OUTPUT:</b>	<b>Result</b>	<b>Unit</b>
Breathing losses:	<b>0,56 kg/month</b>	
Working losses:	<b>0,05 kg/month</b>	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0,61 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chew Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



### 2.3.4 Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.4 Daily power generated


**Table 5:** Daily power generated per unit in MWh for the month of August 2023

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2023/08/01	10996,9	10750,5	13514	3115,6	10068,8	11690,1
2023/08/02	7055,15	10809,2	13148,1	12515,5	10077,3	11960,9
2023/08/03	12282,5	10405,3	13241	12924,1	11723	11259,4
2023/08/04	10174,6	10466,7	13204	10830,5	11686	11995,7
2023/08/05	10063,8	10442,2	13391,5	10249,5	11480,3	12057,6
2023/08/06	10044,3	10312,9	12937,6	10243,4	11217,7	11833,1
2023/08/07	10039,6	10280,8	13396,1	10418,3	11486,8	12326,5
2023/08/08	9836,96	10278,7	13598,3	10189,8	11791,7	12263,3
2023/08/09	9902,41	10727,7	13274,2	10190	12291,6	12054,7
2023/08/10	10002,7	10786,2	13480,2	5741,35	12016,3	11207,6
2023/08/11	10190	11232,6	13258,3	0	12096,9	10171,4
2023/08/12	10180,9	10850,2	13741	0	11552,9	10140,3
2023/08/13	10176,5	10612,4	13558,3	0	11542,3	10145,6
2023/08/14	10155,4	10110	12952	0	11437,8	10125,6
2023/08/15	9944,3	9281,32	12576,8	884,261	11355,6	9779,35
2023/08/16	10951	9881,82	12942,8	11228	11002,1	10101,4
2023/08/17	10382,2	10391,1	12772,4	11477,3	10202,8	10099,5
2023/08/18	9976,25	9170,55	12512,5	10091,6	10331,8	10045,3
2023/08/19	10229,4	8017,77	12390,4	9458,71	10162,8	10102,2
2023/08/20	10134,1	7928,1	737,875	10067,5	11268,8	10060,7
2023/08/21	10018,6	8514,38	0	10098,4	10021,7	9584,7
2023/08/22	9854,36	8688,68	0	9978,34	9918,62	9638,45
2023/08/23	9898,46	8565,55	0	10256,8	10099,3	9819,13
2023/08/24	10239	4475,94	0	11144,5	10951,2	10170,8
2023/08/25	10466,1	0	0	10486,7	11641,8	10174,6
2023/08/26	10810,6	2258,48	0	10388,2	11520,8	9779,6
2023/08/27	481,199	10192	4942,74	10693,4	12365,2	11060
2023/08/28	0	10449,4	12998,5	10740,3	12408,1	11993,3
2023/08/29	0	10972,7	7641,03	10732,1	3089,32	12358
2023/08/30	0	10402,3	13391,8	10338	11736,1	12304,7
2023/08/31	0	10188,1	13079,2	9965,18	11836,5	12111,2

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 19: Unit 1 daily generated power in MWh for the month of August 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 20: Unit 2 daily generated power in MWh for the month of August 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 21: Unit 3 daily generated power in MWh for the month of August 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 22: Unit 4 daily generated power in MWh for the month of August 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




**Figure 23: Unit 5 daily generated power in MWh for the month of August 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 24: Unit 6 daily generated power in MWh for the month of August 2023**

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.5 Pollutant Tonnages

The emitted pollutant tonnages for August 2023 are provided in table 6.

**Table 6:** Pollutant tonnages for the month of August 2023

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	CO <sub>2</sub> (tons)
Unit 1	80,6	2 892,9	512,6	243 592
Unit 2	85,7	5 698,8	923,5	379 490
Unit 3	38,5	4 970,1	891,4	369 127
Unit 4	60,0	4 141,6	829,1	223 794
Unit 5	100,6	2 521,2	456,9	193 201
Unit 6	99,1	3 818,1	797,8	398 074
<b>SUM</b>	<b>464,4</b>	<b>24 042,7</b>	<b>4 411,4</b>	<b>1807279</b>

## 2.6 Operating days in compliance to PM AEL Limit

**Table 7:** Operating days in compliance with PM AEL limit of August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
Unit 1	3	8	0	16	24	57,4
Unit 2	21	4	0	4	8	51,4
Unit 3	23	1	0	0	1	26,5
Unit 4	9	10	0	6	16	59,8
Unit 5	14	5	0	12	17	58,1
Unit 6	16	4	0	11	15	55,7
<b>SUM</b>	<b>56</b>	<b>23</b>	<b>0</b>	<b>26</b>	<b>49</b>	

## 2.7 Operating days in compliance to SOx AEL Limit

**Table 8:** Operating days in compliance with SOx AEL limit of August 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SOx (mg/Nm <sup>3</sup> )
Unit 1	27	0	0	0	0	1 908,4
Unit 2	30	0	0	0	0	2 418,3
Unit 3	25	0	0	0	0	2 338,0
Unit 4	27	0	0	0	0	2 461,6
Unit 5	31	0	0	0	0	1 205,3
Unit 6	31	0	0	0	0	1 628,3
<b>SUM</b>	<b>109</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.8 Operating days in compliance to NOx AEL Limit

**Table 9: Operating days in compliance with NOx AEL limit of August 2023**

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm <sup>3</sup> )
Unit 1	27	0	0	0	0	338,0
Unit 2	30	0	0	0	0	391,6
Unit 3	25	0	0	0	0	417,3
Unit 4	27	0	0	0	0	490,7
Unit 5	31	0	0	0	0	219,5
Unit 6	31	0	0	0	0	340,9
<b>SUM</b>	<b>109</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

## 2.9 Reference values

**Table 10: Reference values for data provided, August 2023**

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	5,70	9,58	4,47	7,57	5,92	6,85
Moisture	%	4,22	3,02	5,90	2,60	4,11	1,63
Velocity	m/s	19,1	33,9	27,9	24,1	22,8	28,7
Temperature	°C	134,8	121,0	130,1	125,8	126,4	164,4
Pressure	mBar	929,0	936,0	920,8	931,4	922,2	918,7

## 2.10 Continuous Emission Monitors

### 2.10.1 Reliability

Continuous emission monitors were available for more than 80% of the reporting period. The emitted pollutant tonnages for August 2023 are provided in table 6.

**Table 11: Average percentage (%) availability of monitors for the month of August 2023.**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	CO <sub>2</sub>
Unit 1	100,0	99,8	99,8	99,8
Unit 2	99,6	100,0	89,6	99,7
Unit 3	100,0	100,0	99,8	99,7
Unit 4	100,0	100,0	100,0	98,4
Unit 5	100,0	99,3	88,3	58,5
Unit 6	98,1	99,7	99,7	99,5

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## **2.10.2 Changes, downtime, and repairs**

### **Unit 1**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

### **Unit 2**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

### **Unit 3**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

### **Unit 4**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

### **Unit 5**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

### **Unit 6**

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

## **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

### 2.10.3 Sampling dates and times

**Table 12:** Dates of last conducted CEMS verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub>

<b>Name of service provider:</b>		Stacklabs Environmental Services CC		
<b>Address of service provider:</b>		10 Chisel Street Boltonia Krugersdorp 1739		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
1	2020/09/30 06h04	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00
2	2021/01/26 04h52	2021/01/27 13h00	2021/01/27 13h00	2021/01/27 13h00
3	2021/08/10 12h05	2020/09/24 07h00	2020/09/24 07h00	2020/09/24 07h00
4	2021/07/13 14h31	2020/09/16 02h00	2020/09/16 02h00	2020/09/16 02h00
5	2020/10/06 05h39	2020/10/08 02h30	2020/10/08 02h30	2020/10/08 02h30
6	2020/09/09 06h41	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00

Note: The CEMS verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> were performed in October 2022 and failed. The spot tests were done in August 2023.

### 2.11 Units Start-up information

**Table 13:** Start-up information

<b>Unit</b>	1	
<b>Fires in</b>	2023/08/02	13h17
<b>Synchronization with Grid</b>	2023/08/02	15h46
<b>Emissions below limit</b>	2023/08/03	00h01
<b>Fires in, to synchronization</b>	2,29	HOURS
<b>Synchronization to &lt; Emission limit</b>	9,15	HOURS

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	2	
<b>Fires in</b>	2023/08/26	00h08
<b>Synchronization with Grid</b>	2023/08/26	12h36
<b>Emissions below limit</b>	2023/08/26	19h01
<b>Fires in, to synchronization</b>	12,28	HOURS
<b>Synchronization to &lt; Emission limit</b>	6,25	HOURS

<b>Unit</b>	2	
<b>Fires in</b>	2023/08/26	18h26
<b>Synchronization with Grid</b>	2023/08/26	20h54
<b>Emissions below limit</b>	2023/08/26	20h54
<b>Fires in, to synchronization</b>	2,28	HOURS
<b>Synchronization to &lt; Emission limit</b>	0	HOURS

<b>Unit</b>	3	
<b>Fires in</b>	2023/08/27	06h48
<b>Synchronization with Grid</b>	2023/08/27	11h16
<b>Emissions below limit</b>	2023/08/27	16h03
<b>Fires in, to synchronization</b>	4,28	HOURS
<b>Synchronization to &lt; Emission limit</b>	4,47	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	3	
<b>Fires in</b>	2023/08/29	12h22
<b>Synchronization with Grid</b>	2023/08/29	15h40
<b>Emissions below limit</b>	2023/08/29	16h06
<b>Fires in, to synchronization</b>	3,18	HOURS
<b>Synchronization to &lt; Emission limit</b>	0,26	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	2023/08/01	05h08
<b>Synchronization with Grid</b>	2023/08/01	14h29
<b>Emissions below limit</b>	2023/08/01	18h04
<b>Fires in, to synchronization</b>	9,21	HOURS
<b>Synchronization to &lt; Emission limit</b>	3,35	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	2023/08/15	04h07
<b>Synchronization with Grid</b>	2023/08/15	19h20
<b>Emissions below limit</b>	2023/08/16	01h05
<b>Fires in, to synchronization</b>	15,13	HOURS
<b>Synchronization to &lt; Emission limit</b>	5,45	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	5	
<b>Fires in</b>	2023/08/29	03h56
<b>Synchronization with Grid</b>	2023/08/29	22h19
<b>Emissions below limit</b>	2023/08/30	01h04
<b>Fires in, to synchronization</b>	18,23	HOURS
<b>Synchronization to &lt; Emission limit</b>	2,45	HOURS

## 2.12 Emergency generation

**Table 14:** Emergency generation

	<b>Unit 1</b>	<b>Unit 2</b>	<b>Unit 3</b>	<b>Unit 4</b>	<b>Unit 5</b>	<b>Unit 6</b>
<b>Emergency Generation hours declared by national Control</b>	744	744	744	744	744	744
<b>Emergency Hours declared including hours after stand down</b>						
<b>Days over the Limit during Emergency Generation</b>	24	8	1	16	17	15

During the period under review all Units were on emergency generation in force from 01 August 2023 until 31 August 2023.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.13 Complaints register

**Table 15:** Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
Manketti lodge And neighbouring farms	Operational changes -The ashing philosophy was updated to piggybacking format (increasing height of the dump by ashing on top of rehabilitated old ash body);	Average fugitive dust fallout for August 2023 on the Ash dumping facility in all directions of communities where complaints originated from was 742,89 mg/m2/day	N/A	Acquire additional resources to extend the dust suppression with water at the ash dump to cover the piggybacking area.	Completed
Marapong Community members (social media)				Covering the exposed long- standing areas with topsoil.	November 2023
Onverwacht counsellor					

## 2.14 Air quality improvements and social responsibility conducted

### 2.14.1 Air quality improvements

None

### 2.14.2 Social responsibility conducted

None

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.15 Ambient air quality monitoring

Ambient air quality monitoring report was not available at the time of publishing this report.

## 2.16 Electrostatic precipitator and Sulphur plant status

### Unit 1

- 8 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 2

- 7 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 3

- 2 fields out of service, will be inspected next opportunity. No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 4

- 4 field out of service, will be inspected next opportunity.
- No abnormalities on the SO<sub>3</sub> plant. Preventative maintenance done during the month.

### Unit 5

- 7 fields out of service, will be inspected next opportunity.
- Hole in burner casing and sulphur leak causing low availability. Preventative maintenance done during the month.

### Unit 6

- 7 fields out of service, will be inspected next opportunity.
- Hole in burner casing and sulphur leak causing low availability. Preventative maintenance done during the month.

### SO<sub>3</sub> common plant

- No abnormalities on the sulphur storage plant.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## 2.17 General

### Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. Eskom internal standard 240-56242363 Emissions Monitoring and Reporting Standard

### Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

None

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely

pp *Wikus van Rensburg*

GENERAL MANAGER: MATIMBA POWER STATION

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.