

The Municipal Manager
Gert Sibande District Municipality
PO Box 1748
ERMELO
2350

Date: 11 August 2023

Enquiries: X. Jila

Tel +27 17 749 5100

E-mail: records@gsibande.gov.za
Email: dan.hlanyane@gsibande.gov.za

Dear Mr Hlanyane

TUTUKA POWER STATION MONTHLY REPORT FOR JULY 2023

This serves as the monthly report required in terms of Section 7.4 of Tutuka Power Station's Atmospheric Emission License (16/4/Lekwa/Eskom H SOC Ltd TPS/0013/2019/f03). The report includes verified emissions of Particulate Matters, Sulphur, and Nitrogen dioxides for the month of July 2023

The report presents monthly trends for each monitored pollutant. Units 1, 2, 5 and 6 were offload for the month of July 2023. There were no exceedances of the dust and gases operating limits recorded in July 2023.

1. RAW MATERIALS AND PRODUCTS

Raw Materials	Raw Material Type	Units Max. Permitted		Actual Consumption Jul-2023
and Products	Coal	Tons	1 200 000	206 313
	Fuel Oil	Tons	10 000	4447.26
	Product / By-Product	Units	Max. Production Capacity Permitted	Indicative Production Rate Jul-
	Name		Capacity Fermitted	2023
Production Rates	Name Energy	GWh	2 611.440	2023 348.798
Production Rates	100000000000000000000000000000000000000	GWh Tons		

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [3 510 MW] x 24 hrs x days in Month/1000 to convert to GWh







2. ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24	21.230
Sulphur Content	%	0.6 TO >2.6	0.900
Ash Content	%	21 TO >33	26.260

3. EMISSIONS LIMIT (mg/Nm³)

Associated Unit/Stack	РМ	SO ₂	NOx	
Unit 1	300	3400	1200	
Unit 2	300	3400	1200	
Unit 3	300	3400	1200	
Unit 4	300	3400	1200	
Unit 5	300	3400	1200	
Unit 6	300	3400	1200	

4. ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Apr-2022	
Unit 1	Electrostatic Precipitators (ESP)	Unit OFF	
Unit 2	Electrostatic Precipitators (ESP)	Unit OFF	
Unit 3	Electrostatic Precipitators (ESP)	Unit OFF	
Unit 4	Electrostatic Precipitators (ESP)	Unit OFF	
Unit 5	Electrostatic Precipitators (ESP)	Unit OFF	
Unit 6	Electrostatic Precipitators (ESP)	Unit OFF	

Note: The ESP does not have bypass mode operating, hence plant considered 100% Utilised.

5. MONITOR RELIABILITY (%

Associated Unit/Stack	PM	SO ₂	NO	02
Unit 1	OFF	OFF	OFF	OFF
Unit 2	OFF	OFF	OFF	OFF
Unit 3	100.0	0.0	0.0	0.0
Unit 4	99.4	99.9	0.0	0.0
Unit 5	OFF	OFF	OFF	OFF
Unit 6	OFF	OFF	OFF	OFF

Note:

All .

^{1.} The gas monitors were not working properly and surrogate values from Parallel tests reports (QAL 2) were used to estimate the gas concentrations and to Tonnages.

6. EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of July-2023

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)	
Unit 1	OFF	OFF	OFF	
Unit 2	OFF	OFF	OFF	
Unit 3	123.5	1 420	520	
Unit 4	145.8	2 650	1 193	
Unit 5	OFF	OFF	OFF	
Unit 6	OFF	OFF	OFF	
SUM	269.4	4 070	1 713	

Table 6.2: Operating days in compliance to PM AEL Limit - July 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
Unit 1	OFF	OFF	OFF	OFF	OFF	OFF
Unit 2	OFF	OFF	OFF	OFF	OFF	OFF
Unit 3	9	0	0	0	0	206.1
Unit 4	28	0	0	0	0	103.4
Unit 5	OFF	OFF	OFF	OFF	OFF	OFF
Unit 6	OFF	OFF	OFF	OFF	OFF	OFF
SUM	37	0	0	0	0	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - July 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm³)
Unit 1	OFF	OFF	OFF	OFF	OFF	OFF
Unit 2	OFF	OFF	OFF	OFF	OFF	OFF
Unit 3	9	0	0	0	0	2 370.6
Unit 4	28	0	0	0	0	1 889.6
Unit 5	OFF	OFF	OFF	OFF	OFF	OFF
Unit 6	OFF	OFF	OFF	OFF	OFF	OFF
SUM	37	0	0	0	0	




Table 6.4: Operating days in compliance to NOx AEL Limit - July 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	OFF	OFF	OFF	OFF	OFF	OFF
Unit 2	OFF	OFF	OFF	OFF	OFF	OFF
Unit 3	9	0	0	0	0	867.5
Unit 4	28	0	0	0	0	852.3
Unit 5	OFF	OFF	OFF	OFF	OFF	OFF
Unit 6	OFF	OFF	OFF	OFF	OFF	OFF
SIIM	37	0	0	0	0	


Note: NOx emissions are measured as NO in PPM. Final NOx value is expressed as total NO2


Table 6.5: Legend Description

Condition	Colour	Description	
Normal		Emissions below Emission Limit Value (ELV)	
Grace		Emissions above the ELV during grace period	
Section 30	克斯格斯	Emissions above ELV during a NEMA S30 incident	
Contravention		Emissions above ELV but outside grace or S30 incident conditions	






















7. COMPLAINTS REGISTER

Source Code/Name	Root Cause Analysis	Calculation of Impacts/emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent recurrence	Date by which measure will be implemented
No complair attached	its were rece	eived for the month of	July 2023. C	opy of the incid	ent register is

For more information or enquiries contact the Tutuka environmental team.

Yours Sincerely

Compiled by:

Supported by:

Xoli Jila

EMISSIONS CONTROL OFFICER

Mike Molepo

Snr CHEMIST: BOILER ENGINEERING



Approved by: