



Ms Nompumelelo Simelane  
Nkangala District  
P.O Box 437  
MIDDLEBERG  
1050  
By email: Simelanenl@nkangaladm.gov.za

Date:  
24 November 2023

Enquiries: S Chokoe  
Tel +27 13 647 6970

Dear Ms. Nompumelelo Simelane

Ref: Kendal Power Station AEL (17/4/AEL/MP312/11/15)

**KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF OCTOBER 2023.**

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

**Compiled by:**

  
Irene Motswenyane  
**ENVIRONMENTAL OFFICER- KENDAL POWER STATION**

Date: 24/11/2023

**Supported by:**


  
Solly Chokoe  
**ENVIRONMENTAL MANAGER- KENDAL POWER STATION**

Date: 24/11/2023

**Generation Division**  
(Kendal Power Station)  
N12 Balmoral Off Ramp, Emalahleni  
Private Bag x7272, Emalahlani 1035 SA  
Tel +27 13 647 6970 Fax +27 13 647 6904 www.eskom.co.za

**KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF OCTOBER 2023**

**Verified by:**



Jacob Zwane

**BOILER ENGINEERING: SENIOR SYSTEM ENGINEER- KENDAL POWER STATION**

24/11/2023

Date:

**Validated by:**



Tendani Rasivhetshela

**BOILER ENGINEERING MANAGER-KENDAL POWER STATION**

Date:

2023/12/04

**Supported by:**



Malibongwe Mabizela

**ENGINEERING MANAGER-KENDAL POWER STATION**

Date:

11/12/2023

**Approved by:**




Kobus Steyn

**GENERAL MANAGER-KENDAL POWER STATION**

Date:

11 Dec 2023

**KENDAL POWER STATION MONTHLY EMISSIONS REPORT**  
 Atmospheric Emission License 17/4/AEL/MP312/11/15



**1 RAW MATERIALS AND PRODUCTS**

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Oct-2023
	Coal	Tons		2 260 000
Fuel Oil	Tons		5 000	8757.650

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate Oct-2023
	Energy	GWh	3 062.304	1 015.205
	Ash	Tons	770 000	201 022.184
	RE Ash	kg/MWh	not specified	1.831

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [4 116 MW] x 24 hrs x days in Month/1000 to convert to GWh

**2 ENERGY SOURCE CHARACTERISTICS**

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24 (MJ/kg)	18.530
Sulphur Content	%	<1 (%)	0.890
Ash Content	%	40 (%)	32.560

**3 EMISSION LIMITS (mg/Nm<sup>3</sup>)**

Associated Unit/Stack	PM	SO <sub>2</sub>	NOx
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Oct-2023	Technology Type	SO <sub>2</sub> Utilization Oct-2023
Unit 1	ESP + SO <sub>2</sub>	98.760%	SO <sub>2</sub>	91.7%
Unit 2	ESP + SO <sub>2</sub>	99.198%	SO <sub>2</sub>	66.1%
Unit 3	ESP + SO <sub>2</sub>	Off-line	SO <sub>2</sub>	Off-line
Unit 4	ESP + SO <sub>2</sub>	98.582%	SO <sub>2</sub>	0.0%
Unit 5	ESP + SO <sub>2</sub>	98.814%	SO <sub>2</sub>	51.3%
Unit 6	ESP + SO <sub>2</sub>	98.916%	SO <sub>2</sub>	45.0%

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

SO<sub>2</sub> steam supply was lost across the units  
 SO<sub>2</sub> kept on tripping on convertor inlet temp high  
 SO<sub>2</sub> Plant is not injecting  
 SO<sub>2</sub> common plant is out for 48hrs steam leak repairs  
 SO<sub>2</sub> off due to steam temp low  
 SO<sub>2</sub> plant was still off due to mass flow meter that was blocked

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>
Unit 1	99.0	80.4	81.5	97.8
Unit 2	31.7	99.7	72.5	56.0
Unit 3	Off	Off	Off	Off
Unit 4	93.7	100.0	100.0	100.0
Unit 5	97.5	98.8	95.6	100.0
Unit 6	98.5	86.6	98.3	87.7

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO<sub>2</sub>  
 Note: Unit 2 dust monitors reliability is low due to monitors maxing out. Unit 2 O<sub>2</sub> monitors reliability low due to defective monitors

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of October 2023

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	426.6	3 198	1 163
Unit 2	157.7	1 052	391
Unit 3	Off	Off	Off
Unit 4	300.1	708	284
Unit 5	541.8	1 500	646
Unit 6	432.9	932	691
SUM	1 859.12	7 389	3 175

Please note the reported figures in tonnage calculation are an under estimate since the station did not use the Maxing out PM monitor quantification exercise which is the use of "surrogate values" on days when the monitor maxed out.

Table 6.2: Operating days in compliance to PM AEL Limit - October 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
Unit 1	6	10	0	9	19	319.6
Unit 2	0	2	0	13	15	256.8
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	0	2	0	13	15	634.7
Unit 5	8	6	0	11	17	486.1
Unit 6	0	2	0	26	28	292.9
SUM	14	22	0	72	94	

Table 6.3: Operating days in compliance to SO<sub>2</sub> AEL Limit - October 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO <sub>2</sub> (mg/Nm <sup>3</sup> )
Unit 1	27	0	0	0	0	1 466.1
Unit 2	16	0	0	0	0	2 340.6
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	18	0	0	0	0	1 672.6
Unit 5	25	0	0	0	0	1 461.2
Unit 6	30	0	0	0	0	840.0
SUM	116	0	0	0	0	


Table 6.4: Operating days in compliance to NOx AEL Limit - October 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contra-vention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	27	0	0	0	0	533.7
Unit 2	16	0	0	0	0	887.4
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	18	0	0	0	0	671.4
Unit 5	25	0	0	0	0	627.4
Unit 6	30	0	0	0	0	618.3
SUM	116	0	0	0	0	


Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO<sub>2</sub>

Table 6.5: Legend Description

Condition	Colour	Description
Normal	GREEN	Emissions below Emission Limit Value (ELV)
Grace	BLUE	Emissions above the ELV during grace period
Section 30	ORANGE	Emissions above ELV during a NEMA S30 incident
Contra-vention	RED	Emissions above ELV but outside grace or S30 incident conditions



High emissions can be attributed to Dhp standing with all kg's closed due to compartments high levels full, hoopers blocked Precip12 hooper 6, Precip14 hooper 7, Precip 23 hooper 4,6 &, Precip 11 to 14, Pcp 11 hp 3, Pcp 13 hp 7, Pcp 23 hp 1&7, Pcp 12 all k/gates are shut



High emissions can be attributed to DHP off due to Pcp 11 to 14 DHP standing with all the knife gates closed

Figure 3: Kendal Unit 3 PM Emissions - October 2023






Figure 4: Kendal Unit 4 PM Emissions - October 2023




High PM emissions can be attributed to fuel oil support C and E elevator running with left hand site draught group and steam flow low, SO3 kept on tripping on convertor inlet temp high, Stream 2 bucket elevator that has blown the fusible plug and topping of oil fusible plug replacement. S1 bucket elevator coupling was leaking, no ashing on the DHP due to S1 not available, closed all knife gates because of the second collector failure to run, DHP precip conveyors 11 to 14 standing due to stream 3 second collector conveyor faulty, precip conveyors started 11,14, and 21-24 all knife gates closed, precip conveyors 12 and 13 chocked Ashing onto stream 1. Stream 2 B/E standing and 1st collector chocked, DHP standing and all knife gates cback-end temps are very low at 110 and 109 degrees hence the SO3 Plant is not injecting any sulphur, loss due to both S1 and S2 bucket elevators chocked

Figure 5: Kendal Unit 5 PM Emissions - October 2023



High PM emissions can be attributed to Dhp standing due to issues at top bunker, Pcp 21 to 24 DHP standing the 1st collecting conv is suspected of a coupling fault, all knife gates are fully shut, PCP 21\_24 first collector stream 2 tripped, DHP plant was standing with some ash backlogs due to compartment levels that were high and low flow on the SO3 plant, SO3 common plant is out for 48hrs steam leak repairs

Figure 6: Kendal Unit 6 PM Emissions - October 2023



High PM emissions can be attributed to precip 11 to 14 standing, knife gates closed, compartments levels high, So3 off due to steam temp low, SO3 plant was still off due to mass flow meter that was blocked

Figure 7: Kendal Unit 1 SO<sub>2</sub> Emissions - October 2023




Figure 8: Kendal Unit 2 SO<sub>2</sub> Emissions - October 2023




Figure 9: Kendal Unit 3 SO<sub>2</sub> Emissions - October 2023




Figure 10: Kendal Unit 4 SO<sub>2</sub> Emissions - October 2023




Figure 11: Kendal Unit 5 SO<sub>2</sub> Emissions - October 2023




Figure 12: Kendal Unit 6 SO<sub>2</sub> Emissions - October 2023




Figure 13: Kendal Unit 1 NO<sub>x</sub> Emissions - October 2023






Figure 14: Kendal Unit 2 NOx Emissions - October 2023




Figure 15: Kendal Unit 3 NOx Emissions - October 2023




Figure 16: Kendal Unit 4 NOx Emissions - October 2023




Figure 17: Kendal Unit 5 NOx Emissions - October 2023





Figure 18: Kendal Unit 6 NOx Emissions - October 2023



## 7 COMPLAINTS

There were no complaints for this months

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

**Abatement Technology-Table 4**

In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as

- ☒ Coal ash content (%) and burnt rate mass
- ☒ Fly : Coarse ash ratio of 80:20 - 80% of fly-ash mass obtained from burnt coal goes to ESP
- ☒ Measurement of dust emission by Dust Monitor over a period of time (monthly)

Operational Dust Removal Efficiency

$$\eta = (1 - (\text{Output}/\text{Input})) \times 100$$

$$\eta = 1 - \frac{(\text{Dust Emission From AQR Report Dust Monitor (tons)} \times 100)}{(\text{Coal Burnt (tons)} \times \% \text{ Ash Content} + 80\%)}$$

**Monitor Reliability-Table 5**

In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average. The **monitor reliability** refers to **data reliability** because the assumed value of 99.325% reliability is compared to the dust concentration signal. If the dust concentration signal is above 99.325% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g 24 hours

The formula is as follows:

$$= (1 - (\text{count hours above } 99.325\% / 24 \text{ hours})) \times 100$$

**Emissions Performance:**

- Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 4, 5 & 6 due to defective CEMS monitors and velocity correction factors were set M=1 and C=0
- Unit 5 Monitor still using the old monitor correlation. After new correlations are done, new correlation factors will be implemented and backfitted to the date of monitor installation.
- U1 and 2 monitors maxed out, meaning the emission were higher than what the monitor was correlated for. In which case we use surrogate values. This is attributed to abnormal plant conditions during the period.  
The following are the days when the monitor was maxing out: Unit 1 on the 13th, Unit 2 04th to 17th. Figures will be restated based on updated upset testing and surrogate value determination that Kendal will conduct
- Average emissions for unit 1 SOx and NOx from the 1st to the 9th and flow for the entire month were used from the QAL2 report, DCS module for those signals had failed and it has been replaced.
- Average emissions for unit 4 Pressure for the whole month were used from the QAL 2 report as the monitors were defective.
- Average emissions for unit 2 NOx from the 4th to 7th monitors were defective data was deleted and the tool will average it self.
- Average emissions for unit 3 CO2 and O2 were taken from QAL2 report as the CO2 and O2 as the monitors were not operating adequately.
  
- Unit 1
- Findings: The high emissions can be attributed to Dhp standing with all kg's closed due to compartments high levels full, hoopers blocked Precip12 hooper 6, Precip14 hooper 7, Precip 23 hooper 4,6 &, Precip 11 to 14, Pcp 11 hp 3, Pcp 13 hp 7, Pcp 23 hp 1&7, Pcp 12 all k/gates are shut
- Resolution: Plant repaired
  
- Unit 2
- Findings: The high emissions can be attributed to DHP off due to Pcp 11 to 14 DHP standing with all the knife gates closed
- Resolution: Plant repaired.
  
- Unit 3
- Findings: The high PM emissions can be attributed to
- Resolution: Plant repaired.
  
- Unit 4
- Findings: High PM emissions can be attributed to fuel oil support C and E elvation running with left hand site draught group and steam flow low, SO3 kept on tripping on convertor inlet temp high, Stream 2 bucket elevator that has blown the fusible plug and topping of oil fusible plug replacement .S1 bucket elevator coupling was leaking, no ashing on the DHP due to S1 not available. closed all knife gates because of the second collector failure to run, DHP precip conveyors 11 to 14 standing due to stream 1 second collector conveyor faulty. precip conveyors started 11,14, and 21-24 all knife gates closed. Precip conveyors 12 and 13 chocked, Ashing onto stream 1. Stream 2 B/E standing and 1st collector chocked, DHP standing and all knife gates cback-end temps are very low at 110 and 109 degrees hence the SO3 Plant is not injecting any sulphur. losed due to both S1 and S2 bucket elevators chocked.  
Resolution: Plant repaired.
  
- Unit 5
- Findings: High PM emissions can be attributed to Dhp standing due to issues at top bunker. Pcp 21 to 24 DHP standing the 1st collecting conv is suspected of a coupling fault, all knife gates are fully shut, PCP 21\_24 first collector stream 2 triped. DHP plant was standing with some ash backlogs due to compartment levels that were high and low flow on the SO3 plant. SO3 common plant is out for 48hrs steam leak repairs.
- Resolution: Plant repaired.
  
- Unit 6
- Findings: High PM emissions can be attributed to precip 11 to 14 standing, knife gates closed, compartments levels high, So3 off due to steam temp low, SO3 plant was still off due to mass flow meter that was blocked.
- Resolution: Plant repaired.