



Generation

Gert Sibande District Municipality
Corner of Joubert & Oosthuise Streets
Ermelo
2350

Attention:
Mr D Hlanyane

AND

Directorate: Air Quality Management Services
The Director:
Mr Vumile Senene
Department of Environmental Affairs
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Date: 2023/12/06

Enquiries: Nomasonto Nsibande

☎ +27 17 779 8995

☎ +27 86 507 5108

Enquiries: Thabo Montja

☎ +27 17 779 8834

Total number of pages:

10

Total number of annexes:

GROOTVLEI POWER STATION

Atmospheric Emission License GPS/0015/2015/F02



BOILER ENGINEERING MANAGER

2023/12/06

DATE



ENGINEERING MANAGER

06/12/2023

DATE



ENVIRONMENTAL MANAGER

09/12/2023

DATE

GROOTVLEI POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License GPS/0015/2015/F02



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Nov-2023
	Coal	Tons	650 000	92 880.0
	Fuel Oil	Tons	20 000	1024.38
Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate Nov-2023
	Energy	GWh	806.4	143.24
	Ash	Tons	300 000	25 449
	RE PM	kg/MWh	not specified	0.21

Note: Maximum energy production is calculated as: $(190\text{MW} \times 4 \text{ Units} + 180\text{MW} \times 2 \text{ Units}) \times 24\text{hrs} \times \text{Days in month} / 1000 = \text{GWh}$.

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	18-24	19.66
Sulphur Content	%	0.6 to < 1.2	0.71
Ash Content	%	27 to < 32	27.40

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO
North	100	3500	1100
South	50	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency
Unit 1	Fabric Filter Plant (FFP)	100.000%
Unit 2	Fabric Filter Plant (FFP)	100.000%
Unit 3	Fabric Filter Plant (FFP)	100.000%
Unit 4	Fabric Filter Plant (FFP)	100.000%
Unit 5	Fabric Filter Plant (FFP)	100.000%
Unit 6	Fabric Filter Plant (FFP)	100.000%

Type text here

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
North	100.0	0.0	0.0	0.0
South				

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of November-2023

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	0.00	0.0	0.0
Unit 2	13.89	467.2	199.6
Unit 3	16.39	679.6	290.4
Unit 4	0.00	0.0	0.0
Unit 5	0.00	0.0	0.0
Unit 6	0.00	0.0	0.0
SUM	30.29	1 146.8	490.1

Table 6.2: Operating days in compliance to PM AEL Limit - November 2023

Associated Unit/Stack	Normal	Grace	Section 30	Total Exceedance	Average PM (mg/Nm ³)
North	29	0	0	0	43.2
South	0	0	0	0	
SUM	29	0	0	0	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - November 2023





Associated Unit/Stack	Normal	Grace	Section 30	Total Exceedance	Average SO ₂ (mg/Nm ³)
North	30	0	0	0	1 578.9
South	0	0	0	0	
SUM	30	0	0	0	



Table 6.4: Operating days in compliance to NO_x AEL Limit - November 2023



Associated Unit/Stack	Normal	Grace	Section 30	Total Exceedance	Average NO _x (mg/Nm ³)
North	30	0	0	0	674.7
South	0	0	0	0	
SUM	30	0	0	0	



Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		







7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of November-2023

North Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 2		Unit 3		Unit 3		Unit 3	
Breaker Open (BO)	3:50 pm	2023/11/14	11:40 pm	2023/11/06	8:40 pm	2023/11/17	5:55 pm	2023/11/24
Draught Group (DG) Shut Down (SD)	11:25 am	2023/11/15	11:05 am	2023/11/07	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	00:19:35	DD:HH:MM	00:11:25	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM
Fires in time			9:00 pm	2023/11/12				
Synch. to Grid (or BC)			5:15 am	2023/11/13				
Fires in to BC (duration)		DD:HH:MM	00:08:15	DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)			not > limit	not > limit				
Emissions below limit from BC (duration)		DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM

North Stack ...Cont.	Event 5		Event 6		Event 7		Event 8	
Unit No.	Unit 3		no event		no event		no event	
Breaker Open (BO)	6:10 am	2023/11/29						
Draught Group (DG) Shut Down (SD)	8:05 am	2023/11/29						
BO to DG SD (duration)	00:01:55	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	12:00 pm	2023/11/29						
Synch. to Grid (or BC)	5:20 pm	2023/11/29						
Fires in to BC (duration)	00:05:20	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit						
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

South Stack	<i>Event 1</i>		<i>Event 2</i>		<i>Event 3</i>		<i>Event 4</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

South Stack ...Cont.	<i>Event 5</i>		<i>Event 6</i>		<i>Event 7</i>		<i>Event 8</i>	
Unit No.	<i>no event</i>		<i>no event</i>		<i>no event</i>		<i>no event</i>	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of November-2023 in mg/Nm³

[[Include reference to once off test showing typical emissions rates during fires in and SD]

ADDENDUM TO MONTHLY EMISSIONS REPORT

8 EMERGENCY GENERATION

Emergency Generation *[This is only required for stations that are requested to report on this information]*

Table 8. Emergency Generation per unit for the month of November-2023

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control						
Emergency Hours declared including hours after stand down						
Hours over the Limit during Emergency Generation						

9 COMPLAINTS REGISTER

Table 9. Complaints for the month of November-2023

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date measure will be implemented
<i>(Insert name of affected person/source)</i>	<i>(Insert root cause for incident)</i>	<i>(Insert emissions associated with incident)</i>	<i>(Insert dispersion model information where applicable)</i>	<i>(Insert mitigation measures taken)</i>	<i>(Insert date of implementation of mitigation method)</i>

10 S30 INCIDENT OR LEGAL CONTRAVENTION REGISTER


To be completed in the case of a S30 Incident or a legal contravention:


Unit no	Incident Start Date	Incident End Date	Incident Cause	Remedial action	Date S30 Initial notification sent	Date S30 Investigation report sent	Date DEA Acknowledgment	Date DEA Acceptable	Comments / Reference No.

11 General

South Stack off. The gas analyzer is currently operational, but we are waiting for the availability of 2 units to conduct parallel tests. In the meantime, surrogate values were employed for reporting gaseous results.

 2023/12/07
Environmental Department Date

 2023/12/06
Boiler Engineering Date

 2023/12/11
General Manager Date

Compiled by: Boiler Engineering Department FFP System Engineer

For: Department of Environmental Affairs and Tol Chief Air Pollution Control Officer

Copies: Eskom Environmental Management D Herbst
K Langerman

Group Technology Engineering R Rampiar
E. Patel

Grootvlie Power Station: Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager
System Engineer
Environmental Officer
Performance and Test
Production Manager