

Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022		
Review Date	July2024		

Date: 2023/07/31

Tel: 014 762 6820

Enquiries: MF Dikgale

Stanley Koenaite

Waterberg District Municipality Private Bag X1018 Modimole 0510

skoenaite@waterberg.gov.za

Ref: H16/1/13-AEL/M1/R1 - July2023

Dear Mr Koenaite

# MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF JULY 2023

This document serves as the monthly emissions report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), H16/1/13-AEL/M1/R1. This Report supersedes the report that was sent to the Department in August 2023, the report was revised due to findings from the Eskom Data Integrity review Audit of FY2023.

This report reflects Unit 1, 2, 3, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of July 2023 only.

#### Raw Materials and Products

TABLE 1: QUANTITY OF RAW MATERIALS AND PRODUCTS CONSUMPTION IN JULY 2023

Raw Materials and Products	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption – July2023
used	Coal	Tons/month	1 875 000	1063907
0.000	Fuel Oil	Tons/month	20 000	1110
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of July2023
	Energy	GWh	3 571.2	2298.99
	Ash Emitted	Tons/month	not specified	182.20

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022		
Review Date	July2024		

	R	eportal	ole Houi	rs of O	peratio	n	Coal	Production rate (MW)					
Date	U1	U2	U3	U4	U5	U6	usage	U1	U2	U3	U4	U5	U6
01-July	24.0	24.0	24.0	0.0	24.0	24.0	35084	742	731	673	off	600	736
02-July	24.0	24.0	24.0	0.0	24.0	24.0	34635	717	710	645	Off	600	705
03-July	24.0	24.0	24.0	0.0	24.0	24.0	35012	740	714	624	Off	600	705
04-July	24.0	24.0	24.0	0.0	24.0	24.0	35235	741	698	681	Off	600	705
05-July	24.0	24.0	24.0	0.0	24.0	24.0	34722	700	713	673	Off	600	727
06-July	24.0	24.0	24.0	0.0	24.0	24.0	34731	697	719	673	Off	570	712
07-July	24.0	24.0	0.7	0.0	24.0	24.0	35416	726	714	615	Off	599	690
08-July	24.0	24.0	21.0	0.0	24.0	24.0	35661	729	720	676	Off	600	709
09-July	6.7	24.0	24.0	0.0	24.0	24.0	31514	672	698	651	Off	666	690
10-July	0.0	24.0	24.0	0.0	24.0	24.0	33939	629	729	673	Off	629	705
11-July	11.0	1.2	24.0	0.0	24.0	24.0	35834	711	703	675	Off	704	724
12-July	24.0	20.3	24.0	0.0	24.0	24.0	36393	699	746	676	Off	705	709
13-July	24.0	24.0	24.0	0.0	24.0	24.0	35269	696	674	663	Off	689	692
14-July	2.3	24.0	24.0	0.0	24.0	24.0	32245	665	716	663	off	587	712
15-July	14.3	24.0	24.0	0.0	24.0	24.0	34336	697	701	619	Off	600	702
16-July	24.0	24.0	24.0	0.0	24.0	24.0	33439	682	691	622	Off	600	676
17-July	24.0	24.0	24.0	0.0	24.0	24.0	33813	689	668	645	Off	616	660
18-July	24.0	24.0	24.0	0.0	24.0	24.0	34456	665	696	653	Off	600	694
19-July	24.0	24.0	24.0	0.0	24.0	24.0	34333	646	712	657	Off	593	723
20-July	24.0	24.0	24.0	0.0	24.0	24.0	35028	725	715	662	Off	585	707
21-July	24.0	24.0	24.0	0.0	24.0	24.0	33436	650	695	647	Off	585	664
22-July	24.0	24.0	24.0	0.0	24.0	24.0	34311	674	709	648	Off	594	717
23-July	24.0	24.0	24.0	0.0	24.0	24.0	33945	663	695	646	Off	576	698
24-July	24.0	24.0	24.0	0.0	24.0	24.0	34547	692	708	642	Off	627	673
25-July	24.0	24.0	24.0	0.0	24.0	24.0	35299	723	721	641	Off	619	677
26-July	24.0	24.0	24.0	0.0	24.0	24.0	36270	735	717	651	Off	640	708
27-July	22.5	24.0	24.0	0.0	24.0	24.0	35088	722	726	648	Off	700	709
28-July	0.0	24.0	24.0	0.0	24.0	24.0	27903		732	651	Off	653	688
29-July	0.0	24.0	24.0	0.0	24.0	24.0	34682	632	703	648	Off	731	684
30-July	22.8	11.3	24.0	0.0	24.0	24.0	31944	638	527	615	Off	695	651
31-July	24.0	11.3	24.0	0.0	24.0	24.0	35387	684	700	621	Off	739	694

### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022		
Review Date	July2024		

NB: Reportable hours less than 24 highlighted in pink; Unit OFF highlighted in Red

# 2. Abatement Technology

Table 2: Abatement Equipment Control Technology efficiency for month of July2023

Associated Unit/Stack	Technology Type	Efficiency	FFP Utilization
Unit 1	Fabric Filter Plant (FFP)	99.929%	100%
Unit 2	Fabric Filter Plant (FFP)	99.917%	100%
Unit 3	Fabric Filter Plant (FFP)	99.907%	100%
Unit 4	Fabric Filter Plant (FFP)	off	off
Unit 5	Fabric Filter Plant (FFP)	99.945%	100%
Unit 6	Fabric Filter Plant (FFP)	99.976%	100%

Note: FFP does not have bypass mode operation, hence plant 100% Utilised.

# 3. Energy Source Characteristics

TABLE 3: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF JULY 2023

Characteristic	Stipulated Range (% by weight on a dry basis)	Monthly Average Content (% by weight on a dry basis)	
	Coal		
Sulphur Content	1.3 - 2.2	1.23	
Ash Content	35 - 39	33.13	

TABLE 4: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF JULY 2023

Characteristic	Stipulated Range (%)	Monthly Average Content (%)		
	Oil			
Sulphur Content	0.5 - 3.5	2.3		
Ash Content	0.02 - 0.1	0.03		

# 4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022		
Review Date	July2024		

 $SO_2$  Monthly = 3500 mg/Nm<sup>3</sup>

Dust Daily= 50 mg/Nm<sup>3</sup>

NO<sub>2</sub> Daily= 750 mg/Nm<sup>3</sup>


#### **CONTROLLED DISCLOSURE**


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.





Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022	l	
Review Date	July2024		

## 4.1 PM Daily Averages















Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022		
Review Date	July2024		






## 4.2 SOx Daily Averages










Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022	I	
Review Date	July2024		













Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022	l	
Review Date	July2024		


# 4.3 NOx Daily Averages











Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022		
Review Date	July2024		











#### Table 6: Monthly tonnages for the month of July 2023

Associated Unit/Stack	РМ	SO <sub>2</sub>	NO <sub>2</sub>
Unit 1	39.4	3 921.8	763.3
Unit 2	49.6	5 581.0	872.5
Unit 3	51.9	4 022.6	532.5
Unit 4	off	off	off
Unit 5	27.7	5 691.4	789.9
Unit 6	13.7	4 139.6	709.9
SUM (Tons)	182.2	23 356.4	3 668.0

#### **TABLE 7: MONTHLY AVERAGES FOR THE MONTH OF JULY 2023**

Associated Unit/Stack	Average PM (mg/Nm³)	Average SOx (mg/Nm³)	Average NOx (mg/Nm³)
Unit 1	27.5	2 472.7	485.4
Unit 2	22.0	2 262.2	353.6
Unit 3	29.0	2 202.1	291.5
Unit 4	off	off	off
Unit 5	10.5	2 167.0	301.0
Unit 6	6.6	1 989.2	341.3

# 5. Continuous Emission Monitoring Systems (CEMS)

• Unit 1, 2, 3, 5 and 6 Continuous Emission Monitoring Systems were always in operation when the unit was on load.

TABLE 8: PERIODS DURING WHICH CEMS WAS INOPERATIVE

Date	CEMS status	Comments
N/A	N/A	N/A

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.




TABLE 9: CEMS MONITOR RELIABILITY PERCENTAGE (%)

Associated Unit/Stack	РМ	SO₂	NO <sub>2</sub>	<b>O</b> 2
Unit 1	99.7	99.3	99.2	98.4
Unit 2	99.5	99.6	99.6	99.6
Unit 3	99.5	0	0	0
Unit 4	Off	off	off	off
Unit 5	99.2	99.5	99.6	99.5
Unit 6	99.2	99.5	99.6	99.5

Note: SO<sub>2</sub>, O<sub>2</sub> and NO was Changed to a Unity Factor (1) for accurate reporting, there was a step change in the performance of the Unit 3 gas Monitor.

# **6.**CEMS Calibration certificates and equipment used for calibration

A service provider was appointed to calibrate CEMS equipment at Medupi Power Station, calibration certificates to be made available upon request. The service appointed for the CEMS calibration is in a process of obtaining SANAS accreditation. Verification of the CEMS after calibration is conducted internally by Eskom.

# 7. Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report for July2023 was e-mailed to the Licensing Authority.

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
<b>⊗</b> Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	July2022		
		Review Date	July2024		

# **8.** Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

TABLE 10: TOTAL VOLATILE ORGANIC COMPOUND (TVOC) FOR JULY 2023

CALCULATION	OF EMISSIONS OF TOTAL VOLATILE COMPO	UNDS FROM FUEL OIL ST	ORAGE TANKS
Date:	Monday, 31 July 2023	_	
Station:	Medupi Power Station		
Province:	Limpopo Province		
Tank no.	1-2		
Description:	Outdoor fuel oil storage tank		
Tank Type:	Vertical fixed roof (vented to atmosphere)		
Material stored:	Fuel Oil 150		
	Choose from a dropdown menu in The total VOC emissions for the month IMPORTANT: Do not change <u>any</u> other cells wit	are in the <u>red cells</u>	
MONTH:	July		
GENERAL INFO	RMATION:	Data	Unit
Total number of	fuel oil tanks:	2	NA
Height of tank:*		14.2	m
Diameter of tank	3	12	m
Net fuel oil throu	ghput for the month:	<u>1110</u>	tons/month
Molecular weigh	t of the fuel oil:	166.00	Lb/lb-mole
METEROLOGIC	AL DATA FOR THE MONTH	Data	Unit
Daily average an	nbient temperature	17.66	°C
Daily maximum a	ambient temperature	25.87	°C
Daily minimum a	mbient temperature	10.47	°C
Daily ambient ter	mperature range	15.40	°C
Daily total insola	tion factor	3.47	kWh/m²/day
Tank paint coloι	ır	Aluminum/Specular	NA
Tank paint solar	absorbtance	0.39	NA
FINAL OUTPUT		Result	Unit
Breathing losses	S:	0.69	kg/month
Working losses:		0.03	kg/month
			kg/month

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
<b>⊗</b> Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	July2022	•	
		Review Date	July2024		

**9.** Air quality improvements initiatives and public education and awareness campaigns

No awareness campaigns for this month.

# 10. Complaints Register

TABLE 5: COMPLAINTS FOR THE MONTH OF JULY 2023

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Results of investigation	Action taken to resolve the complaint
N/A	No complaints received	N/A	N/A	N/A	N/A

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



GENERAL MANAGER: MEDUPI POWER STATION

Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	July2022	•	
Review Date	July2024		

Compiled by:	Environmental Officer
Verified by:	Malose Langa Date: _2023/12/20 System Engineer Boiler
Verified by:	Nontuthuko Mpangase Date: 2023/12/20 System Engineer C&I
Supported by:	Mokgadi Dikgale Date: 2023 12 21 Environmental Manager
Supported by:	Jabulani Mkhatshwa  Engineering Group Wahager
I Zweli Witbooi, declar correct.	res that the information provided in this report is accurate and
Yours sincerely	
10 Kappa	- 2023/12/2/

#### **CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.