

| Template Identifier | 240-43921804 | Rev | 6 |
|------------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective D | ate May 2022 | | |
| Review Dat | te May 2024 | | |

Date: 2023/05/31

Tel: 014 762 6820

Enquiries: MF Dikgale

Stanley Koenaite

Waterberg District Municipality Private Bag X1018 Modimolle 0510

skoenaite@waterberg.gov.za

Ref: H16/1/13-AEL/M1/R1 – May 2023

Dear Mr Koenaite

MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF MAY 2023

This document serves as the monthly emissions report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), H16/1/13-AEL/M1/R1. This Report supersedes the report that was sent to the Department in June 2023, the report was revised due to findings from the Eskom Data Integrity review Audit of FY2023.

This report reflects Unit 1, 2, 3, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of May 2023 only.

1. Raw Materials and Products

TABLE 1: QUANTITY OF RAW MATERIALS AND PRODUCTS CONSUMPTION IN MAY 2023

| Raw Materials and Products | Raw Material Type | Unit | Maximum Permitted Consumption/ Rate (Quantity) | Consumption – May 2023 |
|-------------------------------------|------------------------------|------------|--|---|
| used | Coal | Tons/month | 1 875 000 | 1028997 |
| | Fuel Oil | Tons/month | 20 000 | 1556 |
| | | | | |
| Production Rates | Product/ By- Product Name | Unit | Maximum Production Capacity Permitted (Quantity) | Production Rate in Month of May 2023 |
| | Energy | GWh | 3 571.2 | 2151.15 |
| | Ash Emitted | Tons/month | not specified | 275.9 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



| Template Identifier | 240-43921804 | Rev | 6 |
|------------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | | |
| Review Date | May 2024 | | |

| | F | Reportal | ole hour | s of O | peratio | n | Coal | Production rate (MW) | | | | | |
|--------|------|----------|----------|--------|---------|------|-------|----------------------|-----|-----|-----|-----|-----|
| Date | U1 | U2 | U3 | U4 | U5 | U6 | usage | U1 | U2 | U3 | U4 | U5 | U6 |
| 01-May | 11.3 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 38450 | 701 | 730 | 743 | Off | 634 | 735 |
| 02-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 38409 | 742 | 719 | 750 | Off | 651 | 740 |
| 03-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 38519 | 734 | 727 | 739 | Off | 667 | 704 |
| 04-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 38832 | 759 | 769 | 750 | Off | 661 | 731 |
| 05-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 38496 | 716 | 772 | 750 | Off | 679 | 716 |
| 06-May | 24.0 | 2.2 | 13.6 | 0.0 | 24.0 | 1.8 | 25106 | 737 | 651 | 750 | Off | 659 | 528 |
| 07-May | 9.6 | 14.2 | 0.0 | 0.0 | 24.0 | 9.1 | 26626 | 636 | 749 | 117 | Off | 657 | 720 |
| 08-May | 0.0 | 24.0 | 17.3 | 0.0 | 24.0 | 5.2 | 28442 | Off | 783 | 573 | Off | 672 | 669 |
| 09-May | 0.0 | 24.0 | 24.0 | 0.0 | 24.0 | 16.3 | 30944 | Off | 785 | 711 | Off | 672 | 761 |
| 10-May | 0.0 | 24.0 | 24.0 | 0.0 | 24.0 | 10.8 | 29121 | Off | 758 | 697 | Off | 661 | 720 |
| 11-May | 0.0 | 9.0 | 24.0 | 0.0 | 24.0 | 0.0 | 23225 | Off | 683 | 731 | Off | 661 | 620 |
| 12-May | 0.0 | 0.0 | 24.0 | 0.0 | 24.0 | 7.1 | 21942 | Off | Off | 709 | Off | 652 | 696 |
| 13-May | 0.0 | 0.0 | 24.0 | 0.0 | 24.0 | 0.0 | 21495 | Off | Off | 706 | Off | 666 | 694 |
| 14-May | 0.0 | 0.0 | 24.0 | 0.0 | 24.0 | 20.3 | 21696 | Off | Off | 692 | Off | 632 | 700 |
| 15-May | 0.0 | 0.0 | 24.0 | 0.0 | 24.0 | 24.0 | 24570 | 523 | Off | 732 | Off | 554 | 704 |
| 16-May | 14.1 | 0.0 | 24.0 | 0.0 | 24.0 | 24.0 | 34457 | 701 | 545 | 671 | Off | 655 | 751 |
| 17-May | 24.0 | 19.4 | 24.0 | 0.0 | 24.0 | 24.0 | 36854 | 723 | 687 | 673 | Off | 681 | 736 |
| 18-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 35851 | 720 | 699 | 636 | Off | 661 | 686 |
| 19-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 37172 | 727 | 718 | 601 | Off | 650 | 780 |
| 20-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 36017 | 675 | 714 | 561 | Off | 648 | 777 |
| 21-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 37114 | 660 | 696 | 667 | Off | 755 | 750 |
| 22-May | 24.0 | 24.0 | 12.7 | 0.0 | 24.0 | 17.2 | 33550 | 628 | 727 | 652 | Off | 649 | 739 |
| 23-May | 24.0 | 24.0 | 8.4 | 0.0 | 24.0 | 0.0 | 34791 | 678 | 721 | 690 | Off | 663 | 652 |
| 24-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 17.9 | 37046 | 692 | 696 | 700 | Off | 676 | 740 |
| 25-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 37086 | 657 | 672 | 690 | Off | 665 | 730 |
| 26-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 37175 | 639 | 709 | 685 | Off | 667 | 731 |
| 27-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 38072 | 655 | 707 | 700 | Off | 652 | 740 |
| 28-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 36978 | 653 | 725 | 693 | Off | 681 | 752 |
| 29-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 37322 | 662 | 700 | 685 | Off | 666 | 754 |
| 30-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 37551 | 664 | 705 | 700 | Off | 669 | 754 |
| 31-May | 24.0 | 24.0 | 24.0 | 0.0 | 24.0 | 24.0 | 36088 | 610 | 717 | 696 | Off | 650 | 737 |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



| Template Identifier | 240-43921804 | Rev | 6 |
|------------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | | |
| Review Date | May 2024 | | |

NB: Reportable hours less than 24 highlighted in pink; Unit OFF highlighted in Red

2. Abatement Technology

Table 2: Abatement Equipment Control Technology efficiency for month of May 2023

| Associated Unit/Stack | Technology Type | Efficiency | FFP Utilization |
|-----------------------|---------------------------|------------|-----------------|
| Unit 1 | Fabric Filter Plant (FFP) | 99.907% | 100% |
| Unit 2 | Fabric Filter Plant (FFP) | 99.896% | 100% |
| Unit 3 | Fabric Filter Plant (FFP) | 99.916% | 100% |
| Unit 4 | Fabric Filter Plant (FFP) | off | Off |
| Unit 5 | Fabric Filter Plant (FFP) | 99.826% | 100% |
| Unit 6 | Fabric Filter Plant (FFP) | 99.980% | 100% |

Note: FFP does not have bypass mode operation, hence plant 100% Utilised.

3. Energy Source Characteristics

TABLE 3: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF MAY 2023

| Characteristic | Stipulated Range Monthly Average Content (% by weight on a dry basis) (% by weight on a dry basis) | | |
|-----------------|--|-------|--|
| | Coal | | |
| Sulphur Content | 1.3 - 2.2 | 1.45 | |
| Ash Content | 35 - 39 | 35.48 | |

TABLE 4: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF MAY 2023

| Characteristic | Stipulated Range (%) | Monthly Average Content (%) | |
|-----------------|----------------------|-----------------------------|--|
| | Oil | | |
| Sulphur Content | 0.5 - 3.5 | 2.25 | |
| Ash Content | 0.02 - 0.1 | 0.035 | |

4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



| 1 | 1 | | |
|------------------------|--------------|-----|---|
| Template Identifier | 240-43921804 | Rev | 6 |
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | | |
| Review Date | May 2024 | | |

 SO_2 Monthly = 3500 mg/Nm³

Dust Daily= 50 mg/Nm³

NO₂ Daily= 750 mg/Nm³


CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.





| Template Identifier | 240-43921804 | Rev | 6 |
|---------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | | |
| Review Date | May 2024 | | |

4.1 PM Daily Averages















| Template Identifier | 240-43921804 | Rev | 6 |
|---------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | l . | |
| Review Date | May 2024 | | |






4.2 SOx Daily Averages










| Template Identifier | 240-43921804 | Rev | 6 |
|---------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | l . | |
| Review Date | May 2024 | | |















| Template Identifier | 240-43921804 | Rev | 6 |
|---------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | | |
| Review Date | May 2024 | | |

4.3 NOx Daily Averages













| Template Identifier | 240-43921804 | Rev | 6 |
|---------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | I | |
| Review Date | May 2024 | | |








TABLE 6: MONTHLY TONNAGES FOR THE MONTH OF MAY 2023

| Associated Unit/Stack | РМ | SO ₂ | NO ₂ |
|-----------------------|-------|-----------------|-----------------|
| Unit 1 | 50.3 | 4 537.0 | 720.4 |
| Unit 2 | 58.9 | 6 006.1 | 763.9 |
| Unit 3 | 57.9 | 5 103.5 | 675.8 |
| Unit 4 | off | off | off |
| Unit 5 | 97.2 | 7 098.3 | 857.2 |
| Unit 6 | 11.5 | 4 837.2 | 599.6 |
| SUM (Tons) | 275.9 | 27 582.1 | 3 617.0 |

TABLE 7: MONTHLY AVERAGES FOR THE MONTH OF MAY 2023

| Associated Unit/Stack | Average PM (mg/Nm³) | Average SOx (mg/Nm³) | Average NOx (mg/Nm³) |
|-----------------------|---------------------|-------------------------|-------------------------|
| Unit 1 | 33.4 | 2 822.0 | 449.7 |
| Unit 2 | 28.6 | 2 753.3 | 350.2 |
| Unit 3 | 30.9 | 2 590.3 | 344.4 |
| Unit 4 | off | off | Off |
| Unit 5 | 37.8 | 2 762.2 | 333.5 |
| Unit 6 | 6.9 | 2 406.4 | 297.4 |

5. Continuous Emission Monitoring Systems (CEMS)


• Unit 1, 2, 3, 5 and 6 Continuous Emission Monitoring Systems were always in operation when the unit was on load.

TABLE 8: PERIODS DURING WHICH CEMS WAS INOPERATIVE

| Date | CEMS status | Comments |
|------|-------------|----------|
| N/A | N/A | N/A |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



| Template Identifier | 240-43921804 | Rev | 6 |
|------------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | | |
| Review Date | May 2024 | | |

TABLE 9: CEMS MONITOR RELIABILITY PERCENTAGE (%)

| Associated Unit/Stack | PM | SO₂ | NO ₂ | O 2 |
|--------------------------|-------|-------|-----------------|------------|
| Unit 1 | 98.7 | 99.8 | 99.8 | 99.2 |
| Unit 2 | 98.9 | 99.7 | 99.7 | 99.7 |
| Unit 3 | 98.2 | 0 | 0 | 0 |
| Unit 4 | Off | off | off | off |
| Unit 5 | 99.5 | 100.0 | 100.0 | 100.0 |
| Unit 6 | 100.0 | 99.9 | 99.9 | 99.8 |

Note: SO_2 , O_2 and NO was Changed to a Unity Factor (1) for accurate reporting, there was a step change in the performance of the Unit 3 gas Monitor

6.CEMS Calibration certificates and equipment used for calibration.

A service provider was appointed to calibrate CEMS equipment at Medupi Power Station, calibration certificates to be made available upon request. The service appointed for the CEMS calibration is in a process of obtaining SANAS accreditation. Verification of the CEMS after calibration is conducted internally by Eskom.

7. Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report for May 2023 was e-mailed to the Licensing Authority.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

| | | Template Identifier | 240-43921804 | Rev | 6 |
|----------------|--|------------------------|--------------|-----|---|
| ⊗ Eskom | Medupi Power Station Monthly Emissions Report | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | May 2022 | | |
| | | Review Date | May 2024 | | |

8. Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

TABLE 10: TOTAL VOLATILE ORGANIC COMPOUND (TVOC) FOR MAY 2023

| CALCULATION | OF EMISSIONS OF TOTAL VOLATILE COMPOU | NDS FROM FUEL OIL ST | ORAGE TANKS | |
|---|--|---------------------------|-----------------|--|
| | | | | |
| Date: | Wednesday, 31 May 2023 | | | |
| Station: | Medupi Power Station | | | |
| Province: | Limpopo Province | | | |
| Tank no. | 1-2 | | | |
| Description: | Outdoor fuel oil storage tank | | | |
| Tank Type: | Vertical fixed roof (vented to atmosphere) | | | |
| Material stored: | Fuel Oil 150 | | | |
| | MONTHLY INPUT DATA FOR TH | E STATION | | |
| | Please only insert relevant monthly data inputs | into the blue cells below | | |
| | Choose from a dropdown menu in the | ne <u>green cells</u> | | |
| The total VOC emissions for the month are in the <u>red cells</u> | | | | |
| IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE | | | | |
| MONTH: | May | | | |
| GENERAL INFORMATION: Data Unit | | | | |
| Total number of | fuel oil tanks: | 2 | NA | |
| Height of tank:* | | 14.2 | m | |
| Diameter of tank | : | 12 | m | |
| Net fuel oil throu | ghput for the month: | <u>1556</u> | tons/month | |
| Molecular weigh | t of the fuel oil: | 166.00 | Lb/lb-mole | |
| METEROLOGICA | AL DATA FOR THE MONTH | Data | Unit | |
| Daily average an | bient temperature | 19.51 | °C | |
| Daily maximum a | ambient temperature | 28.42 | °C | |
| Daily minimum a | mbient temperature | 12.06 | °C | |
| Daily ambient ter | nperature range | 15.04 | °C | |
| Daily total insola | tion factor | 3.91 | kWh/m²/day | |
| Tank paint colou | | Aluminum/Specular | NA | |
| Tank paint solar | absorbtance | 0.39 | NA | |
| FINAL OUTPUT: | | Result | Unit | |
| Breathing losses | »: | 0.70 | kg/month | |
| Working losses: | | 0.04 kg/month | | |
| TOTAL LOSSES (Total TVOC Emissions for the month): 0.74 kg/month | | | | |
| • | formed on this spreadsheet are taken from the USEF ary 1996. This spreadsheet is derived from material neers, 85-93 Chevy Chase Street, Jamaica, NY 114: | s provided by Jimmy Peres | ss, PE, Tritech | |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

| | | Template Identifier | 240-43921804 | Rev | 6 |
|-------|--|------------------------|--------------|-----|---|
| €Skom | Medupi Power Station Monthly Emissions Report | Document Identifier | 240-88543153 | Rev | 2 |
| | | Effective Date | May 2022 | · | |
| | | Review Date | May 2024 | | |

9. Air quality improvements initiatives and public education and awareness campaigns

No awareness campaigns for this month.

10. Complaints Register

TABLE 5: COMPLAINTS FOR THE MONTH OF MAY 2023

| Source Code/ Name | Air pollution complaints received | Calculation of Impacts/ emissions associated with the incident | Date of complaint and date of response by the license holder | Results of investigation | Action taken to resolve the complaint |
|----------------------|-----------------------------------|--|--|--------------------------|---------------------------------------|
| N/A | No complaints received | N/A | N/A | N/A | N/A |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



GENERAL MANAGER: MEDUPI POWER STATION

| Template Identifier | 240-43921804 | Rev | 6 |
|------------------------|--------------|-----|---|
| Document Identifier | 240-88543153 | Rev | 2 |
| Effective Date | May 2022 | | |
| Review Date | May 2024 | | |

| | Compiled by: | Lutendo Murovhi Nemutambatti. Date: 18/12/2023 Environmental Officer |
|---|-----------------|---|
| | Verified by: | Malose Langa Date: 2023/12/20 System Engineer Boiler |
| | Verified by: | Nontuthuko Mpangase Date: 2023/12/20 System Engineer C&I |
| | Supported by: | Mokgadi Dikgale Date: 2023 [2] Environmental Manager |
| | Supported by: | Jabulani Mkhatshwa Date: 2023 z z Engineering Group Manager |
| I Zweli Witbooi, declares that the information provided in this report is accurate and correct. | | |
| | Yours sincerely | |
| | 66 | 2022/12/2/ |

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.