	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6	
Eskom		Document Identifier	240-88543153	Rev	2	
		Effective Date	September2022			
		Review Date	September2024			

Stanley Koenaite

Waterberg District Municipality Private Bag X1018 Modimole 0510 Date: 2023/10/31 Enquiries: MF Dikgale Tel: 014 762 6820

skoenaite@waterberg.gov.za

Ref: H16/1/13-AEL/M1/R1 - October2023

Dear Mr Koenaite

MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF OCTOBER 2023

This document serves as the monthly emissions report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), H16/1/13-AEL/M1/R1.

This report reflects Unit 1, 2, 3, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of October 2023 only.

1. Raw Materials and Products

TABLE 1: QUANTITY OF RAW MATERIALS AND PRODUCTS CONSUMPTION IN OCTOBER 2023

Raw Materials and Products	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption – October2023
used	Coal	Tons/month	1 875 000	1 077 573.0
	Fuel Oil	Tons/month	20 000	1331
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of October 2023
	Energy	GWh	3 571.2	2292.41
	Ash Emitted	Tons/month	not specified	235.11

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

() Eskom		Template Identifier	240-43921804	Rev	6	
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2	
		Effective Date	September2022			
		Review Date	September2024			

		Daily	Hours o	of Ope	ration		Coal		Pro	ductior	n rate (N	IW)	
Date	U1	U2	U3	U4	U5	U6	usage	U1	U2	U3	U4	U5	U6
01-Oct	24.0	24.0	24.0	0.0	24.0	24.0	35020	694	600	616	Off	635	682
02-Oct	24.0	24.0	24.0	0.0	24.0	5.6	29057	669	596	638	Off	649	567
03-Oct	24.0	24.0	24.0	0.0	24.0	0.0	28667	739	600	660	Off	663	
04-Oct	24.0	24.0	24.0	0.0	24.0	0.0	30326	719	647	629	Off	729	
05-Oct	24.0	24.0	24.0	0.0	24.0	5.8	31806	719	707	627	Off	734	311
06-Oct	24.0	24.0	24.0	0.0	24.0	24.0	37187	694	731	631	Off	743	665
07-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36956	707	718	628	Off	635	682
08-Oct	24.0	24.0	21.8	0.0	24.0	24.0	33345	668	658	574	Off	554	752
09-Oct	24.0	24.0	24.0	0.0	24.0	24.0	33584	716	702	639	Off	482	746
10-Oct	24.0	24.0	24.0	0.0	24.0	24.0	34849	714	701	662	Off	552	746
11-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36008	729	691	663	Off	706	761
12-Oct	24.0	24.0	24.0	0.0	24.0	24.0	35860	715	716	607	Off	663	753
13-Oct	24.0	24.0	24.0	0.0	24.0	24.0	35419	726	698	653	Off	648	707
14-Oct	24.0	24.0	24.0	0.0	24.0	24.0	35017	641	686	623	Off	696	673
15-Oct	24.0	24.0	24.0	0.0	24.0	24.0	34362	709	674	639	Off	644	712
16-Oct	21.1	24.0	24.0	0.0	24.0	24.0	34980	660	709	673	Off	626	712
17-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36806	726	713	659	Off	715	758
18-Oct	24.0	24.0	24.0	0.0	24.0	24.0	37080	735	689	665	Off	715	758
19-Oct	24.0	24.0	24.0	0.0	24.0	24.0	35611	711	682	616	Off	710	739
20-Oct	24.0	24.0	24.0	0.0	24.0	24.0	33423	740	679	589	Off	637	686
21-Oct	24.0	24.0	24.0	0.0	24.0	24.0	32545	643	670	571	Off	584	662
22-Oct	24.0	22.6	24.0	0.0	24.0	24.0	30450	563	620	543	Off	555	564
23-Oct	24.0	19.4	24.0	0.0	24.0	24.0	34035	655	579	640	Off	731	731
24-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36574	723	634	643	Off	729	738
25-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36395	679	756	679	Off	717	704
26-Oct	24.0	24.0	24.0	0.0	24.0	24.0	38207	697	719	645	Off	733	778
27-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36756	694	701	616	Off	731	778
28-Oct	24.0	24.0	24.0	0.0	24.0	24.0	37196	634	727	575	Off	706	782
29-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36541	640	726	605	Off	715	787
30-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36528	724	714	648	Off	687	765
31-Oct	24.0	24.0	24.0	0.0	24.0	24.0	36983	701	670	659		668	790

NB: Operating hours less than 24 highlighted in pink; Unit OFF highlighted in Red.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

	I Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6	
Eskom		Document Identifier	240-88543153	Rev	2	
		Effective Date	September2022			
		Review Date	September2024			

2. Abatement Technology

Table 2: Abatement Equipment Control Technology efficiency for month of October2023

Associated Unit/Stack	Technology Type	Efficiency	FFP Utilization
Unit 1	Fabric Filter Plant (FFP)	99.913%	100%
Unit 2	Fabric Filter Plant (FFP)	99.865%	100%
Unit 3	Fabric Filter Plant (FFP)	99.909%	100%
Unit 4	Fabric Filter Plant (FFP)	Off	off
Unit 5	Fabric Filter Plant (FFP)	99.939%	100%
Unit 6	Fabric Filter Plant (FFP)	99.966%	100%

Note: FFP does not have bypass mode operation, hence plant 100% Utilised.

3. Energy Source Characteristics

TABLE 3: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF OCTOBER 2023

Characteristic	Stipulated RangeMonthly Average Content(% by weight on a dry basis)(% by weight on a dry basis)				
	Coal				
Sulphur Content	1.3 - 2.2	1.37			
Ash Content	35 - 39	34.42			

TABLE 4: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF OCTOBER 2023

Characteristic	Stipulated Range (%)	Monthly Average Content (%)				
		Oil				
Sulphur Content	0.5 - 3.5	2.4				
Ash Content	0.02 - 0.1	0.030				

4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:

 SO_2 Monthly = 3500 mg/Nm³

Dust Daily= 50 mg/Nm³

NO₂ Daily= 750 mg/Nm³

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.


(P) Eskom		Template Identifier	240-43921804	Rev	6		
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2		
		Effective Date	September2022	September2022			
		Review Date	September2024				


4.1 PM Daily Averages




CONTROLLED DISCLOSURE

		Template Identifier	240-43921804	Rev	6
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	2	
		Effective Date September2022	September2022		
		Review Date	September2024		







4.2SOx Daily Averages





CONTROLLED DISCLOSURE

(P) Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	2	
		Effective Date September2022	September2022		I
		Review Date	September2024		












CONTROLLED DISCLOSURE

Eskom		Template Identifier	240-43921804	Rev	6		
	Medupi Power Station Monthly Emissions Report	Document Identifier 240-88543153	Rev	2			
		Effective Date	September2022	September2022			
		Review Date	September2024				

4.3NOx Daily Averages








CONTROLLED DISCLOSURE

Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	September2022		
		Review Date	September2024		



CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	September	2022	<u> </u>
		Review Date	September	2024	

TABLE 6: MONTHLY TONNAGES FOR THE MONTH OF OCTOBER 2023

Associated Unit/Stack	РМ	SO ₂	NO ₂
Unit 1	53.0	5 555.3	804.3
Unit 2	82.0	6 837.7	1 052.7
Unit 3	49.6	4 868.6	555.6
Unit 4	Off	Off	Off
Unit 5	33.2	7 055.0	940.3
Unit 6	17.3	4 586.7	629.9
SUM (Tons)	235.1	28 903.4	3 982.8

TABLE 7: MONTHLY AVERAGES FOR THE MONTH OF OCTOBER 2023

Associated Unit/Stack	Average PM (mg/Nm ³)	Average SOx (mg/Nm³)	Average NOx (mg/Nm³)
Unit 1	24.2	2 484.0	359.4
Unit 2	34.0	2 761.8	425.5
Unit 3	28.3	2 705.4	309.4
Unit 4	Off	Off	Off
Unit 5	12.2	2 603.2	347.5
Unit 6	9.0	2 276.5	312.2

4 Continuous Emission Monitoring Systems (CEMS)

• Unit 1, 2, 3, 5 and 6 Continuous Emission Monitoring Systems were always in operation when the unit was on load.

TABLE 8: PERIODS DURING WHICH CEMS WAS INOPERATIVE

Date	CEMS status	Comments
N/A	N/A	N/A

TABLE 9: CEMS MONITOR RELIABILITY PERCENTAGE (%)

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	September	2022	
		Review Date	September	2024	

Associated Unit/Stack	РМ	SO2	NO ₂	O 2
Unit 1	100.0	100.0	99.7	99.7
Unit 2	100.0	100.0	100.0	99.7
Unit 3	100.0	0	0	0
Unit 4	Off	Off	Off	Off
Unit 5	100.0	99.9	99.9	99.7
Unit 6	100.0	99.2	99.2	96.4

Notes: SO_2 , O_2 and NO was Changed to a Unity Factor (1) for accurate reporting, there was a step change in the performance of the Unit 3 gas Monitor.

5 CEMS Calibration certificates and equipment used for calibration.

A service provider was appointed to calibrate CEMS equipment at Medupi Power Station, calibration certificates to be made available upon request. The service appointed for the CEMS calibration is in a process of obtaining SANAS accreditation. Verification of the CEMS after calibration is conducted internally by Eskom.

6 Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report for October2023 was e-mailed to the Licensing Authority.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	September2022		
		Review Date	September	2024	

7 Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

TABLE 10: TOTAL VOLATILE ORGANIC COMPOUND (TVOC) FOR OCTOBER 2023

(A) Calva		. <u></u>			
(2) Esko	rt)				
CALCULATION	OF EMISSIONS OF TOTAL VOLATILE COMPOU	NDS FROM FUEL OIL ST	ORAGE TANKS*		
Date:	Tuesday, 31 October 2023				
Station:	Medupi Power Station				
Province:	Limpopo Province				
Tank no.	1-2				
Description:	Outdoor fuel oil storage tank				
Tank Type:	Vertical fixed roof (vented to atmosphere)				
Material stored:	Fuel Oil 150				
	MONTHLY INPUT DATA FOR TH	E STATION			
	Please only insert relevant monthly data inputs	into the <u>blue cells</u> below			
	Choose from a dropdown menu in the	ne <u>green cells</u>			
	The total VOC emissions for the month a	are in the <u>red cells</u>			
	IMPORTANT: Do not change <u>any</u> other cells with	out consulting the AQ CoE			
MONTH:	October				
GENERAL INFOR	RMATION:	Data	Unit		
Total number of	fuel oil tanks:	2	NA		
Height of tank:*		14.2	m		
Diameter of tank:		12	m		
Net fuel oil throug	ghput for the month:	<u>1331</u>	tons/month		
Molecular weight	of the fuel oil:		Lb/lb-mole		
METEROLOGICA	AL DATA FOR THE MONTH	Data	Unit		
Daily average am	bient temperature	26.19	°C		
Daily maximum a	mbient temperature	33.65	°C		
Daily minimum a	nbient temperature	19.11	°C		
Daily ambient ten	nperature range	14.54	°C		
Daily total insolat	ion factor	5.81	kWh/m²/day		
Tank paint colou	r	<u>Aluminum/Specular</u>	NA		
Tank paint solar	absorbtance	0.39	NA		
FINAL OUTPUT:		Result Unit			
Breathing losses	:	0.74 kg/month			
Working losses:		0.04 kg/month			
TOTAL LOSSES	(Total TVOC Emissions for the month):	0.77	kg/month		
Tanks - Janu	ormed on this spreadsheet are taken from the USEF ary 1996. This spreadsheet is derived from material neers, 85-93 Chevy Chase Street, Jamaica, NY 114 6330, e-mail - PeressJ@nyc.r	s provided by Jimmy Peres 32 USA, Tel - 718-454-3920	s, PE, Tritech		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	Date September20		
		Review Date	September	2024	

8 Air quality improvements initiatives and public education and awareness campaigns

No awareness campaign for October 2023

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	e September2022		
		Review Date	September	2024	

9 Complaints Register

TABLE 5: COMPLAINTS FOR THE MONTH OF OCTOBER 2023

Name/ Source Code	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Results of	investi	gation		Action taken to resolve the complaint
Medupi Power Station ADF	Ash found in a farm 30 km from Medupi power station ADF in the Steenbokpan area.	PM ₁₀	Date of the complaint - 29 October 2023	major source Medupi pow km, Matimb 37 km, Grod and Lephala km. According te at the Ambie km away fro were incide Lephalale a impacted th the farm in o various pote concentratic between 29 exceedance this period. Ambient M Pollutants PM10 PM10 Fugitive Du The dust fa and Steenb	es of d ver stat a powe otegelu ale Afrir o the P ent Moi om the p ints of h rea tha e farm, questio ential sc ons of F and 30 es of the Onitori PM10 Limit 75 75	ust. Relative ion ash dump r station ash k coal mine a mat and Quar M ₁₀ data that hitoring Stat farm it is evid igh levels of of t could have i but it should n is located d purces of dus M ₁₀ were rec 0 October and e daily limit re ng Results Daily Exceet Date 29/10/2023 30/10/2023	b is about 30 dump about bout 28 km rry about 31 was analyzed, ion located 30 ent that there dust in the negatively be noted that lownwind of t. The high corded d there were 2 ecorded during dances Conc.(ug/m ³) 327.5 168.7	 Add an additional bucket on the Dust Fallout monitoring Network closer to the farm. This will help in identifying the sources of the dust monitored, Ensure that all actions on the Medupi Power Station Dust monitoring plan are implemented to minimise the dust from Medupi Power station such as: Irrigation using sprinklers. Applying of chemical suppressant Adding tap-off on the ADI system Dust suppression of Haul roads by water tankers Frequent cleaning of the Coal and Ash transfer houses.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	September2022		
		Review Date	September	2024	

Compiled by:	Lutendo Murovhi <u>Nemuter</u>	Date: 28/11/2023	
	Environmental Officer		
Verified by:	Malose Langa System Engineer Boiler	Date: 2023/11/29	
Verified by:	Shu Mpangase System Engineer C&I	Date: _2023/11/29	
Supported by:	Mokgadi Dikgale	Date: 2023 11 30	
Supported by:	Jabulani Mkhatshwa_pp	<u>der</u> Date: <u>2023-11-30</u>	

I Zweli Witbooi, declares that the information provided in this report is accurate and correct.

Yours sincere eo

Date: 2028/11/30

Žwel Witbooi GENERAL MANAGER: MEDUPI POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.