

Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		

Date: 2023/09/30

Tel: 014 762 6820

Enquiries: MF Dikgale

Stanley Koenaite

Waterberg District Municipality Private Bag X1018 Modimole 0510

skoenaite@waterberg.gov.za

Ref: H16/1/13-AEL/M1/R1 – September2023

Dear Mr Koenaite

MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF SEPTEMBER 2023

This document serves as the monthly emissions report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), H16/1/13-AEL/M1/R1.

This report reflects Unit 1, 2, 3, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of September 2023 only.

1. Raw Materials and Products

TABLE 1: QUANTITY OF RAW MATERIALS AND PRODUCTS CONSUMPTION IN SEPTEMBER 2023

Raw Materials and Products	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption – September2023
used	Coal	Tons/month	1 875 000	1 014 493.9
	Fuel Oil	Tons/month	20 000	2257
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of September 2023
	Energy	GWh	3 571.2	2159.98
	Ash Emitted	Tons/month	not specified	197.80

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		

		Daily	Hours o	of Ope	ration		Coal	Production rate (MW)					
Date	U1	U2	U3	U4	U5	U6	usage	U1	U2	U3	U4	U5	U6
01-Sept	24.0	24.0	24.0	0.0	24.0	24.0	35871	691	729	645	Off	710	667
02-Sept	24.0	24.0	24.0	0.0	24.0	24.0	36765	705	729	641	Off	714	699
03-Sept	24.0	24.0	24.0	0.0	24.0	24.0	37720	695	732	652	Off	759	727
03-Sept 04-Sept	24.0	24.0	24.0	0.0	8.5	24.0	31710	679	739	641	Off	672	723
05-Sept	24.0	24.0	17.4	0.0	13.4	24.0	30541	681	716	654	Off	538	714
06-Sept	24.0	24.0	20.2	0.0	24.0	24.0	35077	694	716	613	Off	648	716
07-Sept	24.0	24.0	24.0	0.0	24.0	24.0	35556	681	692	665	Off	635	694
08-Sept	24.0	24.0	24.0	0.0	24.0	24.0	37276	694	723	668	Off	669	729
09-Sept	24.0	24.0	24.0	0.0	24.0	24.0	35479	658	684	590	Off	682	713
10-Sept	24.0	24.0	24.0	0.0	24.0	16.6	33922	655	714	618	Off	740	690
11-Sept	24.0	24.0	24.0	0.0	24.0	19.1	35476	661	732	636	Off	736	641
12-Sept	24.0	24.0	24.0	0.0	24.0	24.0	37063	715	730	659	Off	714	706
13-Sept	24.0	24.0	24.0	0.0	24.0	24.0	36313	718	732	671	Off	628	737
14-Sept	24.0	24.0	24.0	0.0	24.0	24.0	34395	746	721	678	Off	455	744
15-Sept	24.0	24.0	24.0	0.0	24.0	24.0	34434	697	696	658	Off	549	650
16-Sept	24.0	24.0	24.0	0.0	24.0	24.0	34200	679	692	608	Off	623	599
17-Sept	24.0	24.0	24.0	0.0	24.0	24.0	35346	710	695	630	Off	654	700
18-Sept	24.0	18.9	24.0	0.0	24.0	24.0	33408	693	711	644	Off	670	694
19-Sept	24.0	18.2	24.0	0.0	24.0	24.0	32036	685	561	652	Off	663	689
20-Sept	24.0	24.0	24.0	0.0	24.0	24.0	33394	690	589	631	Off	624	695
21-Sept	24.0	24.0	24.0	0.0	24.0	24.0	34350	707	608	638	Off	691	649
22-Sept	24.0	24.0	24.0	0.0	24.0	24.0	35394	755	660	625	Off	625	696
23-Sept	24.0	24.0	24.0	0.0	24.0	0.4	30502	731	739	631	Off	749	478
24-Sept	24.0	16.3	24.0	0.0	24.0	0.0	27347	712	723	632	Off	747	off
25-Sept	24.0	22.2	24.0	0.0	24.0	0.0	27504	714	523	635	Off	669	off
26-Sept	24.0	24.0	24.0	0.0	24.0	16.5	30410	683	590	604	Off	655	531
27-Sept	24.0	24.0	24.0	0.0	9.0	24.0	30261	738	600	625	Off	521	600
28-Sept	24.0	24.0	24.0	0.0	24.0	24.0	34378	763	600	655	Off	578	721
29-Sept	24.0	24.0	24.0	0.0	24.0	24.0	36139	770	600	668	Off	726	718
30-Sept	24.0	24.0	24.0	0.0	24.0	24.0	32227	683	600	621	Off	658	673

NB: Operating hours less than 24 highlighted in pink; Unit OFF highlighted in Red

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		

2. Abatement Technology

Table 2: Abatement Equipment Control Technology efficiency for month of September2023

Associated Unit/Stack	Technology Type	Efficiency	FFP Utilization
Unit 1	Fabric Filter Plant (FFP)	99.907%	100%
Unit 2	Fabric Filter Plant (FFP)	99.899%	100%
Unit 3	Fabric Filter Plant (FFP)	99.912%	100%
Unit 4	Fabric Filter Plant (FFP)	off	off
Unit 5	Fabric Filter Plant (FFP)	99.956%	100%
Unit 6	Fabric Filter Plant (FFP)	99.965%	100%

Note: FFP does not have bypass mode operation, hence plant 100% Utilised.

3. Energy Source Characteristics

TABLE 3: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF SEPTEMBER 2023

Characteristic	Stipulated Range Monthly Average Content (% by weight on a dry basis) (% by weight on a dry basis)			
	Coal			
Sulphur Content	1.3 - 2.2	1.38		
Ash Content	35 - 39	34.37		

TABLE 4: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF SEPTEMBER 2023

Characteristic	Stipulated Range (%)	Monthly Average Content (%)
	0)il
Sulphur Content	0.5 - 3.5	2.45
Ash Content	0.02 - 0.1	0.035

4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:

 SO_2 Monthly = 3500 mg/Nm³ Dust Daily= 50 mg/Nm³ NO₂ Daily= 750 mg/Nm³


CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.





Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		

4.1 PM Daily Averages















Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		






4.2 SOx Daily Averages










Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		















Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		

4.3 NOx Daily Averages













Template Identifier	240-43921804	Rev	6
Document Identifier	240-88543153	Rev	2
Effective Date	September2022		
Review Date	September2024		








Table 6: Monthly tonnages for the month of September 2023

Associated Unit/Stack	РМ	SO ₂	NO ₂
Unit 1	55.7	5 209.2	748.8
Unit 2	57.4	5 660.7	846.8
Unit 3	46.7	4 490.1	492.8
Unit 4	OFF	OFF	OFF
Unit 5	21.5	6 232.0	821.5
Unit 6	16.4	4 080.9	590.2
SUM (Tons)	197.8	25 672.9	3 500.0

TABLE 7: MONTHLY AVERAGES FOR THE MONTH OF SEPTEMBER 2023

Associated Unit/Stack	Average PM (mg/Nm³)	Average SOx (mg/Nm³)	Average NOx (mg/Nm³)
Unit 1	26.5	2 485.2	357.5
Unit 2	28.1	2 612.7	392.8
Unit 3	27.3	2 537.3	278.3
Unit 4	OFF	OFF	OFF
Unit 5	9.2	2 528.6	334.0
Unit 6	9.5	2 264.9	327.6

4 Continuous Emission Monitoring Systems (CEMS)

 Unit 1, 2, 3, 5 and 6 Continuous Emission Monitoring Systems were always in operation when the unit was on load.

TABLE 8: PERIODS DURING WHICH CEMS WAS INOPERATIVE

Date	CEMS status	Comments
N/A	N/A	N/A

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.




TABLE 9: CEMS MONITOR RELIABILITY PERCENTAGE (%)

Associated Unit/Stack	РМ	SO₂	NO ₂	O 2
Unit 1	100.0	96.7	96.7	96.7
Unit 2	100.0	97.4	97.4	97.1
Unit 3	100.0	0	0	0
Unit 4	off	off	off	off
Unit 5	100.0	99.8	99.8	99.8
Unit 6	100.0	96.4	96.3	92.9

Notes: SO2, O₂ and NO was Changed to a Unity Factor (1) for accurate reporting, there was a step change in the performance of the Unit 3 gas Monitor.

5 CEMS Calibration certificates and equipment used for calibration.

A service provider was appointed to calibrate CEMS equipment at Medupi Power Station, calibration certificates to be made available upon request. The service appointed for the CEMS calibration is in a process of obtaining SANAS accreditation. Verification of the CEMS after calibration is conducted internally by Eskom.

6 Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report for September 2023 was e-mailed to the Licensing Authority.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
⊗ Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	September2022		•
		Review Date	September2024		

7 Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

TABLE 10: TOTAL VOLATILE ORGANIC COMPOUND (TVOC) FOR SEPTEMBER 2023

CALCULATION	OF EMISSIONS OF TOTAL VOLATILE COMPOU	INDS FROM FUEL OIL ST	ORAGE TANKS	
0,1200E,11101	TO EMISSIONS OF TOTAL TOLATILE SOME SO		010102 1711110	
Date:	Saturday, 30 September 2023			
Station:	Medupi Power Station			
Province:	Limpopo Province			
Tank no.	1-2			
Description:	Outdoor fuel oil storage tank			
Tank Type:	Vertical fixed roof (vented to atmosphere)			
Material stored:	Fuel Oil 150			
	MONTHLY INPUT DATA FOR TH	E STATION		
	Please only insert relevant monthly data inputs	into the blue cells below		
	Choose from a dropdown menu in the	ne <u>green cells</u>		
	The total VOC emissions for the month a	are in the <u>red cells</u>		
	IMPORTANT: Do not change any other cells with	out consulting the AQ CoE		
MONTH:	September			
GENERAL INFO	ERAL INFORMATION: Data Unit			
Total number of	fuel oil tanks:	2 NA		
Height of tank:*		14.2 m		
Diameter of tank	C:	12	m	
Net fuel oil throu	ighput for the month:	2257	tons/month	
Molecular weigh	t of the fuel oil:		Lb/lb-mole	
METEROLOGIC	AL DATA FOR THE MONTH	Data	Unit	
Dailv average ar	mbient temperature	23.43	°C	
	ambient temperature	31.06	°C	
-	ambient temperature	16.52	°C	
Daily ambient te	mperature range	14.54	°C	
Daily total insola	tion factor	4.41	kWh/m²/day	
Γank paint coloι	ır	Aluminum/Specular	NA	
Tank paint solar	absorbtance	0.39	NA	
FINAL OUTPUT	:	Result	Unit	
Breathing losses	s:	0.69	kg/month	
		0.06	kg/month	
Working losses:		0.00		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6
⊕ Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	September2022	<u>I</u>	
		Review Date	September2024		

8 Air quality improvements initiatives and public education and awareness campaigns

On 22 September 2023, Tielelo Secondary School in Marapong Township was visited by the Medupi Team for an Air Quality Management Awareness and Education session. The target audiences were school teachers and Leaners from Grade 8-12.

- Information shared on the day included the following.
- Electricity generation process from coal fired Power Stations
- Primary pollutants associated with coal fired Power Station (SOx, NOx, CO₂, PM, CO)
- Emissions Control Technologies
- Legal Requirements
- · Consequences of non-compliance (penalties
- Ways of reducing emissions within our daily lives including our homes.

9 Complaints Register


TABLE 5: COMPLAINTS FOR THE MONTH OF SEPTEMBER 2023

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Results of investigation	Action taken to resolve the complaint

Complaint received from DFFE 26 September 2023 stating that: "Compliance Directorate received a complaint from an anonymous complainant alleging ash pollution from Medupi and Matimba Power Station ash-dumps. According to the complainant, this has been happening for several months affecting the entire Onverwacht Township." Response letter is attached.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.



Date: 31 October 2023 NemutamberAtt. Lutendo Murovhi Compiled by: **Environmental Officer** Date: _2023/10/31 Malose Langa Verified by: System Engineer Boiler Shu Mpangase + 1 Date: 31 October 2023 Verified by: System Engineer C&I Supported by: Mokgadi Dikgale **Environmental Manager** Supported by: Jabulani Mkhatshwa Engineering Group Manager

I Zweli Witbooi, declares that the information provided in this report is accurate and correct.

Date: 7023 - 10 - 31

Yours sincerely

Zweli Witbooi

GENERAL MANAGER: MEDUPI POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.