



Generation

Nkangala District Municipality
P O Box 437
Middleburg
1050

Date: 2023/12/20

Enquiries: Lufuno Tshidzumba
☎ +27 17 612 6269

Attention:

Mr V Mahlangu

Enquiries: Lindokuhle Ngobese
☎ +27 17 612 6291

AND


Directorate: Air Quality Management Services
The Director:
Mr Vumile Senene
Department of Environmental Affairs
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Total number of pages:
13


Total number of annexes:

MATLA POWER STATION

Atmospheric Emission License 17/4/AEL/MP312/11/14



BOILER ENGINEERING MANAGER


ENVIRONMENTAL MANAGER


ENGINEERING MANAGER

20/12/2023
DATE
2023/12/20
DATE
20.12.2023
DATE

MATLA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/14



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Nov-2023
	Coal	Tons	1 475 000	749 629
	Fuel Oil	Tons	3 500	1 387

Production Rates	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Nov-2023
	Energy	GWh	2 657	1 665
	Ash	Tons	471 000	240 181
	RE PM	kg/MWh	not specified	0.870

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [3 690 MW] x 24 hrs x days in Month/1000 to convert to GWh

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.8-1.1	1.00
Ash Content	%	21-40	32.04

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO
South	200	3500	1200
Unit 4	200	3500	1200
Unit 5	100	3500	1200
Unit 6	100	3500	1200

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Nov-2023
South	<i>Electro Static Precipators (ESP)</i>	<i>99.329%</i>
Unit 4	<i>Electro Static Precipators (ESP)</i>	<i>98.830%</i>
Unit 5	<i>Electro Static Precipators (ESP)</i>	<i>99.098%</i>
Unit 6	<i>Electro Static Precipators (ESP)</i>	<i>99.764%</i>

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 DATA RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
South	<i>93.2</i>	<i>94.3</i>	<i>94.3</i>	<i>88.7</i>
Unit 4	<i>94.1</i>	<i>99.5</i>	<i>99.7</i>	<i>99.8</i>
Unit 5	<i>100.0</i>	<i>99.7</i>	<i>99.9</i>	<i>100.0</i>
Unit 6	<i>99.3</i>	<i>99.6</i>	<i>99.7</i>	<i>99.9</i>

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of November-2023

Associated Unit/Stack	PM	SO ₂	NOx
Unit 1	149.9	1 198.4	388.3
Unit 2	386.6	3 499.8	1 148.9
Unit 3	331.0	2 466.3	808.2
Unit 4	310.8	3 566.7	1 240.7
Unit 5	174.4	2 786.8	914.5
Unit 6	96.8	2 893.9	825.6
SUM	1 449.4	16 411.9	5 326.2

Table 6.2: Operating days in compliance to PM AEL Limit - November 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
South	14	8	0	8	16	240.3
Unit 4	17	7	0	2	9	202.0
Unit 5	17	8	1	4	13	119.8
Unit 6	26	4	0	0	4	65.9
SUM	74	27	1	14	42	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - November 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
South	30	0	0	0	0	1 799.1
Unit 4	27	0	0	0	0	2 306.7
Unit 5	30	0	0	0	0	1 924.9
Unit 6	30	0	0	0	0	1 963.8
SUM	117	0	0	0	0	

Table 6.4: Operating days in compliance to NO_x AEL Limit - November 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
South	30	0	0	0	0	589.6
Unit 4	27	0	0	0	0	803.7
Unit 5	30	0	0	0	0	631.5
Unit 6	30	0	0	0	0	560.1
SUM	117	0	0	0	0	

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Matla South Stack PM Emissions - November 2023




Figure 2: Matla Unit 4 PM Emissions - November 2023




Figure 3: Matla Unit 5 PM Emissions - November 2023




Figure 4: Matla Unit 6 PM Emissions - November 2023




Figure 5: Matla South Stack SO₂ Emissions - November 2023




Figure 6: Matla Unit 4 SO₂ Emissions - November 2023




Figure 7: Matla Unit 5 SO₂ Emissions - November 2023




Figure 8: Matla Unit 6 SO₂ Emissions - November 2023




Figure 9: Matla South Stack NOx Emissions - November 2023




Figure 10: Matla Unit 4 NOx Emissions - November 2023




Figure 11: Matla Unit 5 NOx Emissions - November 2023





Figure 12: Matla Unit 6 NOx Emissions - November 2023



7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of November-2023

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 1		Unit 1		Unit 2		no event	
Breaker Open (BO)	12:15 PM	2023/11/02	11:30 PM	2023/11/28	2:45 PM	2023/11/25		
Draught Group (DG) Shut Down (SD)	6:10 AM	2023/11/03	10:10 AM	2023/11/29	6:10 AM	2023/11/27		
BO to DG SD (duration)	00:17:55	DD:HH:MM	00:10:40	DD:HH:MM	01:15:25	DD:HH:MM		DD:HH:MM
Fires in time	9:35 PM	2023/11/08	4:45 PM	2023/11/30	7:40 PM	2023/11/29		
Synch. to Grid (or BC)	2:20 AM	2023/11/10	2:35 AM	2023/12/01	5:20 AM	2023/11/30		
Fires in to BC (duration)	01:04:45	DD:HH:MM	00:09:50	DD:HH:MM	00:09:40	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit	not > limit	not > limit		
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM

South Stack ...cont.	Event 5		Event 6		Event 7		Event 8	
Unit No.	no event		no event		no event		no event	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 5	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM



Unit No. 6	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of November-2023 in mg/Nm³

[Include reference to once off test showing typical emissions rates during fires in and SD]

11 General

Unit 5 and 6 PM curve expired, target for new correlation testing is 02 February 2024.
QAL 2 averages used on gas emissions where monitor is faulty or inaccurate.


21/12/2023
Boiler Engineering Date

22/12/2023
General Manager Date


21/12/2023
Environmental Department Date

Compiled by: Boiler Engineering Department

ESP & SO₃ System Engineer

For: Department of Environmental Affairs and Tourism

Chief Air Pollution Control Officer

Copies: Eskom Environmental Management

D Herbst
B Mccourt

Group Technology Engineering

R Rampiar
E. Patel

Matla Power Station:

Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager
System Engineer
Environmental Officer
Performance and Test
Production Manager

ADDENDUM TO MONTHLY EMISSIONS REPORT

8 EMERGENCY GENERATION

Emergency Generation *[This is only required for stations that are requested to report on this information]*

Table 8. Emergency Generation per unit for the month of November 2023

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control						
Emergency Hours declared including hours after stand down						
Hours over the Limit during Emergency Generation						

9 COMPLAINTS REGISTER

Table 9. Complaints for the month of November 2023

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date measure will be implemented
<i>(insert name of station)</i>	<i>(Insert root cause for incident)</i>	<i>(Insert emissions associated with incident)</i>	<i>(Insert dispersion model information where applicable)</i>	<i>(Insert mitigation measures taken)</i>	<i>(Insert date of implementation of)</i>

10 S30 INCIDENT OR LEGAL CONTRAVENTION REGISTER

To be completed in the case of a S30 incident or a legal contravention:

Unit no	Incident Start Date	Incident End Date	Incident Cause	Remedial action	S30 initial notification sent	Date S30 investigation report sent	Date DEA Acknowledgment	Date DEA Acceptable	Comments / Reference No.
SS	04/11/2023	06/11/2023	Unit 2 and 3 poor precip performance due to high precip flue gas temperatures	Biased unit drought group, cleared hopper levels	No				Legal contravention
SS	25/11/2023	06/12/2023	High hopper levels, poor K-pump performance and defects.	Repaired K-pump and cleared hopper levels	No				Legal contravention
4	08/11/2023	09/11/2023	High hopper levels, poor precip performance and internally damaged precip.	Hired, compressors and repairing the defective compressors	No				Legal contravention
5	18/11/2023	18/11/2023	partially blocked SO3 catalyst.	Hired, compressors and repairing the defective compressors	Yes				Legal contravention
5	19/11/2023	21/11/2023	High hopper levels, poor precip performance, poor coal qualities and high precip flue gas temperatures.	Coal qualities improved and cleared hopper levels	No				Legal contravention