		Template Identifier	240-43921804	Rev	6	
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2	
		Effective Date	September2022			
		Review Date	September2024			

Stanley Koenaite

Waterberg District Municipality Private Bag X1018 Modimole 0510 Date: 2023/12/31 Enquiries: MF Dikgale Tel: 014 762 6820

skoenaite@waterberg.gov.za

Ref: H16/1/13-AEL/M1/R1 - December 2023

Dear Mr Koenaite

MEDUPI POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF DECEMBER 2023

This document serves as the monthly emissions report required in terms of Section 7.7.1 of Medupi Power Station Provisional Atmospheric Emission License (AEL), H16/1/13-AEL/M1/R1.

This report reflects Unit 1, 2, 3, 5 and 6 gaseous and particulate emissions performance against the AEL limit for the month of December 2023 only.

1. Raw Materials and Products

TABLE 1: QUANTITY OF RAW MATERIALS AND PRODUCTS CONSUMPTION IN DECEMBER 2023

Raw Materials and Products	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption – December2023
used	Coal	Tons/month	1 875 000	836 553.0
	Fuel Oil	Tons/month	20 000	2412
Production Rates	Product/ By- Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of December 2023
	Energy	GWh	3 571.2	1773.95
	Ash Emitted	Tons/month	not specified	134.90

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6	
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2	
		Effective Date	September2022			
		Review Date	September2024			

	Dail	y Repor	table H	ours o	of Opera	tion	Coal		Pro	ductior	n rate (N	IW)	
Date	U1	U2	U3	U4	U5	U6	usage	U1	U2	U3	U4	U5	U6
01-Dec	0.0	24.0	24.0	0.0	24.0	24.0	28928	Off	703	650	Off	665	698
02-Dec	0.0	24.0	24.0	0.0	24.0	24.0	28541	Off	704	623	Off	687	696
03-Dec	0.0	24.0	24.0	0.0	24.0	24.0	26957	Off	671	614	Off	640	617
04-Dec	0.0	24.0	24.0	0.0	24.0	24.0	29393	Off	734	621	Off	677	678
05-Dec	0.0	24.0	24.0	0.0	24.0	24.0	28432	Off	740	612	Off	666	674
06-Dec	0.0	24.0	24.0	0.0	24.0	16.0	26627	Off	736	634	Off	678	689
07-Dec	0.0	24.0	24.0	0.0	24.0	0.0	26037	Off	675	647	Off	638	556
08-Dec	0.0	24.0	24.0	0.0	24.0	19.9	29010	Off	675	647	Off	628	722
09-Dec	0.0	24.0	24.0	0.0	24.0	24.0	27695	Off	723	621	Off	560	706
10-Dec	0.0	24.0	24.0	0.0	24.0	24.0	25608	Off	732	625	Off	571	647
11-Dec	0.0	21.3	24.0	0.0	24.0	24.0	27180	Off	733	669	Off	680	659
12-Dec	0.0	0.0	24.0	0.0	24.0	24.0	19518	Off	Off	640	Off	638	663
13-Dec	0.0	0.0	24.0	0.0	18.8	24.0	17698	Off	Off	645	Off	426	698
14-Dec	0.0	0.0	24.0	0.0	0.0	24.0	19945	507	Off	654	Off	Off	684
15-Dec	10.2	0.0	24.0	0.0	0.0	24.0	24052	601	Off	686	Off	408	700
16-Dec	0.0	0.0	24.0	0.0	23.7	24.0	26296	570	Off	664	Off	687	697
17-Dec	8.1	0.0	24.0	0.0	24.0	24.0	25835	612	Off	639	Off	628	658
18-Dec	24.0	0.0	24.0	0.0	24.0	24.0	26401	609	Off	623	Off	679	663
19-Dec	24.0	0.0	24.0	0.0	24.0	24.0	27038	645	Off	634	Off	682	652
20-Dec	24.0	0.0	24.0	0.0	24.0	24.0	27910	609	Off	623	Off	672	590
21-Dec	24.0	0.0	24.0	0.0	24.0	24.0	28039	733	Off	615	Off	615	590
22-Dec	24.0	0.0	24.0	0.0	24.0	24.0	32884	740	474	614	Off	690	590
23-Dec	24.0	19.9	24.0	0.0	24.0	24.0	33436	634	704	573	Off	664	547
24-Dec	24.0	24.0	24.0	0.0	24.0	24.0	33518	683	625	605	Off	678	574
25-Dec	24.0	24.0	24.0	0.0	23.2	24.0	30501	688	619	622	Off	431	557
26-Dec	24.0	14.3	24.0	0.0	0.0	24.0	24509	619	582	586	Off	Off	560
27-Dec	24.0	5.8	24.0	0.0	0.0	24.0	24565	669	613	632	Off	Off	475
28-Dec	24.0	24.0	24.0	0.0	0.0	24.0	25885	692	743	599	Off	Off	550
29-Dec	24.0	24.0	24.0	0.0	0.0	24.0	28546	740	716	653	Off	Off	550
30-Dec	24.0	24.0	24.0	0.0	0.0	24.0	28141	755	680	659	Off	Off	550
31-Dec	24.0	24.0	24.0	0.0	0.0	24.0	27428	775	678	658	Off	Off	550

NB: Operating hours less than 24 highlighted in pink; Unit OFF highlighted in Red.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

		Template Identifier	240-43921804	Rev	6	
Eskom	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2	
		Effective Date	September2022			
		Review Date	September2024			

2. Abatement Technology

 Table 2: Abatement Equipment Control Technology efficiency for month of December2023

Associated Unit/Stack	Technology Type	Efficiency	FFP Utilization
Unit 1	Fabric Filter Plant (FFP)	99.964%	100%
Unit 2	Fabric Filter Plant (FFP)	99.921%	100%
Unit 3	Fabric Filter Plant (FFP)	99.894%	100%
Unit 4	Fabric Filter Plant (FFP)	Off	off
Unit 5	Fabric Filter Plant (FFP)	99.945%	100%
Unit 6	Fabric Filter Plant (FFP)	99.980%	100%

Note: FFP does not have bypass mode operation, hence plant 100% Utilised.

3. Energy Source Characteristics

TABLE 3: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF DECEMBER 2023

Characteristic	Stipulated RangeMonthly Average Content(% by weight on a dry basis)(% by weight on a dry basis)				
	Coal				
Sulphur Content	1.3 - 2.2	1.42			
Ash Content	35 - 39	35.14			

TABLE 4: ENERGY SOURCE MATERIAL CHARACTERISTICS FOR THE MONTH OF DECEMBER 2023

Characteristic	Stipulated Range (%)	Monthly Average Content (%)				
		Oil				
Sulphur Content	0.5 - 3.5	2.4				
Ash Content	0.02 - 0.1	0.03				

4. Emissions Reporting

Medupi Power Station uses Continuous Emission Monitoring System which uses the extractive method for analysis.

The emission limits are as follows:

 SO_2 Monthly = 3500 mg/Nm³

Dust Daily= 50 mg/Nm³


NO₂ Daily= 750 mg/Nm³


CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2
		Effective Date	September2022		
		Review Date	September2024		

4.1 PM Daily Averages










CONTROLLED DISCLOSURE


(P) Eskom		Template Identifier	240-43921804	Rev	6
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	2	
		Effective Date September2022			
		Review Date	September2024		






4.2SOx Daily Averages





CONTROLLED DISCLOSURE


() Eskom		Template Identifier	240-43921804	Rev	6	
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	Rev	2	
		Effective Date	September2022	September2022		
		Review Date	September2024			



CONTROLLED DISCLOSURE


() Eskom		Template Identifier	240-43921804	Rev	6	
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153	2		
		Effective Date	September2022	September2022		
		Review Date	September2024			

4.3 NOx Daily Averages




CONTROLLED DISCLOSURE


€€skom		Template Identifier	240-43921804
	Medupi Power Station Monthly Emissions Report	Document Identifier	240-88543153
		Effective Date	September2022
		Review Date	September2024



CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.





Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	te September2022		<u> </u>
		Review Date	September2024		

TABLE 6: MONTHLY TONNAGES FOR THE MONTH OF DECEMBER 2023

Associated Unit/Stack	РМ	SO ₂	NO ₂
Unit 1	11.9	2 850.2	412.2
Unit 2	32.2	4 466.6	603.6
Unit 3	58.5	5 000.8	567.4
Unit 4	Off	Off	Off
Unit 5	22.0	5 087.8	522.6
Unit 6	10.3	3 297.1	633.9
SUM (Tons)	134.9	20 702.4	2 739.6

TABLE 7: MONTHLY AVERAGES FOR THE MONTH OF DECEMBER 2023

Associated Unit/Stack	Average PM (mg/Nm ³)	Average SOx (mg/Nm³)	Average NOx (mg/Nm³)
Unit 1	11.7	2 444.9	353.3
Unit 2	19.8	2 622.1	355.7
Unit 3	30.9	2 639.2	300.2
Unit 4	Off	Off	Off
Unit 5	11.6	2 632.8	271.8
Unit 6	5.2	1 602.5	312.0

5. Continuous Emission Monitoring Systems (CEMS)

• Unit 1, 2, 3, 5 and 6 Continuous Emission Monitoring Systems were always in operation when the unit was on load. However, there were days where the monitors were faulty and reading incorrect values. Table 8

TABLE 8: PERIODS DURING WHICH CEMS WAS INOPERATIVE/MALFUNCTIONING

Date	CEMS status	Comments
17-20 Dec 2023	Unit 5	Unit 5 experienced CEMS issues for 3 days from 17 - 20 December 2023. The CEMS issues were resolved before the Unit went on Outage on 25 December 2023.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	-	Power Station Monthly nissions Report	Template Identifier	240-43921804	Rev	6
			Document Identifier	240-88543153	Rev	2
		Effective Date September		September	per2022	
			Review Date	Date September2024		
08 – 31 Dec 2023 Unit 6		the monitor rea station is cond investigation to	nced CEMS issue ading low figures. ucting a detailed o determine the ne faulty monitor.			

TABLE 9: CEMS MONITOR RELIABILITY PERCENTAGE (%)

Associated Unit/Stack	РМ	SO2	NO ₂	O 2
Unit 1	93.8	100.0	100.0	99.2
Unit 2	100.0	99.7	99.5	99.9
Unit 3	100.0	0	0	0
Unit 4	Off	Off	Off	Off
Unit 5	100.0	100.0	99.8	99.4
Unit 6	100.0	97.0	99.9	80.0

Notes: SO_2 , O_2 and NO was Changed to a Unity Factor (1) for accurate reporting, there was a step change in the performance of the Unit 3 gas Monitor.

6.CEMS Calibration certificates and equipment used for calibration.

A service provider was appointed to calibrate CEMS equipment at Medupi Power Station, calibration certificates to be made available upon request. The service appointed for the CEMS calibration is in a process of obtaining SANAS accreditation. Verification of the CEMS after calibration is conducted internally by Eskom.

7. Ambient Air Quality Monitoring Report

The Ambient Air Quality Monitoring and Dust fall-out report for December2023 was e-mailed to the Licensing Authority.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	e September2022		
		Review Date	September2024		

8. Visual inspection of the exterior walls of the fuel oil tanks and TVOC Estimation

Visual inspection was conducted and there were no leaks observed on the exterior walls of the fuel oil tanks.

TABLE 10: TOTAL VOLATILE ORGANIC COMPOUND (TVOC) FOR DECEMBER 2023

<pre></pre>				
CALCULATION	OF EMISSIONS OF TOTAL VOLATILE COMPOU	INDS FROM FUEL OIL ST	ORAGE TANKS*	
	-			
Date:	Sunday, 31 December 2023			
Station:	Medupi Power Station			
Province:	Limpopo Province			
Tank no.	1-2			
Description:	Outdoor fuel oil storage tank			
Tank Type:	Vertical fixed roof (vented to atmosphere)			
Material stored:	Fuel Oil 150			
	MONTHLY INPUT DATA FOR TH	E STATION		
	Please only insert relevant monthly data inputs			
	Choose from a dropdown menu in the	he <u>green cells</u>		
	The total VOC emissions for the month a	are in the <u>red cells</u>		
IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE				
MONTH:	December			
GENERAL INFOR	MATION:	Data	Unit	
Total number of f	uel oil tanks:	2	NA	
Height of tank:*		14.2	m	
Diameter of tank:		12	m	
Net fuel oil throug	hput for the month:	<u>2412</u>	tons/month	
Molecular weight	of the fuel oil:		Lb/lb-mole	
METEROLOGICA	L DATA FOR THE MONTH	Data	Unit	
Daily average am	bient temperature	27.35	°C	
Daily maximum a	mbient temperature	33.26	°C	
Daily minimum an	nbient temperature	21.97	°C	
Daily ambient terr	nperature range	11.30	°C	
Daily total insolati	ion factor	6.12	kWh/m²/day	
Tank paint colour	•	<u>Aluminum/Specular</u>	NA	
Tank paint solar a	absorbtance	0.39	NA	
FINAL OUTPUT:		Result	Unit	
Breathing losses:		0.69	kg/month	
Working losses: 0.07 kg/month				
TOTAL LOSSES (Total TVOC Emissions for the month): 0.76 kg/month				
*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage				
Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech				
Consulting Engir	Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-			
6330. e-mail - PeressJ@nvc.rr.com.				

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

(2) Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	September	2022	
		Review Date	September	2024	

9. Air quality improvements initiatives and public education and awareness campaigns

No awareness campaign for December 2023

On 16 November 2023, Steenbokpan Township (Leseding Hall) was visited by the Medupi Team for an Air Quality Management Awareness and Education session. The target audiences were the community Members of Steenbokpan.

Information shared on the day included the following:

- Electricity generation process from coal fired Power Stations
- Primary pollutants associated with coal fired Power Station (SOx, NOx, CO₂, PM, CO)
- Emissions Control Technologies
- Legal Requirements
- Consequences of non-compliance (penalties)
- Ways of reducing emissions within our daily lives including our homes.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	te September2022		
		Review Date	September2024		

10. Complaints Register

TABLE 5: COMPLAINTS FOR THE MONTH OF DECEMBER 2023

Name/ Source Code	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Results of investigation	Action taken to resolve the complaint
N/A	N/A	N/A	N/A	N/A	N/A

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

(2) Eskom	Medupi Power Station Monthly Emissions Report	Template Identifier	240-43921804	Rev	6
		Document Identifier	240-88543153	Rev	2
		Effective Date	September2022		
		Review Date	September	2024	

Compiled by:	Lutendo Murovhi Nemutambadto. Date: <u>30 January 20</u> 24
Verified by:	Environmental Officer Malose Langa Date: 2024/01/31 System Engineer Boiler
Verified by:	Shu MpangaseDate: _2024/01/31 System Engineer C&I
Supported by:	Mokgadi DikgaleDate: 2024/01/31 Environmental Manager
Supported by:	Jabulani MkhatshwaDate:Date: Engineering Group Manager

I Zweli Witbooi, declares that the information provided in this report is accurate and correct.

Yours sincerely

200 Zweli Witbooi

Zweli Witbooi GENERAL MANAGER: MEDUPI POWER STATION

Date: 2024/01/3/

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.