


HENDRINA POWER STATION MONTHLY EMISSIONS REPORT
 Atmospheric Emission License 17/4/AEL/MP312/11/16



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted Consumption Rate	Consumption Rate Jan-2024
	Coal	Tons	820,000	119,141.0
Fuel Oil	Tons	3,200	624,066	

Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Production Rate Jan-2024
	Energy	GWh	1488	192.04
Ash	Tons	290,000	27,665	
RE PM	kg/MWh	not specified	0.208	

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 to < 1	0.68
Ash Content	%	20 to < 35	23.22

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
North	75	3500	1200
South	75	3500	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jan-2024
Unit 1	Fabric Filter Plant (FFP)	Unit Off-line
Unit 2	Fabric Filter Plant (FFP)	Unit Off-line
Unit 3	Fabric Filter Plant (FFP)	Unit Off-line
Unit 4	Fabric Filter Plant (FFP)	Unit Off-line
Unit 5	Fabric Filter Plant (FFP)	99.928%
Unit 6	Fabric Filter Plant (FFP)	99.936%
Unit 7	Fabric Filter Plant (FFP)	Unit Off-line
Unit 8	Fabric Filter Plant (FFP)	Unit Off-line
Unit 9	Fabric Filter Plant (FFP)	Unit Off-line
Unit 10	Fabric Filter Plant (FFP)	Unit Off-line

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂	CO ₂
North	97.9	100.0	100.0	99.8	0
South	99.6	0.0	0.0	99.9	0

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂.

6 EMISSION PERFORMANCE

Table 6.1 Monthly tonnages for the month of January-2024

Associated Unit/Stack	PM (tons)	SOx (tons)	NOx (tons)
North	8.4	1,283.6	828.3
South	31.5	0.0	0.0
SUM	40.0	1,283.6	828.3

Table 6.2 Operating days in compliance to PM AEL Limit - January 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
North	23	0	0	0	0	18.1
South	31	0	0	0	0	48.1
SUM	57	0	0	0	0	

Table 6.3 Operating days in compliance to SO₂ AEL Limit - January 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
North	27	0	0	0	0	2,519.0
South	0	0	0	0	0	
SUM	27	0	0	0	0	

Table 6.4 Operating days in compliance to NOx AEL Limit - January 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
North	3	0	0	24	24	1,576.0
South	0	0	0	0	0	
SUM	3	0	0	24	24	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions




Figure 1: PM Emissions trends for North Stack- January 2024




Figure 2: PM Emissions trends for South Stack- January 2024




Figure 4: Sulphur dioxide Emissions trends for North Stack- January 2024




Figure 4: Sulphur dioxide Emissions trends for South Stack- January 2024




Figure 5: Nitrogen dioxide Emissions trends for North Stack- January 2024




Figure 6: Nitrogen dioxide Emissions trends for South Stack- January 2024

7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7 1 PM Start-up information for the month of January-2024

North Stack	Event 1	
Unit No	Unit 5	
Breaker Open (BO)	3 25 PM	01/01/2024
Draught Group (DG) Shut Down (SD)	3 25 PM	01/01/2024
BO to DG SD (duration)		DD HH MM
Fires in time	8 10 AM	06/01/2024
Synch to Grid (or BC)	8 10 PM	06/01/2024
Fires in to BC (duration)	00 12 00	DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD HH MM


South Stack	Event 1	
Unit No	Unit 6	
Breaker Open (BO)	1 25 PM	08/01/2024
Draught Group (DG) Shut Down (SD)	1 25 PM	08/01/2024
BO to DG SD (duration)		DD HH MM
Fires in time	6 30 PM	08/01/2024
Synch to Grid (or BC)	8 30 PM	08/01/2024
Fires in to BC (duration)	00 02 00	DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD HH MM

8 Complaints register


Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Date measure will be implemented	Measures implemented to prevent reoccurrence
The Station did not receive complaints related to air quality during the month of January 2024					

9 General


Hendrina Power Station has noted the exceedances of NO2 for North Stack due to monitor defects and the monitor failure on the South Stack was due to over voltage which damaged the analyser. A contributory factor to monitor issues at Hendrina Power Station is the ageing of the equipment. The station has taken to execute short term and long term mitigations to ensure reliability of the Continuous Emissions Monitoring System. Short term actions include interim repairs and replacement for the damaged equipment - which the Original Equipment Manufacturer contracted with the station is sourcing spares which have lengthy lead times for delivery. For the long term, the station has submitted a request for quote from the Original Equipment Manufacturer for a complete overhaul of the system. An authorisation for this activity shall be sought from the Licencing Authority as per Condition 4.1 of the AEL prior commencement of any activities, including procurement. Following that, the station shall provide progress on to the Licencing Authority on the monthly reports.

 05/03/2024


 Compiled. Environmental Officer Date

 05/03/2024

 Boiler/ FFP Date

B Madipe
 2024/03/07

 Authorised by: GM Date
 T Lekalakala

Moyahabo Cetlyff Mapto
 05/03/2024

 Validated by Manager: Environmental Date
 L Ntula

Compiled by Boiler Engineering Department
 For Nkangala District Municipality
 Copies Eskom Environmental Management
 Group Technology Engineering
 Hendrina Power Station

FFP SE/ Environmental Officer
 Air Quality Officer
 D Herbst
 B Mccourt
 R Rampiar
 E Patel
 Engineering Manager
 Operating Manager
 Maintenance Manager
 Unit Production Manager
 Boiler Engineering Manager
 System Engineer Boiler Engineering
 Environmental Officer
 C & I Engineering Manager
 Production Manager
 Environmental Manager
 PSM