

The Municipal Manager
Gert Sibande District Municipality
PO Box 1748
ERMELO
2350

Date: 10 April 2024

Enquiries: X. Jila

Tel +27 17 749 5100

E-mail: records@gsibande.gov.za
Email: dan.hlanyane@gsibande.gov.za

Dear Mr Hlanyane

TUTUKA POWER STATION MONTHLY REPORT FOR MARCH 2024

This serves as the monthly report required in terms of Section 7.4 of Tutuka Power Station's Atmospheric Emission License (16/4/Lekwa/Eskom H SOC Ltd TPS/0013/2019/f03). The report includes verified emissions for Particulate Matters, Sulphur, and Nitrogen dioxides for the month of March 2024

The report presents monthly trends for each monitored pollutant. Units 3, 4 and 5 were offload for the month of March 2024. There was only one exceedance for Particulate Matter recorded in unit 2 which fell outside the 48-hour period allowed for start-ups, maintenance and shut down. The exceedance was due to a section 30 fire incident that occurred in the electrostatic precipitator board. The rest of the units operated within the limits for PMs and gases.

1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted	Actual Consumption Mar-2024
	Coal	Tons	1 200 000	1 045
	Fuel Oil	Tons	10 000	2763.68
Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Indicative Production Rate Mar-2024
	Energy	GWh	2 611	422.8
	Ash	Tons	350 000	512
	RE Ash	kg/MWh	not specified	1.21

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [3 510 MW] x 24 hrs x days in Month/1000 to convert to GWh



TUTUKA POWER STATION MONTHLY REPORT FOR MARCH 2024

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24	20.920
Sulphur Content	%	0.6 TO 2.6	0.600
Ash Content	%	21 TO 33	26.590

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
Unit 1	300	3400	1200
Unit 2	300	3400	1200
Unit 3	300	3400	1200
Unit 4	300	3400	1200
Unit 5	300	3400	1200
Unit 6	300	3400	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Mar-2024
Unit 1	Electrostatic Precipitators (ESP)	98.0%
Unit 2	Electrostatic Precipitators (ESP)	99.0%
Unit 3	Electrostatic Precipitators (ESP)	99.2%
Unit 4	Electrostatic Precipitators (ESP)	Unit Off
Unit 5	Electrostatic Precipitators (ESP)	Unit Off
Unit 6	Electrostatic Precipitators (ESP)	Unit Off

Note: The ESP does not have bypass mode operating, hence plant considered 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100.0	90.6	100.0	86.4
Unit 2	84.5	16.7	16.7	100.0
Unit 3	100.0	99.6	100.0	98.9
Unit 4	Off	Off	Off	Off
Unit 5	Off	Off	Off	Off
Unit 6	Off	Off	Off	Off

TUTUKA POWER STATION MONTHLY REPORT FOR MARCH 2024

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of March-2024

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	149.6	1 734	599
Unit 2	250.3	2 193	919
Unit 3	111.7	648	402
Unit 4	Off	Off	Off
Unit 5	Off	Off	Off
Unit 6	Off	Off	Off
SUM	511.7	4 575	1 920

Table 6.2: Operating days in compliance to PM AEL Limit - March 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	19	0	0	0	0	183.0
Unit 2	15	2	0	1	3	230.5
Unit 3	12	0	0	0	0	187.7
Unit 4	Off	Off	Off	Off	Off	Off
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	Off	Off	Off	Off	Off	Off
SUM	46	2	0	1	3	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - March 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	22	0	0	0	0	2 118.1
Unit 2	18	0	0	0	0	1 974.6
Unit 3	13	0	0	0	0	1 144.4
Unit 4	Off	Off	Off	Off	Off	Off
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	Off	Off	Off	Off	Off	Off
SUM	53	0	0	0	0	

Table 6.4: Operating days in compliance to NO_x AEL Limit - March 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
Unit 1	22	0	0	0	0	694.9
Unit 2	18	0	0	0	0	827.7
Unit 3	13	0	0	0	0	671.8
Unit 4	Off	Off	Off	Off	Off	Off
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	Off	Off	Off	Off	Off	Off
SUM	53	0	0	0	0	

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

TUTUKA POWER STATION MONTHLY REPORT FOR MARCH 2024

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Tutuka Unit 1 PM Emissions - March 2024





Figure 2: Tutuka Unit 2 PM Emissions - March 2024



[Handwritten signature]

TUTUKA POWER STATION MONTHLY REPORT FOR MARCH 2024

Figure 3: Tutuka Unit 3 PM Emissions - March 2024




Figure 7: Tutuka Unit 1 SO₂ Emissions - March 2024





Figure 8: Tutuka Unit 2 SO₂ Emissions - March 2024



[Handwritten Signature]

TUTUKA POWER STATION MONTHLY REPORT FOR MARCH 2024

Figure 9: Tutuka Unit 3 SO₂ Emissions - March 2024




Figure 13: Tutuka Unit 1 NO_x Emissions - March 2024






Figure 14: Tutuka Unit 2 NO_x Emissions - March 2024



Handwritten signature/initials.

TUTUKA POWER STATION MONTHLY REPORT FOR MARCH 2024



7. COMPLAINTS REGISTER

Source Code/Name	Root Cause Analysis	Calculation of Impacts/emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent recurrence	Date by which measure will be implemented
No complaints were received for the month of March 2024.					

Yours Sincerely

Compiled by:

Xoli Jila

Xoli Jila

EMISSIONS CONTROL OFFICER

Supported by:

Mike Molepo

Mike Molepo

Snr CHEMIST: BOILER ENGINEERING

Approved by:

Bruce Moyo

Bruce Moyo

GENERAL MANAGER

[Handwritten mark]