	Technical and Generic Report	Matimba Power Station
---	-------------------------------------	------------------------------

Title: **Matimba Power Station April 2023
emissions report Rev 1**

Document Identifier: **RP/247/034**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area
Applicability: **Environment**

Revision: **1**

Total Pages: **39**

Report Date: **April 2023**

Disclosure
Classification: **Controlled**


Compiled by



**KH Ramahlare
Senior Advisor
Environment**

Date: 2024-03-26

Functional Responsibility



**MC Mamabolo
Environmental Manager**

Date: 26/03/2024

Authorized by



**Obakeng Mabotja
General Manager**

Date: 2024/03/26

Content

	Page
1. Report Summary	4
2. Emission information	5
2.1 Raw materials and products.....	5
2.2 Abatement technology.....	5
2.3 Energy source characteristics	6
2.4 Emissions reporting.....	6
2.4.1 Particulate Matter Emissions	6
2.4.2 Gaseous Emissions	12
2.4.3 Total Volatile Organic Compounds	24
2.4.4 Greenhouse gas (CO ₂) emissions	25
2.5 Daily power generated	25
2.6 Pollutant Tonnages	31
2.7 Reference values	31
2.8 Continuous Emission Monitors.....	33
2.8.1 Reliability.....	33
2.8.2 Changes, downtime, and repairs	33
2.8.3 Sampling dates and times.....	34
2.9 Units Start-up information	34
2.10 Emergency generation	37
2.11 Complaints register	37
2.12 Air quality improvements and social responsibility conducted	37
2.12.1 Air quality improvements.....	37
2.12.2 Social responsibility conducted.....	37
2.13 Ambient air quality monitoring.....	38
2.14 Electrostatic precipitator and Sulphur plant status	38
2.15 General.....	39
3. Attachments.....	39
4. Report Conclusion	39
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	5
Table 2: Abatement Equipment Control Technology Utilised.....	5
Table 3: Energy Source Material Characteristics.	6
Table 4: Total volatile compound estimates	24
Table 5: Daily power generated per unit in MWh for the month of April 2023.....	25
Table 6: Pollutant tonnages for the month of April 2023	31
Table 7: Operating days in compliance with PM AEL limit of April 2023.....	31
Table 8: Operating days in compliance with SO _x AEL limit of April 2023	32
Table 9: Operating days in compliance with NO _x AEL limit of April 2023.....	32

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 10: Reference values for data provided, April 2023	32
Table 11: Average percentage (%) availability of monitors for the month of April 2023.	33
Table 12: Dates of last conducted CEMS verification tests for PM, SO ₂ and NO _x	34
Table 13: Start-up information	34
Table 14: Emergency generation	37
Table 15: Complaints.....	37

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of April 2023	6
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of April 2023	7
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of April 2023	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of April 2023	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of April 2023	11
Figure 6: SO ₂ daily average emissions against emission limit for unit 1 for the month of April 2023.....	12
Figure 7: SO ₂ daily average emissions against emission limit for unit 2 for the month of April 2023.....	13
Figure 8: SO ₂ daily average emissions against emission limit for unit 3 for the month of April 2023.....	14
Figure 9: SO ₂ daily average emissions against emission limit for unit 4 for the month of April 2023.....	15
Figure 10: SO ₂ daily average emissions against emission limit for unit 6 for the month of April 2023.....	17
Figure 11: NO _x daily average emissions against emission limit for unit 1 for the month of April 2023.....	18
Figure 12: NO _x daily average emissions against emission limit for unit 2 for the month of April 2023.....	19
Figure 13: NO _x daily average emissions against emission limit for unit 3 for the month of April 2023.....	20
Figure 14: NO _x daily average emissions against emission limit for unit 4 for the month of April 2023.....	21
Figure 15: NO _x daily average emissions against emission limit for unit 6 for the month of April 2023.....	23
Figure 16: Unit 1 daily generated power in MWh for the month of April 2023.....	26
Figure 17: Unit 2 daily generated power in MWh for the month of April 2023.....	27
Figure 18: Unit 3 daily generated power in MWh for the month of April 2023.....	28
Figure 19: Unit 4 daily generated power in MWh for the month of April 2023.....	29
Figure 20: Unit 6 daily generated power in MWh for the month of April 2023.....	30

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report is the revision 1 of the report issued containing the required information as specified in the license for April 2023. The revision 1 is issued due to the changes applied to the Matimba Emission Reporting tool for the usage of surrogate particulate emissions values when monitors exceed their range due to high actual emissions using the Deutsch calculation. The information recorded in the original report April 2023 was from Matimba Emission Reporting tool V12.2021 and the information on revision 1 April 2023 is from Matimba Emission Reporting tool V02.2024FD.



During the period under review, Matimba experienced ninety-two (92) exceedances of the daily particulate matter emission limit (50mg/Nm³), sixty-one (61) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. Thirty-one (31) exceedances occurred within the grace period.

The flue gas conditioning (Sulphur trioxide plant (SO₃ plant)) for unit 1,3,4 and unit 6 did not achieve the required 100% availability as results of online maintenance that occurred during the month, on average the plant was available for 96% of the time. Matimba Unit 5 has been off load for long-term maintenance outage since the 20th of March 2023.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month.

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	853 241
	Fuel Oil	Tons/month	1 200	2125,566
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	1997,273

The consumption rates for the month of April 2023 exceeded the permitted maximum limits of 1200 Tons due to defective pyrometers used to detect the flames in the boiler resulting in requirement to constantly supporting the combustion with fuel oil. The unit ended the month with the fuel oil usage of 2125,566 Tons.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99,732%
Unit 2	Electrostatic Precipitator	100%	99,701%
Unit 3	Electrostatic Precipitator	100%	99,817%
Unit 4	Electrostatic Precipitator	100%	99,856%
Unit 5	Electrostatic Precipitator	100%	Unit Off
Unit 6	Electrostatic Precipitator	100%	99,898%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	99,48%
Unit 2	SO ₃ Plant	100%	100%
Unit 3	SO ₃ Plant	100%	99,23%
Unit 4	SO ₃ Plant	100%	93,76%
Unit 5	SO ₃ Plant	100%	Unit Off
Unit 6	SO ₃ Plant	100%	95,68%

Flue gas conditioning plant availability was below the required 100% for all six (06) units due to maintenance activities and unplanned breakdowns. Defects were addressed and plants returned to services.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3 Energy source characteristics

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1,33%
	Ash Content	40%	34,60%

Energy source characteristics remained within the ranges stipulated in the license.

2.4 Emissions reporting

2.4.1 Particulate Matter Emissions

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of April 2023

Interpretation:

Unit 1 exceeded the daily particulate emission limit of 50mg/Nm³ on 3,6 to 13 and 15 to 18 and 20 to 30 April 2023. Exceedances from 8 to 13, 17,18,21 to 30 April 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of April 2023

Interpretation:

Unit 2 exceeded the daily particulate emission limit of 50mg/Nm³ on 3, 5 to 28 and 30 April 2023. Exceedances from 7 to 19 and 25 to 28 April 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of April 2023

Interpretation:

Unit 3 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 8 to 12, 14 to 17, 20, 22, 23, 25 and 26 April 2023. Exceedances from the 10 to 12, 16 and 17 April 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 Particulate Emissions

Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of April 2023

Interpretation:

Unit 4 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 2 to 4, 8 to 29 April 2023. Exceedances from 12 to 29 April 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 Particulate Emissions

Unit 5 on outage.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 Particulate Emissions

Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of April 2023

Interpretation:

Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 17 to 19, 21, 23 to 26 April 2023. Exceedances of 19, 25 and 26 April 2023 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.2 Gaseous Emissions

Gaseous emissions analyzers for all 6 units are providing unreliable data due to the movement of the Oxygen analyzer ports that were previously installed incorrectly to a new correct position.

The station completed the project to relocate the Oxygen analyzer ports in November 2022 as part of the activities to implement the changes on gaseous emission analyzers to improve the reliability of the data.

The station is currently preparing to perform the quality assurance tests and calibrations on the monitors post the changes implemented.

Unit 1 SO₂ Emissions




Figure 6: SO₂ daily average emissions against emission limit for unit 1 for the month of April 2023


Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO₂ Emissions**Figure 7: SO₂ daily average emissions against emission limit for unit 2 for the month of April 2023****Interpretation:**

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 SO₂ Emissions

Figure 8: SO₂ daily average emissions against emission limit for unit 3 for the month of April 2023


Interpretation:

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO₂ Emissions**Figure 9: SO₂ daily average emissions against emission limit for unit 4 for the month of April 2023****Interpretation:**

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 5 SO₂ Emissions

Unit 5 off load for outage

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 SO₂ Emissions**Figure 10: SO₂ daily average emissions against emission limit for unit 6 for the month of April 2023****Interpretation:**

All daily averages remained below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 1 NO_x Emissions**Figure 11: NO_x daily average emissions against emission limit for unit 1 for the month of April 2023****Interpretation:**

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO_x Emissions**Figure 12: NO_x daily average emissions against emission limit for unit 2 for the month of April 2023****Interpretation:**

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 3 NO_x Emissions**Figure 13: NO_x daily average emissions against emission limit for unit 3 for the month of April 2023****Interpretation:**

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 NO_x Emissions**Figure 14: NO_x daily average emissions against emission limit for unit 4 for the month of April 2023****Interpretation:**

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO_x Emissions

Unit 5 off load for outage

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 NO_x Emissions

Figure 15: NO_x daily average emissions against emission limit for unit 6 for the month of April 2023

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Thursday, 01 June 2023	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the blue cells below</p> <p align="center">Choose from a dropdown menu in the green cells</p> <p align="center">The total VOC emissions for the month are in the red cells</p> <p align="center">IMPORTANT: Do not change any other cells without consulting the AQ CoE</p>		
MONTH:	April	
GENERAL INFORMATION:	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13,34	m
Diameter of tank:	9,53	m
Net fuel oil throughput for the month:	2125,566	
Molecular weight of the fuel oil:	166,00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH	Data	Unit
Daily average ambient temperature	20,60	°C
Daily maximum ambient temperature	27,37	°C
Daily minimum ambient temperature	13,11	°C
Daily ambient temperature range	10,46	°C
Daily total insolation factor	3,84	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0,68	NA
FINAL OUTPUT:	Result	Unit
Breathing losses:	0,48 kg/month	
Working losses:	0,06 kg/month	
TOTAL LOSSES (Total TVOC Emissions for the month):	0,54 kg/month	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chew Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.4.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.5 Daily power generated

Table 5: Daily power generated per unit in MWh for the month of April 2023

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2023/04/01	11420,5	10330,6	13568,7	10440,6		
2023/04/02	12229,6	10777,9	12911,9	10271,9		10781,1
2023/04/03	11024,8	10467,3	12030,5	9908,34		11057,1
2023/04/04	10372,7	10262,7	12360,9	5753,06		11436,5
2023/04/05	12044,3	10760,6	11789,6	11539,1		12022,1
2023/04/06	10195	9794,36	12419,5	11263,7		11603,9
2023/04/07	9245,08	8646,93	148,62	10185,6		11995,7
2023/04/08	8435,01	8630,32	11172,3	7124,63		11312
2023/04/09	8420,28	8655,54	13577,7			11908,2
2023/04/10	8427,94	8670,44	13082	8025,47		11173,8
2023/04/11	8415,32	8692,01	9774,11	10337		11732,2
2023/04/12	8438,16	8703,89	8463,95	10421,3		12071,6
2023/04/13	9730,65	8789,07	12920	10452,4		12015,3
2023/04/14	10325,6	9324,91	11771,9	10226,8		11756,7
2023/04/15	10409	9354,92	10295,9	10134,9		10338,6
2023/04/16	10316,7	9378,41	10313	9271,05		10261,2
2023/04/17	10111,8	9375,58	10187,6	8448,84		11334,8
2023/04/18	8658,72	9351,81	11301,6	8443,64		10648,9
2023/04/19	2523,04	9247,83	11560,7	8469,96		11390,3
2023/04/20	10663,8		11929,8	9542,9		12008,6
2023/04/21	8289,28		8055,29	10566,8		12055,9
2023/04/22	10026,1	7041,26	9264,49	10212,4		11264
2023/04/23	8642,79	10196,4	11233,1	9619,08		10859,5
2023/04/24	8650,71	10215,2	12211,9	9569,11		10499,9
2023/04/25	8639,58	10217,3	12396,6	9478,83		10532,3
2023/04/26	8625,87	10218,1	10519,9	9432,04		9749,9
2023/04/27	8643,53	10209,6	10481,2	9631,12		
2023/04/28	8644,02	10344,2	12405,8	9736,81		
2023/04/29	8641,37	10099,7	12491,5	9977,1		
2023/04/30	9057,83	10156,4	12162,2	9740,93		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 16: Unit 1 daily generated power in MWh for the month of April 2023

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 17: Unit 2 daily generated power in MWh for the month of April 2023

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 18: Unit 3 daily generated power in MWh for the month of April 2023

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 19: Unit 4 daily generated power in MWh for the month of April 2023

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 6 daily generated power in MWh for the month of April 2023

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Pollutant Tonnes

The emitted pollutant tonnages for April 2023 are provided in table 6. Gaseous emissions analysers for all 6 units are providing unreliable data due to the movement of the Oxygen analyser port to a new position. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

Table 6: Pollutant tonnages for the month of April 2023

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	165.6	4 151.4	636.1
Unit 2	771.6	5 631.8	759.5
Unit 3	105.3	5 623.6	832.3
Unit 4	72.8	4 562.6	773.0
Unit 5	Off	Off	Off
Unit 6	53.8	3 426.2	521.5
SUM	1 169.1	23 395.6	3 522.4

2.7 Operating days in compliance to PM AEL Limit

Table 7: Operating days in compliance with PM AEL limit of April 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	6	6	0	18	24	115.3
Unit 2	4	6	0	17	23	488.6
Unit 3	15	9	0	5	14	58.9
Unit 4	5	5	0	18	23	70.8
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	16	5	0	3	8	39.6
SUM	46	31	0	61	92	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Operating days in compliance to SO_x AEL Limit

Table 8: Operating days in compliance with SO_x AEL limit of April 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	30	0	0	0	0	2 295.1
Unit 2	28	0	0	0	0	2 880.2
Unit 3	30	0	0	0	0	2 302.1
Unit 4	29	0	0	0	0	2 750.2
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	25	0	0	0	0	1 836.9
SUM	142	0	0	0	0	

2.9 Operating days in compliance to NO_x AEL Limit

Table 9: Operating days in compliance with NO_x AEL limit of April 2023

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
Unit 1	30	0	0	0	0	349.4
Unit 2	28	0	0	0	0	388.5
Unit 3	30	0	0	0	0	339.3
Unit 4	29	0	0	0	0	465.8
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	25	0	0	0	0	279.6
SUM	142	0	0	0	0	

2.10 Reference values

Table 10: Reference values for data provided, April 2023

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	6.98	9.65	4.18	7.91	Off	5.91
Moisture	%	4.34	3.83	5.65	2.95	Off	1.94
Velocity	m/s	22.2	30.2	25.6	22.3	Off	27.0
Temperature	°C	139.8	123.3	128.6	127.6	Off	166.8
Pressure	mBar	932.5	936.0	919.3	925.8	Off	914.6

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.11 Continuous Emission Monitors

2.11.1 Reliability

Continuous emission monitors were available for more than 80% of the reporting period. The emitted pollutant tonnages for April 2023 are provided in table 6. Gaseous emissions analysers for all 6 units are providing unreliable data due to the movement of the Oxygen analyser port to a new position. Matimba is currently in the process of implementing recommended changes on gaseous emission analysers to improve the reliability of the data.

Table 11: Average percentage (%) availability of monitors for the month of April 2023.

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	81,7	100,0	100,0
Unit 2	63,6	100,0	98,9
Unit 3	100,0	100,0	100,0
Unit 4	100,0	100,0	100,0
Unit 5	Off	Off	Off
Unit 6	100,0	86,0	86,0

2.11.2 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 2

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 3

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 4

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 5

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.
- No downtime or repairs done on the particulate monitors

Unit 6

- No adjustments done on the CEMs. Calibration of gaseous analysers is done every second week.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

- No downtime or repairs done on the particulate monitors

2.11.3 Sampling dates and times

Table 12: Dates of last conducted CEMS verification tests for PM, SO₂ and NO_x

Name of service provider:		Stacklabs Environmental Services CC		
Address of service provider:		10 Chisel Street Boltonia Krugersdorp 1739		
Stack/ Unit	PM	SO₂	NO_x	CO₂
1	2020/09/30 06h04	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00
2	2021/01/26 04h52	2021/01/27 13h00	2021/01/27 13h00	2021/01/27 13h00
3	2021/08/10 12h05	2020/09/24 07h00	2020/09/24 07h00	2020/09/24 07h00
4	2021/07/13 14h31	2020/09/16 02h00	2020/09/16 02h00	2020/09/16 02h00
5	2020/10/06 05h39	2020/10/08 02h30	2020/10/08 02h30	2020/10/08 02h30
6	2020/09/09 06h41	2020/09/09 13h00	2020/09/09 13h00	2020/09/09 13h00

2.12 Units Start-up information

Table 13: Start-up information

Unit	1	
Fires in	2023/04/19	11h36
Synchronization with Grid	2023/04/19	14h40
Emissions below limit	2023/04/19	15h01
Fires in to synchronization	3,4	HOURS
Synchronization to < Emission limit	0,21	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	1	
Fires in	2023/04/20	14h49
Synchronization with Grid	2023/04/20	16h12
Emissions below limit	2023/04/20	21h12
Fires in to synchronization	1,23	HOURS
Synchronization to < Emission limit	5,0	HOURS

Unit	2	
Fires in	2023/04/07	14h14
Synchronization with Grid	2023/04/08	00h49
Emissions below limit	2023/04/22	14h02
Fires in to synchronization	10,35	HOURS
Synchronization to < Emission limit	349,13	HOURS

Unit	3	
Fires in	2023/04/07	04h50
Synchronization with Grid	2023/04/08	08h43
Emissions below limit	2023/04/11	20h02
Fires in to synchronization	27,53	HOURS
Synchronization to < Emission limit	83,19	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	3	
Fires in	2023/04/12	03h16
Synchronization with Grid	2023/4/12	06h50
Emissions below limit	2023/04/12	18h02
Fires in to synchronization	3,47	HOURS
Synchronization to < Emission limit	11,12	HOURS

Unit	4	
Fires in	2023/04/04	10h54
Synchronization with Grid	2023/04/04	13h37
Emissions below limit	2023/04/04	16h04
Fires in to synchronization	2,43	HOURS
Synchronization to < Emission limit	2,27	HOURS

Unit	4	
Fires in	2023/04/09	22h09
Synchronization with Grid	2023/04/10	01h38
Emissions below limit	2023/04/11	04h04
Fires in to synchronization	3,29	HOURS
Synchronization to < Emission limit	26,26	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.13 Emergency generation

Table 14: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	720	720	720	720	Off	720
Emergency Hours declared including hours after stand down						
Days over the Limit during Emergency Generation	24	23	14	23	Off	8

During the period under review all Units were on emergency generation in force from 01 April 2023 until 30 April 2023.

2.14 Complaints register.

Table 15: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
N/A					

2.15 Air quality improvements and social responsibility conducted.

2.15.1 Air quality improvements

None

2.15.2 Social responsibility conducted.

None

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.16 Ambient air quality monitoring

Ambient air quality monitoring report was not available at the time of publishing this report.

2.17 Electrostatic precipitator and Sulphur plant status

Unit 1

- 3 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 2

- 2 fields out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 3

- All precipitator fields in service. Unit shut down for outage
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 4

- 3 field out of service, will be inspected next opportunity.
- No abnormalities on the SO3 plant. Preventative maintenance done during the month.

Unit 5

- On outage.

Unit 6

- 2 fields out of service, will be inspected next opportunity.
- Hole in burner casing and sulphur leak causing low availability. Preventative maintenance done during the month.

SO3 common plant

- No abnormalities on the sulphur storage plant.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.18 General

Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

None

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.