



Generation

Nkangala District Municipality
P O Box 437
Middleburg
1050

Attention:

Mr V Mahlangu

AND

Directorate: Air Quality Management Services
The Director:
Mr Vumile Senene
Department of Environmental Affairs
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Date: 2024/03/25

Enquiries: Lufuno Tshidzamba-Matla Environmental
☎ +27 17 612 6263

Enquiries: Lindokuhle Ngobese
☎ +27 17 612 6291


Total number of pages:
16

Total number of annexes:

MATLA POWER STATION

Atmospheric Emission License 17/4/AEL/MP312/11/14



BOILER ENGINEERING MANAGER


ENVIRONMENTAL MANAGER


ENGINEERING MANAGER

26/08/2024

DATE

26/03/2024

DATE

26/03/2024

DATE

MATLA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/14


1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Feb-2024
	Coal	Tons	1 475 000	844 860
	Fuel Oil	Tons	3 500	436
Production Rates	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Feb-2024
	Energy	GWh	2 568	1 504
	Ash	Tons	471 000	241 377
	RE PM	kg/MWh	not specified	1.032

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [3 690 MW] x 24 hrs x days in Month/1000 to convert to GWh

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.8-1.1	1.00
Ash Content	%	21-40	28.57

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO
South	200	3500	1200
Unit 4	200	3500	1200
Unit 5	100	3500	1200
Unit 6	100	3500	1200

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Feb-2024
South	Electro Static Precipators (ESP)	99.582%
Unit 4	Electro Static Precipators (ESP)	99.261%
Unit 5	Electro Static Precipators (ESP)	99.867%
Unit 6	Electro Static Precipators (ESP)	97.784%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 DATA RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
South	97.8	100.0	100.0	100.0
Unit 4	99.7	99.2	99.2	99.0
Unit 5	99.6	100.0	100.0	99.9
Unit 6	63.4	100.0	100.0	99.8

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of February-2024

Associated Unit/Stack	PM	SO ₂	NOx
Unit 1	Exempt	0.0	0.0
Unit 2	244.8	4 070.0	1 502.9
Unit 3	154.8	2 594.3	957.1
Unit 4	326.9	2 877.1	828.8
Unit 5	56.6	2 617.6	815.8
Unit 6	769.6	2 074.4	738.2
SUM	1 552.7	14 233.4	4 842.8

Table 6.2: Operating days in compliance to PM AEL Limit - February 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
South	27	2	0	0	2	104.4
Unit 4	15	3	0	9	12	215.6
Unit 5	28	1	0	0	1	41.7
Unit 6	14	3	8	0	11	706.6
SUM	84	9	8	9	26	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - February 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
South	29	0	0	0	0	1 736.3
Unit 4	28	0	0	0	0	1 766.1
Unit 5	29	0	0	0	0	1 975.6
Unit 6	27	0	0	0	0	1 798.2
SUM	113	0	0	0	0	

Table 6.4: Operating days in compliance to NO_x AEL Limit - February 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
South	29	0	0	0	0	640.8
Unit 4	28	0	0	0	0	508.4
Unit 5	29	0	0	0	0	617.4
Unit 6	27	0	0	0	0	625.0
SUM	113	0	0	0	0	

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Matla South Stack PM Emissions - February 2024




Figure 2: Matla Unit 4 PM Emissions - February 2024




Figure 3: Matla Unit 5 PM Emissions - February 2024




Figure 4: Matla Unit 6 PM Emissions - February 2024




Figure 5: Matla South Stack SO₂ Emissions - February 2024




Figure 6: Matla Unit 4 SO₂ Emissions - February 2024




Figure 7: Matla Unit 5 SO₂ Emissions - February 2024




Figure 8: Matla Unit 6 SO₂ Emissions - February 2024




Figure 9: Matla South Stack NOx Emissions - February 2024




Figure 10: Matla Unit 4 NOx Emissions - February 2024




Figure 11: Matla Unit 5 NOx Emissions - February 2024





Figure 12: Matla Unit 6 NOx Emissions - February 2024



7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of February-2024

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	no event		no event		no event		no event	
Breaker Open (BO)	1:20 AM	2024/03/02						
Draught Group (DG) Shut Down (SD)	5:30 AM	2024/03/02						
BO to DG SD (duration)	00:04:10	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

South Stack ...cont.	Event 5		Event 6		Event 7		Event 8	
Unit No.	no event		no event		no event		no event	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 4	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	BO previously	BO previously	BO previously	BO previously				
Draught Group (DG) Shut Down (SD)	n/a	n/a	n/a	n/a				
BO to DG SD (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 5	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	BO previously	BO previously						
Draught Group (DG) Shut Down (SD)	n/a	n/a						
BO to DG SD (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time								
Synch. to Grid (or BC)								
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)								
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM


Unit No. 6	Event 1		Event 2		Event 3		Event 4	
Breaker Open (BO)	11:15 PM	2024/02/16	5:30 PM	2024/02/25	6:00 PM	2024/02/29		
Draught Group (DG) Shut Down (SD)	4:55 PM	2024/02/18	5:30 PM	2024/02/25	6:00 PM	2024/02/29		
BO to DG SD (duration)	01:17:40	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time	5:10 PM	2024/02/18	7:15 PM	2024/02/25	6:00 PM	2024/02/29		
Synch. to Grid (or BC)	5:00 PM	2024/02/19	5:10 PM	2024/02/26	8:10 AM	2024/03/01		
Fires in to BC (duration)	00:23:50	DD:HH:MM	00:21:55	DD:HH:MM	00:14:10	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit	not > limit	not > limit		
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM


7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of February-2024 in mg/Nm³

11 General

Unit 6 PM reliability below 80% due to high emissions during RH precipitator cable repairs.
Unit 5 PM correlation expired and target date to complete testing is 26 April 2024
Unit 6 PM correlation expired and target date to complete testing is 26 April 2024


Boiler Engineering
Date 24/03/2024


General Manager
Date 26/03/2024


Environmental Department
Date

Compiled by: Boiler Engineering Department

For: Department of Environmental Affairs and Tourism

Copies: Eskom Environmental Management

Group Technology Engineering

Matla Power Station:

ESP & SO₃ System Engineer

Chief Air Pollution Control Officer

D Herbst
B Mccourt

R Rampiar
E. Patel

Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager
System Engineer
Environmental Officer
Performance and Test
Production Manager