

Ms Nompumelelo Simelane
Nkangala District
P.O Box 437
MIDDLEBERG
1050
By email: SimelaneNl@nkangaladm.gov.za

Date: 13 May 2024
Enquiries: S Chokoe
Tel +27 13 647 6970


Dear Ms. Nompumelelo Simelane

Ref: Kendal Power Station AEL (17/4/AEL/MP312/11/15)

SUBMISSION OF KENDAL POWER STATION'S EMISSIONS REPORT FOR THE MONTH OF APRIL 2024.

This is a monthly report required in terms of Section 7.4 in the Kendal Power Station's Atmospheric Emission License. The emissions are for Eskom Kendal Power Station.

Compiled by:



Tsakani Holeni

ENVIRONMENTAL SENIOR ADVISOR- KENDAL POWER STATION

Date: 13.05.2024

Supported by:




Solly Chokoe

ENVIRONMENTAL MANAGER- KENDAL POWER STATION

Date: 14.05.2024

Generation Division
Kendal Power Station
N12 Balmoral Off Ramp, Emalahleni
Private Bag x7272, Emalahleni 1035 SA
Tel +27 13 647 6970 Fax +27 13 647 6904 www.eskom.co.za

Verified by:




Jacob Zwane
BOILER ENGINEERING: SENIOR SYSTEM ENGINEER- KENDAL POWER STATION
Date: 15/05/2024

Validated by:



Tendani Rasivhetshele
BOILER ENGINEERING MANAGER-KENDAL POWER STATION
Date: 15/05/2024

Supported by:




Nomfundo Mtshali
ACTING ENGINEERING MANAGER-KENDAL POWER STATION
Date: 2024/05/15

Approved by:



Tshepiso Temo
GENERAL MANAGER-KENDAL POWER STATION
Date: 2024/05/24



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate Apr-2024	Production Rates		
				Product / By-Product Name	Energy	RE Ash
Coal	Coal	Tons	2 260 000	Maximum Production	2 983 520	kg/MWh
	Fuel Oil	Tons	5 000	Capacity Permitted	770 000	Tons
Indicative Production Rate Apr-2024				Indicative Production Rate Apr-2024	1 236 651	2 181
					241 605 630	not specified

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [4 116 MW] x 24 hrs x days in Month/1000 to convert to GWh

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24 (MJ/kg)	18 580
Sulphur Content	%	<1 (%)	0.770
Ash Content	%	40 (%)	33.430

3 EMISSION LIMITS (mg/Mm³)

Associated Unitstack	PM	SO _x	NO _x
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated UnitStack	Technology Type	Efficiency Apr-2024	Technology Type	SO ₂ Utilization Apr-2024
Unit 1	ESP + SO ₂	95.375%	SO ₂	0.0%
Unit 2	ESP + SO ₂	99.229%	SO ₂	0.0%
Unit 3	ESP + SO ₂	99.828%	SO ₂	0.0%
Unit 4	ESP + SO ₂	99.450%	SO ₂	0.0%
Unit 5	ESP + SO ₂	97.672%	SO ₂	0.0%
Unit 6	ESP + SO ₂	Off-line	SO ₂	Off-line

Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.

There is no value for SO₃ utilization due to switch failure on the server, however Kendal Sulfur utilisation database will be ready once we have commissioned the new FI system.

5 MONITOR RELIABILITY (%)

Associated UnitStack	PM	SO ₂	NO	O ₂
Unit 1	69.6	100.0	100.0	20.3
Unit 2	86.2	94.2	95.0	81.0
Unit 3	97.8	100.0	100.0	97.2
Unit 4	100.0	100.0	100.0	0.0
Unit 5	100.0	80.3	87.5	0.0
Unit 6	Off	Off	Off	Off

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂ Unit 1, 4 and 5 O₂ monitor was defective

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of April 2024


Associated UnitStack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	1 399.8	2 056.8	846
Unit 2	350.9	3 876	1 808
Unit 3	4 271	96.9	1 767
Unit 4	2 155	177.9	910
Unit 5	671.2	995	556
Unit 6	Off	Off	Off
SUM	2 696.57	13 364	5 890

Table 6.2: Operating days in compliance to PM AEL Limit - April 2024


Associated UnitStack	Normal	Grace	Section 30	Contraven	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	0	0	0	15	15	1 388.1
Unit 2	0	0	0	29	29	234.4
Unit 3	0	0	0	3	3	58.6
Unit 4	0	0	0	7	7	175.3
Unit 5	0	0	0	3	3	796.3
Unit 6	Off	Off	Off	Off	Off	Off
SUM	1	6	0	57	63	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - April 2024

Associated UnitStack	Normal	Grace	Section 30	Contraven	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	22	0	0	0	0	1 736.3
Unit 2	30	0	0	0	0	2 453.1
Unit 3	30	0	0	0	0	2 579.2
Unit 4	21	0	0	0	0	2 055.2
Unit 5	20	0	0	0	0	1 010.0
Unit 6	Off	Off	Off	Off	Off	Off
SUM	123	0	0	0	0	



High emissions can be attributed to the SO3 plant that was on hold mode due to low steam temperature, poor precip field performance, DHP off due to bucket elevator flopper gate that lost open limit. The DHP also tripped due to compartment levels that were high.



High emissions can be attributed to the fault and unit on start up (cold start). Precip field no 24, 33 and 35 had communication bus fault and tripping and SO3 failed to start due steam inlet temperature that was low. DHP also tripped due to compartments high level.



Condition	Colour	Description
Normal	GREEN	Emissions below Emission Limit Value (ELV)
Grace	BLUE	Emissions above the ELV during grace period
Section 30	ORANGE	Emissions above ELV during a NEMA S30 incident
Contravention	RED	Emissions above ELV but outside grace or S30 incident conditions

Table 6.5: Legend Description


Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	22	0	0	0	0	701.1
Unit 2	16	0	0	0	14	1 120.4
Unit 3	19	0	0	0	11	1 068.7
Unit 4	21	0	0	0	0	852.2
Unit 5	20	0	0	0	0	572.2
Unit 6	Off	Off	Off	Off	Off	Off
SUM	98	0	0	0	25	

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂


Table 6.4: Operating days in compliance to NOx AEL Limit - April 2024






High PM emissions can be attributed to unit right up conditions and the SO3 plant that was not available, DHP conveyor was off due to stream 1 bucket elevator that was tripping, DHP stream 2 and 3 was not available, field 3, 2, 3, 4 and 5 secondary voltage was low, field 35 contactor error, field 42 and 43 communication bus fault and the other that are under performing.











High PM emissions can be attributed to the DHP stream 2 bucket elevator that tripped, SO3 stopped from outside plant due to pipe leak, field 42 was faulty and SO3 plant on hold mode due to burner outlet temperature that was low.



High PM emissions can be attributed to SO3 plant that was on hold mode due to our steam temperature that was low, SO3 plant was also off due to heater being off.







7 COMPLAINTS

There were no complaints for this month

Source Code / Root Cause Analysis Name	Calculation of impacts / emissions associated where applicable	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

Abatement Technology-Table 4	
In order to achieve the required operational dust removal efficiency based on measured values, several assumptions such as	
☐ Coal ash content (%) and burnt rate mass	
☐ Fly : Coarse ash ratio of 80:20 - 80% of fly-ash mass obtained from burnt coal goes to ESP	
☐ Measurement of dust emission by Dust Monitor over a period of time (monthly)	
Operational Dust Removal Efficiency	
$\eta = (1 - (\text{Output/Input})) \times 100$	
$\eta = 1 - ((\text{DustEmissionFromAQH ReportDustMonitor})(\text{tons}) \times 100 / (\text{CoalBurnt}(\text{tons}) \times \text{AshContent} \times 80\%))$	
Monitor Reliability-Table 5	
In terms of the minimum emissions standard, the requirement is that a monitor should be 80% reliable on a monthly average.	
The monitor reliability refers to data reliability because the assumed value of 99.325% reliability is compared to the dust concentration signal. If the dust concentration signal is above 99.325% opacity, the data information is no longer reliable because the monitor reading is out of its maximum reading range. The data reliability looks at how many times did the dust concentration signal go above 98% over a period of time e.g 24hours	
The formula is as follows: $= (1 - (\text{count hours above } 99.325\% / 24\text{hours})) \times 100$	
Emissions Performance:	
Average velocity values from the latest correlation report were used on the gaseous emissions on Unit 1, 2, 4, 5 & 6 due to defective	
CEM5 monitors and velocity correction factors were set M=1 and C=0	
Average emissions for unit 1 NOx from the 1st to the 3rd were used from the available data as the monitor was defective.	
Average emissions for Unit 1 O2 from the 1st to the 9th were used from the available data as the monitor was defective.	
Unit 1	
Findings: The high emissions can be attributed to the unit on start up (cold start), Precipit field no 24, 33 and 35 had communication buss fault and Precipit field no 21 circuit breaker was faulty, Precipit chain conveyor 23 kept tripping and SO3 failed to start due steam inlet temperature was low. DHP also tripped due to compartments high level.	
Unit 2	
Findings: The high emissions can be attributed to the SO3 plant that was on hold mode due to low steam temperature, poor precip fields performance, DHP off due to bucket elevator flopper gate that lost open limit. The DHP also tripped due to compartment levels that were high.	
Unit 3	
Findings: The high PM emissions can be attributed to SO3 plant that was on hold mode due to aux steam temperature that was low, SO3 plant was off due to the heater that was off.	
Unit 4	
Findings: High PM emissions can be attributed to the DHP stream 2 bucket elevator that tripped, SO3 that stopped from outside plant due to pipe leak, Field 45 was faulty and SO3 plant that was on hold mode due to burner outlet temperature that was low.	
Unit 5	
Findings: High PM emissions can be attributed to unit light up conditions and the SO3 plant that was not available, DHP conveyor was off due to stream 1 bucket elevator that was tripping, DHP stream 1 and 2 was not available, Field 31, 32, 34 and 36 secondary voltage was low, Field 35 contactor error, Field 42 and 43 Communication bus fault and the other that are under performing.	
Unit 6- Unit off.	