

Nkangala District Municipality
P O Box 437
Middleburg
1050

Attention:

Mr V Mahlangu

AND

Directorate: Air Quality Management Services
The Chief Director:
Mr S S Maluleka
Department of Environmental Services
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

DUVHA POWER STATION

Atmospheric Emission License 17/4/AEL/MP312/11/07



GENERAL MANAGER

Date: 2024/04/15

Enquiries: Duvha Environmental Management

☎ +27 13 690 0445

📠 +27 66 212 2105

Enquiries: Ms Simthandile Nhlapo

☎ +27 13 690 0445

📠 +27 66 212 2105

Total number of pages: 21

Total number of annexes: 0

2024/05/22

DATE



**JANUARY
2024**

DUVHA POWER STATION MONTHLY EMISSIONS REPORT
Atmospheric Emission License 17/4/AEL/MP312/11/07



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Jan-2024
	Coal	Tons	1 400 000	472637.53
	Fuel Oil	Tons	5 000	6296.55
Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate Jan-2024
	Energy	GWh	2 505.600	795.12
	Ash	Tons	not specified	119530.03

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [3 600 MW] x 24 hrs x days in Month/1000 to convert to GWh

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 TO >1.2	0.68
Ash Content	%	27 TO 30	25.29

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NOx
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jan-2024	Technology Type	SO ₃ Utilization Jan-2024
Unit 1	FFP	Off	SO ₃	n/a
Unit 2	FFP	100.0%	SO ₃	n/a
Unit 4	ESP + SO ₃	99.8%	SO ₃	99.6%
Unit 5	ESP + SO ₃	99.6%	SO ₃	100.0%
Unit 6	ESP + SO ₃	99.7%	SO ₃	100.0%
Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.				

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	<i>Unit Off</i>	<i>Unit Off</i>	<i>Unit Off</i>	<i>Unit Off</i>
Unit 2	<i>92.9</i>	<i>99.8</i>	<i>99.8</i>	<i>100.0</i>
Unit 4	<i>100.0</i>	<i>82.1</i>	<i>82.1</i>	<i>85.6</i>
Unit 5	<i>100.0</i>	<i>84.1</i>	<i>81.4</i>	<i>100.0</i>
Unit 6	<i>100.0</i>	<i>98.8</i>	<i>98.8</i>	<i>100.0</i>

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of January 2024

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	Unit off	Unit off	Unit off
Unit 2	8.2	2 024	714
Unit 4	49.6	1 386	635
Unit 5	114.4	2 016	759
Unit 6	86.2	2 067	1 177
SUM	258.43	7 494	3 285

Table 6 2 Operating days in compliance to PM AEL Limit - January 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1		0	0	0	0	
Unit 2	21	0	0	0	0	8 3
Unit 4	19	3	0	0	3	53 3
Unit 5	25	2	0	0	3	84 3
Unit 6	20	3	0	0	3	66 3
SUM	85	8	0	0	9	

Table 6 3 Operating days in compliance to SO₂ AEL Limit - January 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	Unit off	Unit off	Unit off	Unit off	Unit off	
Unit 2	23	0	0	0	0	1 736 4
Unit 4	24	0	0	0	0	1 296 2
Unit 5	28	0	0	0	0	1 443 7
Unit 6	24	0	0	0	0	1 431 6
SUM	99	0	0	0	0	

Table 6.4: Operating days in compliance to NO_x AEL Limit - January 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
Unit 1	Unit off	Unit off	Unit off	Unit off	Unit off	
Unit 2	23	0	0	0	0	604.8
Unit 4	24	0	0	0	0	584.2
Unit 5	28	0	0	0	0	536.0
Unit 6	24	0	0	0	0	807.6
SUM	99	0	0	0	0	

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 1 PM Emissions - January 2024




Figure 2: Duvha Unit 2 PM Emissions - January 2024




Figure 3: Duvha Unit 4 PM Emissions - January 2024




Figure 4: Duvha Unit 5 PM Emissions - January 2024




Figure 5: Duvha Unit 6 PM Emissions - January 2024




Figure 6: Duvha Unit 1 SO₂ Emissions - January 2024




Figure 7: Duvha Unit 2 SO₂ Emissions - January 2024




Figure 8: Duvha Unit 4 SO₂ Emissions - January 2024




Figure 9: Duvha Unit 5 SO₂ Emissions - January 2024




Figure 10: Duvha Unit 6 SO₂ Emissions - January 2024




Figure 11: Duvha Unit 1 NOx Emissions - January 2024




Figure 12: Duvha Unit 2 NOx Emissions - January 2024




Figure 13: Duvha Unit 4 NOx Emissions - January 2024




Figure 14: Duvha Unit 5 NOx Emissions - January 2024





Figure 15: Duvha Unit 6 NOx Emissions - January 2024



7 SHUT DOWN AND LIGHT UP INFORMATION

Tables 7.1: Shut-down and light-up information for the month of January 2024

Unit No.2	Event 1	Event 2		
Breaker Open (BO)	BO previously	BO previously	7:10 am	2024/01/19
Draught Group (DG) Shut Down (SD)	n/a	n/a	2:15 am	2024/01/20
BO to DG SD (duration)	n/a	DD:HH:MM	00:19:05	DD:HH:MM
Fires in time	12:45 am	2024/01/02	5:05 am	2024/01/27
Synch. to Grid (or BC)	9:20 am	2024/01/02	8:05 pm	2024/01/27
Fires in to BC (duration)	00:08:35	DD:HH:MM	00:15:00	DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM

Unit No.4	Event 1	Event 2		
Breaker Open (BO)	9:55 pm	2024/01/03	9:15 am	2024/01/18
Draught Group (DG) Shut Down (SD)	5:55 am	2024/01/04	12:10 pm	2024/01/18
BO to DG SD (duration)	00:08:00	DD:HH:MM	00:02:55	DD:HH:MM
Fires in time	11:05 am	2024/01/07	1:20 am	2024/01/23
Synch. to Grid (or BC)				
Fires in to BC (duration)	00:08:35	DD:HH:MM	00:09:35	DD:HH:MM
Emissions below limit from BC (end date)	8:00 pm	2024/01/08	6:00 am	2024/01/24
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM

Unit No.5	Event 1	
Breaker Open (BO)	BO previously	BO previously
Draught Group (DG) Shut Down (SD)	n/a	n/a
BO to DG SD (duration)	n/a	DD:HH:MM
Fires in time	2:55 pm	2024/01/04
Synch. to Grid (or BC)	10:50 pm	2024/01/04
Fires in to BC (duration)	00:07:55	DD:HH:MM
Emissions below limit from BC (end date)	12:00 am	2024/01/06
Emissions below limit from BC (duration)	01:01:10	DD:HH:MM

Unit No.6	Event 1	Event 2		
Breaker Open (BO)	4:15 am	2024/01/01	11:20 am	2024/01/04
Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	12:40 pm	2024/01/04
BO to DG SD (duration)	n/a	DD:HH:MM	00:01:20	DD:HH:MM
Fires in time			12:00 am	2024/01/12
Synch. to Grid (or BC)			8:30 am	2024/01/12
Fires in to BC (duration)		DD:HH:MM	00:08:30	DD:HH:MM
Emissions below limit from BC (end date)			12:00 am	2024/01/13
Emissions below limit from BC (duration)		DD:HH:MM	00:15:30	DD:HH:MM

8 COMPLAINTS

There were no complaints for this month

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

9 GENERAL

Exceedances:

Units 4

02/01/2024 and 03/01/2024

- Unit exceeded on the 2nd and 3rd Jan. The issue was Field 1 1, 1 2, 2 4, 3.1 were off due to an under-voltage fault. Field 1.5 & 3 5 were off due to a faulty transformer that need to be replaced. Fields 1 3, 2 1, 2 2, 3.2, 3 3, 4 1, 4 2, 4 4, and 4 5. High backend temperatures. The unit was then shut down for Boiler Tube leaks repair and inspection and repairs on the precipitator fields.

18/01/2024

- Dust handling plant out of service, all slide gates closed and not conveying any dust to the silo.

Unit 5

11/01/2024

- Electrostatic precipitator Fields kept tripping due to suspected communication problems experienced between the DCS and PPMS.

15/01/2024

- Poor Electrostatic precipitator Performance affected by the high back end temperatures.

Unit 6

04/01/2024

- High Dust Silo level at 73% - Dusting not conducted due sluice pump A tripping. Sluice pump B was not to be available due to high vibrations.

22/01/2024 and 23/01/2024

- The Dust Handling Plant was not in service due to maintenance that was in progress, and this resulted in high hoppers. Work on the Dust handling plant was completed, and dusting commenced.

The Fuel oil usage for the month of January 2024 exceeded the permitted consumption rate due to the following reasons

Unit 1

- Attempted unit return to service from outage
- Unit shutdown to repair turbine bearing No 03

Unit 2

- Oil burner testing and oil burner support during soot blowing
- Mills challenges
- Cold return to service from boiler tube leaks repairs
- Soot blowing boiler manually (soot blowing testing)
- Continuously on oil burner support due to unstable bottom pyros
- Return to service of boiler feed pump turbine

Unit 4

- Continuously supporting combustion due to unstable bottom pyros
- Cold return to service
- Supporting combustion while soot blowing the boiler and testing of soot blowing lances
- Milling plant challenges
- return to service of boiler feed pump turbine

Unit 5

- Support unstable combustion due to milling plant challenges (mills rejecting excessively)
- Cold return to service from boiler tube leaks repairs
- Supporting combustion while soot blowing the boiler and testing of soot blowing lances

Unit 6


- Support unstable combustion due to milling plant challenges
- Continuously supporting combustion due to unstable bottom pyros and mills
- unavailable
- Oil burner testing and oil burner support during soot blowing
- Cold return to service
- Hot return to service

Lastly the averages Oxygen (O2) and Carbon Dioxide (CO2) data from the QAL2 tests report were used for reporting gaseous emissions for units 2, 4, 5 and 6 due to poor performance of the O2 and CO2 gaseous monitors. These poor performances of the monitors are due to faulty O2 analysers. The station is in the process to replace all the faulty analysers by 31 March 2024.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office.

10. S30 Incidents Register


There were no section 30 incidents for the month of January.



Boiler Plant Engineering
Manager

22/05/2024.

Date



Environmental
Manager

2024/05/22

Date



Engineering Manager

2024-05-22

Date

Compiled by

Environmental Officer

For

Nkangala District Municipality

Air Quality Officer

Copies

Generation Environmental Management

D Herbst

B Mccourt

Generation Compliance Management

R Rampiar

Generation Asset Management

E Patel

Duvha Power Station

Engineering Manager

Operating Manager

Maintenance Manager

Production Manager

Boiler Engineering Manager

System Engineer

Environmental Manager