



Generation

Nkangala District Municipality
P O Box 437
Middleburg
1050

Attention:

Mr V Mahlangu

AND

Directorate: Air Quality Management Services
The Chief Director:
Mr S S Maluleka
Department of Environmental Services
Private Bag X447
PRETORIA
0001
Tel: (012) 310 3263
Fax: (012) 320 0488

Date: 2024/07/31

Enquiries: Duvha Environmental Management

☎ +27 13 690 0445

☎ +27 66 212 2105

Enquiries: Ms Simthandile Nhlapo

☎ +27 13 690 0445

☎ +27 66 212 2105

Total number of pages: 14

Total number of annexes: 0

DUVHA POWER STATION

Atmospheric Emission License 17/4/AEL/MP312/11/07



GENERAL MANAGER

2024/08/21

DATE

DUVHA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/07



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Jun-2024
	Coal	Tons	1 400 000	408 274.740
	Fuel Oil	Tons	5 000	3479.23

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate Jun-2024
	Energy	GW h	2 592.000	757.550
	Ash	Tons	not specified	105 620.7

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 TO >1.2	0.74
Ash Content	%	27 TO 30	25.87

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NOx
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jun-2024	Technology Type
Unit 1	FFP	100.0%	SO ₃
Unit 2	FFP	100.0%	SO ₃
Unit 4	ESP + SO ₃	99.9%	SO ₃
Unit 5	ESP + SO ₃	99.8%	SO ₃
Unit 6	ESP + SO ₃	99.9%	SO ₃
<i>Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.</i>			

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100.0	100.0	100.0	100.0
Unit 2	100.0	99.7	100.0	100.0
Unit 4	99.7	100.0	100.0	100.0
Unit 5	98.6	100.0	99.9	100.0
Unit 6	99.7	17.6	83.4	100.0

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO₂

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of June 2024

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	8.0	969	319
Unit 2	4.1	876	410
Unit 4	35.1	1 963	930
Unit 5	61.0	1 979	1 086
Unit 6	29.6	1 583	445
SUM	137.79	7 370	3 189

Table 6.2: Operating days in compliance to PM AEL Limit - June 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contrave ntion	Total Exceedance
Unit 1	4	0	0	0	0
Unit 2	10	0	0	0	0
Unit 4	25	0	0	0	0
Unit 5	28	1	0	0	0
Unit 6	16	0	0	0	0
SUM	83	1	0	0	0

Table 6.3: Operating days in compliance to SO₂ AEL Limit - June 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contrave ntion	Total Exceedance
Unit 1	2	0	0	3	3
Unit 2	12	0	0	0	0
Unit 4	26	0	0	0	0
Unit 5	30	0	0	0	1
Unit 6	16	0	0	1	1
SUM	86	0	0	4	5

Table 6.4: Operating days in compliance to NO_x AEL Limit June 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contrave ntion	Total Exceedance
Unit 1	2	0	0	3	3
Unit 2	12	0	0	0	0
Unit 4	26	0	0	0	0
Unit 5	30	0	0	0	1
Unit 6	16	0	0	1	1
SUM	86	0	0	4	5

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Table 6.5: Legend Description






Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
		
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 1 PM Emissions - June 2024




Figure 2: Duvha Unit 2 PM Emissions - June 2024




Figure 3: Duvha Unit 4 PM Emissions - June 2024




Figure 4: Duvha Unit 5 PM Emissions - June 2024




Figure 5: Duvha Unit 6 PM Emissions - June 2024




Figure 6: Duvha Unit 1 SO₂ Emissions - June 2024




Figure 7: Duvha Unit 2 SO₂ Emissions - June 2024




Figure 8: Duvha Unit 4 SO₂ Emissions - June 2024




Figure 9: Duvha Unit 5 SO₂ Emissions - June 2024




Figure 10: Duvha Unit 6 SO₂ Emissions - June 2024




Figure 11: Duvha Unit 1 NO_x Emissions - June 2024




Figure 12: Duvha Unit 2 NO_x Emissions - June 2024




Figure 13: Duvha Unit 1 NOx Emissions - June 2024




Figure 14: Duvha Unit 5 NOx Emissions - June 2024





Figure 15: Duvha Unit 6 NOx Emissions - June 2024



7 SHUT DOWN AND LIGHT UP INFORMATION

Tables 7.1: Shut-down and light-up information for the month of June 2024

Unit No.1	Event 1		Event 2	
Breaker Open (BO)	1:10 am	2024/06/03	9:25 pm	2024/06/05
Draught Group (DG) Shut Down (SD)	1:15 am	2024/06/03	10:30 pm	2024/06/05
BO to DG SD (duration)	00:00:05	DD:HH:MM	00:01:05	DD:HH:MM
Fires in time	8:50 pm	2024/06/03	8:15 pm	2024/06/07
Synch. to Grid (or BC)	4:15 am	2024/06/04		
Fires in to BC (duration)	00:07:25	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM

Unit No.2	Event 1		Event 2		Event 3	
Breaker Open (BO)	BO previously	BO previously	4:55 pm	2024/06/18	3:00 am	2024/06/30
Draught Group (DG) Shut Down (SD)	n/a	n/a	9:20 am	2024/06/26	DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	n/a	DD:HH:MM	07:16:25	DD:HH:MM	n/a	DD:HH:MM
Fires in time	7:20 am	2024/06/12	11:10 am	2024/06/26		
Synch. to Grid (or BC)	1:40 pm	2024/06/12	9:55 pm	2024/06/26		
Fires in to BC (duration)	00:06:20	DD:HH:MM	00:10:45	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit		
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM

Unit No.4	<i>Event 1</i>	
Breaker Open (BO)	<i>11:20 pm</i>	<i>2024/06/20</i>
Draught Group (DG) Shut Down (SD)	<i>3:40 am</i>	<i>2024/06/21</i>
BO to DG SD (duration)	<i>00:04:20</i>	DD:HH:MM
Fires in time	<i>12:50 pm</i>	<i>2024/06/25</i>
Synch. to Grid (or BC)		
Fires in to BC (duration)	<i>00:06:55</i>	DD:HH:MM
Emissions below limit from BC (end date)	<i>not > limit</i>	<i>not > limit</i>
Emissions below limit from BC (duration)		DD:HH:MM

Unit No.6	<i>Event 1</i>		<i>Event 2</i>	
Breaker Open (BO)	<i>11:00 am</i>	<i>2024/06/03</i>	<i>10:15 am</i>	<i>2024/06/30</i>
Draught Group (DG) Shut Down (SD)	<i>11:50 am</i>	<i>2024/06/03</i>	<i>11:15 pm</i>	<i>2024/06/30</i>
BO to DG SD (duration)	<i>00:00:50</i>	DD:HH:MM	<i>00:13:00</i>	DD:HH:MM
Fires in time	<i>7:20 pm</i>	<i>2024/06/16</i>		
Synch. to Grid (or BC)	<i>3:00 am</i>	<i>2024/06/17</i>		
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	<i>not > limit</i>	<i>not > limit</i>		
Emissions below limit from BC (duration)	<i>n/a</i>	DD:HH:MM		DD:HH:MM

8 COMPLAINTS

There were no complaints for the month of June.

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

Exceedances

Unit 5

05/06/2024

The issue was related to the PPMS program frequently switching to P3 despite the load being above the low load setpoint

Unit 1

02/06/2024, 04-05/06/2024

Unit 1 was offload from the 9th of May and the gas monitor bi-weekly calibration was conducted on the 15th of May whilst the unit was off load. As a best practice in such an instance it would be recommended that the gas monitors be calibrated again when the unit is put back on load. However, this could not be done as required due to the unavailability of the unit Stack Lifts. The inability to conduct bi-weekly calibration inadvertently resulted in the SO_x and NO_x data integrity being compromised.

Unit 6

03/06/2024


Unit 6 was offload from the 18th of May and the gas monitor bi-weekly calibration was conducted on the 15th of May whilst the unit was off load. When the unit came back on the monitors were not calibrated due to the stack lifts not working. As a best practice in such an instance it would be recommended that the gas monitors be calibrated again when the unit is put back on load. However, this could not be done as required due to the unavailability of the unit Stack Lifts. The inability to conduct bi-weekly calibration inadvertently resulted in the NO_x data integrity being compromised.

Lastly the averages for Oxygen (O₂) and Carbon Dioxide (CO₂) data from the QAL2 tests reports were used for reporting gaseous emissions for units 2, 4, 5 and 6 due to poor performance of the O₂ and CO₂ gaseous monitors. These poor performances of the monitors are due to the inability to conduct bi-weekly calibrations of the O₂ analysers.


The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office.

10 S30 Incidents Register


There were no section 30 incidents for the month of June.


Boiler Plant Engineering Manager

21/08/2024
Date


Environmental Manager

2024/08/21
Date


Engineering Manager

2024-08-21
Date

Compiled by Environmental Officer

For Nkangala District Municipality

Air Quality Officer

Copies Generation Environmental Management

D Herbst
B Mccourt

Generation Compliance Management
Generation Asset Management

R Rampiar
E Patel

Duvha Power Station

Engineering Manager
Operating Manager
Maintenance Manager
Production Manager
Boiler Engineering
Manager
System Engineer
Environmental Manager