



**Generation**

Nkangala District Municipality  
P O Box 437  
Middleburg  
1050

**Attention:**

Mr V Mahlangu

AND

Directorate: Air Quality Management Services  
The Chief Director:  
Mr S S Maluleka  
Department of Environmental Services  
Private Bag X447  
PRETORIA  
0001  
Tel: (012) 310 3263  
Fax: (012) 320 0488

**Date: 2024/07/02**

Enquiries: Duvha Environmental Management

☎ +27 13 690 0445

☎ +27 66 212 2105

Enquiries: Ms Simthandile Nhlapo

☎ +27 13 690 0445

☎ +27 66 212 2105


**Total number of pages: 12**

**Total number of annexes: 0**

**DUVHA POWER STATION**

Atmospheric Emission License 17/4/AEL/MP312/11/07

  
\_\_\_\_\_  
GENERAL MANAGER

  
\_\_\_\_\_  
DATE

**DUVHA POWER STATION  
MONTHLY EMISSIONS REPORT**

Atmospheric Emission License 17/4/AEL/MP312/11/07



## 1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate May-2024
	Coal	Tons	1 400 000	447 847.85
	Fuel Oil	Tons	5 000	2 847.63

Production Rates	Product / By-Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate May-2024
	Energy	GWh	2 678.400	771.92
	Ash	Tons	not specified	116485.23

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [3 600 MW] x 24 hrs x days in Month/1000 to convert to GWh

## 2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 TO >1.2	0.76
Ash Content	%	27 TO 30	26.01

## 3 EMISSION LIMITS (mg/Nm<sup>3</sup>)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>x</sub>
Unit 1	100	3500	1100
Unit 2	100	3500	1100
Unit 3	100	3500	1100
Unit 4	100	3500	1100
Unit 5	100	3500	1100
Unit 6	100	3500	1100

#### 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency May-2024	Technology Type	SO <sub>3</sub> Utilization May-2024
Unit 1	FFP	99.9%	SO <sub>3</sub>	n/a
Unit 2	FFP	99.9%	SO <sub>3</sub>	n/a
Unit 4	ESP + SO <sub>3</sub>	99.8%	SO <sub>3</sub>	99.8%
Unit 5	ESP + SO <sub>3</sub>	Off	SO <sub>3</sub>	Off
Unit 6	ESP + SO <sub>3</sub>	99.9%	SO <sub>3</sub>	100.0%
<i>Note: ESP plant does not have bypass mode operation, hence plant 100% Utilised.</i>				

#### 5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>
Unit 1	94.9	100.0	100.0	100.0
Unit 2	95.1	100.0	100.0	100.0
Unit 4	100.0	100.0	100.0	100.0
Unit 5	Off	Off	Off	Off
Unit 6	100.0	36.4	74.2	99.4

*Note: NO<sub>x</sub> emissions is measured as NO in PPM. Final NO<sub>x</sub> value is expressed as total NO<sub>2</sub>*

#### 6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of May 2024

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	32.4	3 218	1 111
Unit 2	18.3	2 895	1 195
Unit 4	38.8	2 083	837
Unit 5	Off	Off	Off
Unit 6	24.2	1 154	397
<b>SUM</b>	<b>113.76</b>	<b>9 349</b>	<b>3 540</b>

Table 6.2: Operating days in compliance to PM AEL Limit - May 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
Unit 1	17	0	0	0	0	30.5
Unit 2	30	0	0	0	0	11.6
Unit 4	23	0	0	0	0	32.4
Unit 5	0	Off	Off	Off	Off	Off
Unit 6	12	0	0	0	0	37.3
<b>SUM</b>	<b>82</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	



Table 6.3: Operating days in compliance to SO<sub>2</sub> AEL Limit - May 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO <sub>2</sub> (mg/Nm <sup>3</sup> )
Unit 1	16	0	0	3	3	2 956.7
Unit 2	31	0	0	0	0	1 806.0
Unit 4	25	0	0	0	0	1 603.7
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	16	0	0	0	0	1 401.3
<b>SUM</b>	<b>88</b>	<b>0</b>	<b>0</b>	<b>3</b>	<b>3</b>	

Table 6.4: Operating days in compliance to NO<sub>x</sub> AEL Limit - May 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO <sub>x</sub> (mg/Nm <sup>3</sup> )
Unit 1	13	0	0	6	6	1 008.3
Unit 2	31	0	0	0	0	740.2
Unit 4	25	0	0	0	0	644.8
Unit 5	Off	Off	Off	Off	Off	Off
Unit 6	16	0	0	0	0	485.9
<b>SUM</b>	<b>85</b>	<b>0</b>	<b>0</b>	<b>6</b>	<b>6</b>	

Note: NO<sub>x</sub> emissions is measured as NO in PPM. Final NO<sub>x</sub> value is expressed as total NO<sub>2</sub>

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 1: Duvha Unit 1 PM Emissions - May 2024




Figure 2: Duvha Unit 2 PM Emissions - May 2024




Figure 3: Duvha Unit 4 PM Emissions - May 2024






Figure 4: Duvha Unit 6 PM Emissions - May 2024




Figure 5: Duvha Unit 1 SO<sub>2</sub> Emissions - May 2024




Figure 6: Duvha Unit 2 SO<sub>2</sub> Emissions - May 2024




Figure 7: Duvha Unit 4 SO<sub>2</sub> Emissions - May 2024




Figure 8: Duvha Unit 6 SO<sub>2</sub> Emissions - May 2024




Figure 9: Duvha Unit 1 NO<sub>x</sub> Emissions - May 2024






Figure 10: Duvha Unit 2 NOx Emissions - May 2024




Figure 11: Duvha Unit 4 NOx Emissions - May 2024





Figure 12: Duvha Unit 6 NOx Emissions - May 2024



## 7 SHUT DOWN AND LIGHT UP INFORMATION

Tables 7.1: Shut-down and light-up information for the month of May 2024

Unit No.1	<i>Event 1</i>	
Breaker Open (BO)	<i>5:50 pm</i>	<i>2024/05/09</i>
Draught Group (DG) Shut Down (SD)	<i>11:45 pm</i>	<i>2024/05/09</i>
BO to DG SD (duration)	<i>00:05:55</i>	DD:HH:MM
Fires in time	<i>6:30 am</i>	<i>2024/05/22</i>
Synch. to Grid (or BC)	<i>1:20 pm</i>	<i>2024/05/22</i>
Fires in to BC (duration)	<i>00:06:50</i>	DD:HH:MM
Emissions below limit from BC (end date)	<i>not &gt; limit</i>	<i>not &gt; limit</i>
Emissions below limit from BC (duration)	<i>n/a</i>	DD:HH:MM

Unit No.2	<i>Event 1</i>	
Breaker Open (BO)	<i>3:50 am</i>	<i>2024/05/30</i>
Draught Group (DG) Shut Down (SD)	<i>DG did not trip or SD</i>	<i>DG did not trip or SD</i>
BO to DG SD (duration)	<i>n/a</i>	DD:HH:MM
Fires in time		
Synch. to Grid (or BC)		
Fires in to BC (duration)		DD:HH:MM
Emissions below limit from BC (end date)		
Emissions below limit from BC (duration)		DD:HH:MM

Unit No.4	<i>Event 1</i>		<i>Event 2</i>	
Breaker Open (BO)			<i>2:30 pm</i>	<i>2024/05/06</i>
Draught Group (DG) Shut Down (SD)			<i>12:35 am</i>	<i>2024/05/07</i>
BO to DG SD (duration)		DD:HH:MM	<i>00:10:05</i>	DD:HH:MM
Fires in time			<i>2:15 pm</i>	<i>2024/05/12</i>
Synch. to Grid (or BC)				
Fires in to BC (duration)		DD:HH:MM	<i>00:12:35</i>	DD:HH:MM
Emissions below limit from BC (end date)			<i>not &gt; limit</i>	<i>not &gt; limit</i>
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM



Unit No.6	Event 1		Event 2		Event 3	
Breaker Open (BO)			1:45 pm	2024/05/10	3:45 pm	2024/05/18
Draught Group (DG) Shut Down (SD)			DG did not trip or SD	DG did not trip or SD	1:45 pm	2024/05/21
BO to DG SD (duration)		DD:HH:MM	n/a	DD:HH:MM	02:22:00	DD:HH:MM
Fires in time					9:00 pm	2024/05/29
Synch. to Grid (or BC)					4:00 am	2024/05/30
Fires in to BC (duration)		DD:HH:MM		DD:HH:MM	00:07:00	DD:HH:MM
Emissions below limit from BC (end date)					not > limit	not > limit
Emissions below limit from BC (duration)		DD:HH:MM		DD:HH:MM	n/a	DD:HH:MM

## 8 COMPLAINTS

There were no complaints for the month of May.

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence

## 9 GENERAL

Exceedances:

Unit 1

23/05/2024 to 29/05/2024


Unit 1 was offload from the 9th of May and the gas monitor bi-weekly calibration was conducted on the 15th of May whilst the unit was off load. As a best practice in such an instance it would be recommended that the gas monitors be calibrated again when the unit is put back on load. However, this could not be done as required due to the unavailability of the unit Stack Lifts. The inability to conduct bi-weekly calibration inadvertently resulted in the Sox and NOx data integrity being compromised.

Lastly the averages for Oxygen (O2) and Carbon Dioxide (CO2) data from the QAL2 tests reports were used for reporting gaseous emissions for units 1, 2, 4, and 6 due to poor performance of the O2 and CO2 gaseous monitors. These poor performances of the monitors are due to the inability to conduct bi-weekly calibration of the O2 analysers. The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report which will be sent to your office.

## 10 S30 Incidents Register

There were no section 30 incidents for the month of May.




  
Boiler Plant Engineering Manager

21/08/2024  
Date

  
Environmental Manager

2024/08/21  
Date

  
Engineering Manager

2024-08-21  
Date

Compiled by

Environmental Officer

For

Nkangala District Municipality

Air Quality Officer

Copies

Generation Environmental Management

D Herbst  
B Mccourt

Generation Compliance Management  
Generation Asset Management

R Rampiar  
E Patel

Duvha Power Station

Engineering Manager  
Operating Manager  
Maintenance Manager  
Production Manager  
Boiler Engineering Manager  
System Engineer  
Environmental Manager