



APRIL 2024

HENDRINA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/16



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted Consumption Rate	Consumption Rate Apr-2024
	Coal	Tons	820,000	266,915.5
	Fuel Oil	Tons	3,200	1712.612

Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Production Rate Apr-2024
	Energy	GWh	1440	432.25
	Ash	Tons	290,000	58,268
	RE PM	kg/MWh	not specified	0.150

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 to < 1	0.60
Ash Content	%	20 to < 35	21.83

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
North	75	3500	1200
South	75	3500	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Apr-2024
Unit 1	Fabric Filter Plant (FFP)	Unit Off-line
Unit 2	Fabric Filter Plant (FFP)	99.95%
Unit 3	Fabric Filter Plant (FFP)	Unit Off-line
Unit 4	Fabric Filter Plant (FFP)	99.96%
Unit 5	Fabric Filter Plant (FFP)	99.95%
Unit 6	Fabric Filter Plant (FFP)	99.94%
Unit 7	Fabric Filter Plant (FFP)	99.95%
Unit 8	Fabric Filter Plant (FFP)	Unit Off-line
Unit 9	Fabric Filter Plant (FFP)	Unit Off-line
Unit 10	Fabric Filter Plant (FFP)	100.00%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂	CO ₂
North	100.0	100.0	100.0	100.0	94
South	100.0	100.0	94.0	100.0	100

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂.

6 EMISSION PERFORMANCE

Table 6.1 Monthly tonnages for the month of April-2024

Associated Unit/Stack	PM (tons)	SO _x (tons)	NO _x (tons)
North	12.0	4,429.1	3,413.9
South	52.9	2,152.1	677.2
SUM	64.8	6,581.1	4,091.1

Table 6.2: Operating days in compliance to PM AEL Limit - April 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
North	30	0	0	0	0	9.6
South	30	0	0	0	0	38.5
SUM	60	0	0	0	0	

North Stack SO₂ exceedance due to monitor defects. Mitigation measure outline at section 9 of this report: General

Table 6.3: Operating days in compliance to SO₂ AEL Limit - April 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm³)
North	14	0	0	0	16	3,522.6
South	30	0	0	0	0	1,482.3
SUM	44	0	0	16	16	

North Stack SO₂ exceedance due to monitor defects. Mitigation measure outline at section 9 of this report: General

Table 6.4: Operating days in compliance to NO_x AEL Limit - April 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm³)
North	0	0	0	0	30	2,682.2
South	30	0	0	0	0	445.0
SUM	30	0	0	30	30	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions




Figure 1: PM Emissions trends for North Stack- April 2024




Figure 2: PM Emissions trends for South Stack- April 2024

Gaseous Emission Trends (NO_x and SO_x) for the North Stack have been removed due to suspected erroneous data from the Continuous Emission Monitoring System (CEMS) .

Spot Checks measurements have been performed internally and they confirm the error.

The Station has conducted correlation and parallel tests for both stacks via services of a SANAS Accredited service provider and the final report is awaited. The station shall implement the correlation factors once the reports are received from the service provider and they shall be shared with the Licensing Authority.

Figure 4: Hendrina South Stack SO₂ Emissions - April 2024




Figure 4: Sulphur dioxide Emissions trends for South Stack- April 2024

Figure 6: Hendrina South Stack NO_x Emissions - April 2024




Figure 6: Nitrogen dioxide Emissions trends for South Stack- April 2024

7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7 1 PM Start-up information for the month of April-2024

North Stack	Event 1		Event 2		Event 3		Event 4	
Unit No	Unit 2		Unit 2		Unit 4		Unit 4	
Breaker Open (BO)	10 45 PM	08/04/2024	10 15 AM	28/04/2024			4 35 PM	15/04/2024
Draught Group (DG) Shut Down (SD)	7 25 PM	09/04/2024	11 05 PM	28/04/2024			3 45 PM	16/04/2024
BO to DG SD (duration)	00 20 40	DD HH MM	00 12 50	DD HH MM		DD HH MM	00 23 10	DD HH MM
Fires in time	10 10 AM	14/04/2024			11 01 00	11/04/2024		
Synch to Grd (or BC)	10 10 PM	14/04/2024			1 00 PM	11/04/2024		
Fires in to BC (duration)	00 12 00	DD HH MM		DD HH MM	00 12 00	DD HH MM		DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit			not > limit	not > limit		
Emissions below limit from BC (duration)	n/a	DD HH MM		DD HH MM	n/a	DD HH MM		DD HH MM


South Stack	Event 1		Event 2		Event 3	
Unit No	Unit 6		Unit 10		Unit 10	
Breaker Open (BO)	5 15 AM	20/04/2024			11 15 PM	22/04/2024
Draught Group (DG) Shut Down (SD)	5 15 AM	20/04/2024			11 15 PM	22/04/2024
BO to DG SD (duration)		DD HH MM		DD HH MM		DD HH MM
Fires in time	8 00 AM	19/04/2024	17/04/2024	17/04/2024	22 23 40	22/04/2024
Synch to Grnd (or BC)	2 00 AM	21/04/2024	5 00 AM	18/04/2024	5 40 AM	23/04/2024
Fires in to BC (duration)	01 18 00	DD HH MM	00 06 00	DD HH MM	00 06 00	DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD HH MM	n/a	DD HH MM	n/a	DD HH MM

8 Complaints register


Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Date measure will be implemented	Measures implemented to prevent reoccurrence
The Station did not receive complaints related to air quality during the month of April 2024					

9 General


The station has taken to execute short term and long term mitigations to ensure reliability of the CEMS. The short term actions include interim repairs and replacement of damaged components, which are now complete, by the Original Equipment Manufacturer. For the long term, the station will engage the Licencing Authority regarding a complete overhaul of the CEMS as required by Paragraph 2 of General Condition 4.1 of the AEL.

 11/06/2024
 Compiler Date


B Madipe
 Office
 Environmental


 12/06/2024
 Checked by Date

Moyahabo Maoto
 System Engineer

 12/06/2024
 Checked by Date

S Kubheka C/I
 Engineer

 2024.06.19
 Authorised by: GM Date
 T Lekalakala

 11/06/2024
 Validated by Manager Environmental Date
 L Ntla

Compiled by Boiler Engineering Department

FFP SE/ Environmental Officer

For Nkangala District Municipality

Air Quality Officer

Copies Eskom Environmental Management

D Herbst
 B Mccourt

Group Technology Engineering

R Rampiar
 E Patel

Hendrina Power Station

Engineering Manager
 Operating Manager
 Maintenance Manager
 Unit Production Manager
 Boiler Engineering Manager
 System Engineer Boiler Engineering
 Environmental Officer
 C & I Engineering Manager
 Production Manager
 Environmental Manager
 PSM