


HENDRINA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/16



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted Consumption Rate	Consumption Rate Jun-2024
	Coal	Tons	820	281.7
	Fuel Oil	Tons	3200	866.94

Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Production Rate Jun-2024
	Energy	GWh	1440	453.43
	Ash	Tons	290000	61665
	RE PM	kg/MWh	not specified	0.181

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 to < 1	0.58
Ash Content	%	20 to < 35	21.89

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
North	50	3500	1200
South	50	3500	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jun-2024
Unit 1	Fabnc Filter Plant (FFP)	Unit Off-line
Unit 2	Fabnc Filter Plant (FFP)	99.96%
Unit 3	Fabnc Filter Plant (FFP)	Unit Off-line
Unit 4	Fabnc Filter Plant (FFP)	Unit Off-line
Unit 5	Fabnc Filter Plant (FFP)	99.95%
Unit 6	Fabnc Filter Plant (FFP)	99.96%
Unit 7	Fabnc Filter Plant (FFP)	99.93%
Unit 8	Fabnc Filter Plant (FFP)	Unit Off-line
Unit 9	Fabnc Filter Plant (FFP)	Unit Off-line
Unit 10	Fabnc Filter Plant (FFP)	100%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂	CO ₂
North	100.0	100.0	100.0	100	100
South	96.7	100.0	100.0	100	100

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂.

6 EMISSION PERFORMANCE

Table 6.1 Monthly tonnages for the month of June-2024

Associated Unit/Stack	PM (tons)	SO _x (tons)	NO _x (tons)
North	11.1	6521.9	3167.9
South	70.8	2953.5	1538.9
SUM	81.9	9475.4	4706.8

Table 6.2: Operating days in compliance to PM AEL Limit - June 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
North	30	0	0	0	0	9.8
South	23	2	5	0	7	53.0
SUM	53	2	5	0	7	

North Stack SO2 issue due to monitor defects. Mitigation measures outlined at section 9 of this report: General

Table 6.3: Operating days in compliance to SO₂ AEL Limit - June 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm³)
North						
South	30	0	0	0	0	1,973.8
SUM	30	0	0	30	30	

North Stack NO2 issue due to monitor defects. Mitigation measures outlined at section 9 of this report: General

Table 6.4: Operating days in compliance to NO_x AEL Limit - June 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm³)
North						
South	29	0	0	1	1	1,024.9
SUM	29	0	0	31	31	

Table 6.5: Legend Description

Condition	Colour	Description
Normal	Grey	Emissions below Emission Limit Value (ELV)
Grace	Dark Blue	Emissions above the ELV during grace period
Section 30	Green	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions




Figure 1: PM Emissions trends for North Stack- June 2024




Figure 2: PM Emissions trends for South Stack- June 2024




Figure 4: Sulphur dioxide Emissions trends for South Stack- June 2024

Gaseous Emission Trends (NOx and SOx) for the North Stack have been removed due to suspected erroneous data from the Continuous Emission Monitoring System (CEMS).

Spot Checks measurements have been performed internally and they confirm the error.

The Station has conducted correlation and parallel tests for both stacks via services of a SANAS Accredited service provider and the final report is awaited.

The station shall implement the correlation factors once the reports are received from the service provider and they shall be shared with the Licencing Authority.




Figure 6: Nitrogen dioxide Emissions trends for South Stack- June 2024

7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7 1 PM Start-up information for the month of June-2024

North Stack	Event 1		Event 2	
Unit No	Unit 5		Unit 5	
Breaker Open (BO)	<i>BO previously</i>	<i>BO previously</i>	5 15 AM	27/06/2024
Draught Group (DG) Shut Down (SD)	<i>n/a</i>	<i>n/a</i>	1 05 PM	27/06/2024
BO to DG SD (duration)	<i>n/a</i>	DD HH MM	00 07 50	DD HH MM
Fires in time	12 00 AM	04/06/2024	27/06/2024	27/06/2024
Synch to Grid (or BC)	12 00 PM	04/06/2024	11 30 PM	27/06/2024
Fires in to BC (duration)	00 12 00	DD HH MM	00 12 00	DD HH MM
Emissions below limit from BC (end date)	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>
Emissions below limit from BC (duration)	<i>n/a</i>	DD HH MM	<i>n/a</i>	DD HH MM

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No	Unit 6		Unit 7		Unit 7		Unit 7	
Breaker Open (BO)	1 35 PM	17/06/2024	11 25 PM	05/06/2024	10 25 PM	15/06/2024	7 35 AM	24/06/2024
Draught Group (DG) Shut Down (SD)	1 55 PM	17/06/2024	10 45 AM	06/06/2024	6 25 AM	16/06/2024	6 05 PM	24/06/2024
BO to DG SD (duration)	00 00 20	DD HH MM	00 11 20	DD HH MM	00 08 00	DD HH MM	00 10 30	DD HH MM
Fires in time	4 00 PM	17/06/2024	11/06/2024	11/06/2024	17 01 00	17/06/2024		
Synch to Grid (or BC)	10 00 PM	17/06/2024	1 30 AM	12/06/2024	7 00 AM	17/06/2024		
Fires in to BC (duration)	00 06 00	DD HH MM	00 06 00	DD HH MM	00 06 00	DD HH MM		DD HH MM
Emissions below limit from BC (end date)	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>		
Emissions below limit from BC (duration)	<i>n/a</i>	DD HH MM	<i>n/a</i>	DD HH MM	<i>n/a</i>	DD HH MM		DD HH MM


South Stack Continued	Event 1		Event 2	
Unit No	Unit 10		Unit 10	
Breaker Open (BO)	3 25 AM	02/06/2024	4 15 PM	16/06/2024
Draught Group (DG) Shut Down (SD)	3 25 AM	02/06/2024	4 15 PM	16/06/2024
BO to DG SD (duration)		DD HH MM		DD HH MM
Fires in time	7 20 AM	02/06/2024	18/06/2024	18/06/2024
Synch to Grid (or BC)	1 20 PM	02/06/2024	4 10 AM	19/06/2024
Fires in to BC (duration)	00 06 00	DD HH MM	00 06 00	DD HH MM
Emissions below limit from BC (end date)	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>	<i>not > limit</i>
Emissions below limit from BC (duration)	<i>n/a</i>	DD HH MM	<i>n/a</i>	DD HH MM


8 Complaints register


Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Date measure will be implemented	Measures implemented to prevent reoccurrence
<i>The Station did not receive complaints related to air quality during the month of June 2024</i>					


09 General


The station has taken to execute short term and long term mitigations to ensure reliability of the CEMS. The short term actions include interim repairs and replacement of damaged components, which are now complete, by the Original Equipment Manufacturer. For the long term, the station will engage the Licencing Authority regarding a complete overhaul of the CEMS as required by Paragraph 2 of General Condition 4.1 of the AEL.


 Compiled Environmental Officer
 Azola Boja


 2024/07/30
 Checked by System Engineer
 Boiler/ FFP
 Moyahabo Cetlyff Maoto


 2024/07/31
 C/I Engineer
 S Kubheka


 31/07/2024
 Authorised by. GM
 T. Lekalakala
 Date


 30/07/2024
 Validated by Manager
 Environmental
 L Ntla
 Date

Compiled by Boiler Engineering Department
 For Nkangala District Municipality
 Copies Eskom Environmental Management
 Group Technology Engineering
 Hendrina Power Station

FFP SE/ Environmental Officer
 Air Quality Officer
 D Herbst
 B Mccourt
 R Rampiar
 E Patel
 Engineering Manager
 Operating Manager
 Maintenance Manager
 Unit Production Manager
 Boiler Engineering Manager
 System Engineer Boiler Engineering
 Environmental Officer
 C & I Engineering Manager
 Production Manager
 Environmental Manager
 PSM