 Eskom	Technical and Generic Report	Matimba Power Station
---	------------------------------	-----------------------

Title: **Matimba Power Station April 2024 emissions report**

Document Identifier: **RP/247/046**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **30**

Report Date: **April 2024**

Disclosure Classification: **Controlled**

Compiled by



Kamogelo Kwata
Environmental Officer
(GIT)

Date: 10.07.2024


Reviewed by



Helry Ramahlare
Senior Advisor
Environment

Date: 15.07.2024

Functional
Responsibility



MC Mamabolo
Environmental
Manager

Date: 15/07/2024

Authorized by



Obakeng Mabotja
General Manager

Date: 2024/07/15

Content

	Page
1. Report Summary	5
2. Emission information	6
2.1 Raw materials and products.....	6
2.2 Abatement technology.....	6
2.3 Emissions reporting.....	7
Particulate Matter Emissions.....	7
Gaseous Emissions.....	10
Total Volatile Organic Compounds	16
Greenhouse gas (CO ₂) emissions.....	17
2.4 Daily power generated.	17
2.5 Pollutant Tonnages	21
2.6 Operating days in compliance to PM AEL Limit	21
2.7 Operating days in compliance to SO _x AEL Limit	21
2.8 Operating days in compliance to NO _x AEL Limit	22
2.9 Reference values	22
2.10 Continuous Emission Monitors.....	22
2.10.1 Reliability.....	22
2.10.2 Changes, downtime, and repairs	23
2.10.3 Sampling dates and times.....	24
2.11 Units Start-up information	25
2.12 Emergency generation	27
2.13 Complaints register.	28
2.14 Air quality improvements and social responsibility conducted.	28
Air quality improvements.....	28
Social responsibility conducted.	28
2.15 Ambient air quality monitoring.....	29
2.16 Electrostatic precipitator and Sulphur plant status.....	29
2.17 General.....	30
3. Attachments.....	30
4. Report Conclusion	30
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	6
Table 2: Abatement Equipment Control Technology Utilised.....	6
Table 3: Energy Source Material Characteristics.	7
Table 4: Total volatile compound estimates	16
Table 5: Daily power generated per unit in MWh for the month of April 2024.....	17
Table 6: Pollutant tonnages for the month of April 2024	21

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 7: Operating days in compliance with PM AEL limit of April 2024.....	21
Table 8: Operating days in compliance with SOx AEL limit of April 2024	21
Table 9: Operating days in compliance with NOx AEL limit of April 2024.....	22
Table 10: Reference values for data provided, April 2024	22
Table 11: Average percentage (%) availability of monitors for the month of April 2024.	22
Table 12: Dates of last full conducted CEMS verification tests for PM for unit 4 and 6 only	24
Table 13: Dates of last conducted CEMS Spot verification tests for PM, SO ₂ and NOx (without unit 4 and 6 PMs)	24
Table 14: Start-up information	25
Table 15: Emergency generation	27
Table 16: Complaints.....	28

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of April 2024	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of April 2024	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of April 2024	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of April 2024	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of April 2024	9
Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of April 2024	10
Figure 7: SO ₂ daily average emissions against emission limit for unit 1 for the month of April 2024.....	10
Figure 8: SO ₂ daily average emissions against emission limit for unit 2 for the month of April 2024.....	11
Figure 9: SO ₂ daily average emissions against emission limit for unit 3 for the month of April 2024.....	11
Figure 10: SO ₂ daily average emissions against emission limit for unit 3 for the month of April 2024.....	12
Figure 11: SO ₂ daily average emissions against emission limit for unit 5 for the month of April 2024.....	12
Figure 12: SO ₂ daily average emissions against emission limit for unit 6 for the month of April 2024.....	13
Figure 13: NOx daily average emissions against emission limit for unit 1 for the month of April 2024.....	13
Figure 14: NOx daily average emissions against emission limit for unit 2 for the month of April 2024.....	14
Figure 15: NOx daily average emissions against emission limit for unit 3 for the month of April 2024.....	14
Figure 16: NOx daily average emissions against emission limit for unit 4 for the month of April 2024.....	15
Figure 17: NOx daily average emissions against emission limit for unit 5 for the month of April 2024.....	15
Figure 18: NOx daily average emissions against emission limit for unit 6 for the month of April 2024.....	15

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Figure 19: Unit 1 daily generated power in MWh for the month of April 2024.....18

Figure 20: Unit 2 daily generated power in MWh for the month of April 2024.....18

Figure 21: Unit 3 daily generated power in MWh for the month of April 2024.....19

Figure 22: Unit 4 daily generated power in MWh for the month of April 2024.....19

Figure 23: Unit 5 daily generated power in MWh for the month of April 2024.....20

Figure 24: Unit 6 daily generated power in MWh for the month of April 2024.....20

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for April 2024. The information recorded in the report is obtained from Matimba Emission Reporting tool V02.2024VF.



During the period under review, Matimba experienced sixty (60) exceedances of the daily particulate matter emission limit (50mg/Nm³), thirty-nine (39) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence and twenty-one (21) exceedances occurred within the 48-hour grace period.

There was one exceedance for monthly SO_x limit (3500mg/Nm³) on the 07th of April 2024 which is still under investigation. No exceedance for daily NO_x emission limit (750mg/Nm³) occurred.

Flue gas conditioning plant availability was below the required 100% for all the units due to unplanned breakdowns and defects. Defects were addressed and plants returned to service. Unit 1, unit 2 and unit 4 SO₃ plant was constantly on hold for the month of April 2024.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month.

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	916653
	Fuel Oil	Tons/month	1 200	3725.287
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	1081.063

The consumption rates for fuel oil for the month of April 2024 exceeded the permitted maximum limit due to multiple units light ups and mill support.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99.999%
Unit 2	Electrostatic Precipitator	100%	99.998%
Unit 3	Electrostatic Precipitator	100%	99.999%
Unit 4	Electrostatic Precipitator	100%	99.995%
Unit 5	Electrostatic Precipitator	100%	99.999%
Unit 6	Electrostatic Precipitator	100%	99.998%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	73%
Unit 2	SO ₃ Plant	100%	74%
Unit 3	SO ₃ Plant	100%	98%
Unit 4	SO ₃ Plant	100%	77%
Unit 5	SO ₃ Plant	100%	81%
Unit 6	SO ₃ Plant	100%	97%

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.16%
	Ash Content	40%	35.70%

Energy source characteristics remained within the ranges stipulated in the license.

2.3 Emissions reporting

Particulate Matter Emissions

The emission monitors Correlation spot test were performed in August 2023 and the results were applied and used for gaseous emissions calculation for April 2024. The spot test results for PM emissions does not meet the minimum requirements outlined in the Eskom emission calculation Methodology and were not applied.

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of April 2024

Interpretation:

Unit 1 exceeded the daily particulate emission limit of 50mg/Nm³ on 23 to 30 April 2024. The exceedances from 25 to 30 April 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to unavailability of the ash conveyance system that led to ash accumulation on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of April 2024

Interpretation:

Unit 2 exceeded the daily particulate emission limit of 50mg/Nm³ on 1 to 3, 14 and 28 to 30 April 2024. The exceedances from 3 and 30 April 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to unavailability of the ash conveyance system that led to ash accumulation on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of April 2024

Interpretation:

Unit 3 exceeded the daily particulate emission limit of 50mg/Nm³ on 2 to 4, 8 to 10, 29 and 30 April 2024. The exceedances from 4 and 10 April 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to unavailability of the ash conveyance system that led to ash accumulation on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of April 2024

Interpretation:

Unit 3 exceeded the daily particulate emission limit of 50mg/Nm³ on 26 to 29 April 2024. The exceedances from 28 and 29 April 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to unavailability of the ash conveyance system that led to ash accumulation on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

Unit 5 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of April 2024

Interpretation:

Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 3 to 30 April 2024. Exceedances from 5 to 30 April 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of April 2024

Interpretation:

Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm^3 on 7, 21 to 23 and 26 April 2024. The exceedances on 23 April 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields). The investigation into the causes of the exceedances were done and corrective measure put in place to correct the root causes.

Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in April 2024 as per the Eskom emission standard requirements.

The quality assurance spot tests were performed on the monitors in August 2023 and the test results are used for the April 2024 emission calculation.


Unit 1 SO₂ Emissions

Figure 7: SO₂ daily average emissions against emission limit for unit 1 for the month of April 2024


Interpretation:

The exceedance on 07 April 2024 occurred within the 48-hour grace period. The cause of the exceedances is still under investigation.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 SO₂ Emissions**Figure 8: SO₂ daily average emissions against emission limit for unit 2 for the month of April 2024****Interpretation:**

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


Unit 3 SO₂ Emissions**Figure 9: SO₂ daily average emissions against emission limit for unit 3 for the month of April 2024****Interpretation:**

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO₂ Emissions**Figure 10: SO₂ daily average emissions against emission limit for unit 3 for the month of April 2024****Interpretation:**

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

Unit 5 SO₂ Emissions**Figure 11: SO₂ daily average emissions against emission limit for unit 5 for the month of April 2024****Interpretation:**

All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 6 SO₂ Emissions

Figure 12: SO₂ daily average emissions against emission limit for unit 6 for the month of April 2024

Interpretation:

All daily averages remained below SO₂ emission monthly limit of 3500 mg/Nm³.


Unit 1 NO_x Emissions

Figure 13: NO_x daily average emissions against emission limit for unit 1 for the month of April 2024

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO_x Emissions

Figure 14: NO_x daily average emissions against emission limit for unit 2 for the month of April 2024

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.


Unit 3 NO_x Emissions

Figure 15: NO_x daily average emissions against emission limit for unit 3 for the month of April 2024

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 NO_x Emissions

Figure 16: NO_x daily average emissions against emission limit for unit 4 for the month of April 2024

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.


Unit 5 NO_x Emissions

Figure 17: NO_x daily average emissions against emission limit for unit 5 for the month of April 2024

Interpretation:

All daily averages below NO_x emission limit of 750 mg/Nm³.


Unit 6 NO_x Emissions

Figure 18: NO_x daily average emissions against emission limit for unit 6 for the month of April 2024

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Total Volatile Organic Compounds**Table 4:** Total volatile compound estimates

CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Tuesday, 07 May 2024	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
MONTHLY INPUT DATA FOR THE STATION Please only insert relevant monthly data inputs into the blue cells below Choose from a dropdown menu in the green cells The total VOC emissions for the month are in the red cells IMPORTANT: Do not change any other cells without consulting the AQ CoE		
MONTH:	April	
GENERAL INFORMATION:	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13.34	m
Diameter of tank:	9.53	m
Net fuel oil throughput for the month:	3725.287	
Molecular weight of the fuel oil:	166.00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH	Data	Unit
Daily average ambient temperature	20.60	°C
Daily maximum ambient temperature	27.37	°C
Daily minimum ambient temperature	13.11	°C
Daily ambient temperature range	10.46	°C
Daily total insolation factor	3.84	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0.68	NA
FINAL OUTPUT:	Result	Unit
Breathing losses:	0.48	kg/month
Working losses:	0.11	kg/month
TOTAL LOSSES (Total TVOC Emissions for the month):	0.59	kg/month
*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.4 Daily power generated.



Table 5: Daily power generated per unit in MWh for the month of April 2024

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2024/04/01	Unit Off	8707.98	10931.5	Unit Off	Unit Off	8999.86
2024/04/02	Unit Off	8446.26	11704.3	Unit Off	7519.04	8694.04
2024/04/03	Unit Off	8234.84	11936.3	Unit Off	9695.54	9054.94
2024/04/04	3884.01	8477.74	11835.3	Unit Off	11047.2	9268.9
2024/04/05	10979.9	6727.6	10946	Unit Off	10533.8	9195.84
2024/04/06	10541	4440.43	10900.5	Unit Off	10468.8	8928.69
2024/04/07	11974.6	Unit Off	11180.4	Unit Off	10803.4	9267.59
2024/04/08	12021.1	Unit Off	11590.4	Unit Off	11079.6	9261.57
2024/04/09	11526.2	Unit Off	11838.7	Unit Off	11242.7	9258.86
2024/04/10	10733.8	8539.17	11528.3	Unit Off	10890.5	9250.63
2024/04/11	11330.4	8097.26	11306	Unit Off	10316.7	9278.02
2024/04/12	10926.2	8109.68	11266.7	Unit Off	10777.3	9289.11
2024/04/13	10999.4	7999.71	12280.6	Unit Off	11264.1	9289.18
2024/04/14	10081.9	8004.13	11293.1	Unit Off	10681.3	9136.04
2024/04/15	10803.7	8016.37	11983.9	Unit Off	11942.9	9288.52
2024/04/16	11742.8	8009.56	12488.9	Unit Off	12243.3	9293.02
2024/04/17	12053.8	8018.28	11043.5	Unit Off	12299.4	9283.62
2024/04/18	11879.4	8006.09	10083.6	Unit Off	12458.8	9281.88
2024/04/19	10080.5	7966.48	10705	Unit Off	11078.1	9282.45
2024/04/20	Unit Off	7975.56	10360.7	Unit Off	12315.7	9264.41
2024/04/21	7011.75	8882	10186.7	Unit Off	12327	9028.4
2024/04/22	10517.6	8542.5	10402.7	369.339	12284.4	8471.84
2024/04/23	10379.3	10625.9	10268.4	6983.87	11629.1	6824.19
2024/04/24	11323	10421.6	10123.3	9900.31	11987	3994.55
2024/04/25	10834.4	10418	10520.5	10051.8	11369.6	7605.32
2024/04/26	10772.2	9761.4	10528.2	10036.3	11599	8361.83
2024/04/27	10355.8	10979.2	10598.3	10181.1	10425.1	8793.99
2024/04/28	10617.9	10588.4	10575.8	10255.7	10515.7	8800.16
2024/04/29	11194.1	11510.7	11022.7	11160.8	10889.4	8796.25
2024/04/30	11046.1	9941.34	9903.43	5737.33	10357.7	8514.17

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.



No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Figure 19: Unit 1 daily generated power in MWh for the month of April 2024****Figure 20: Unit 2 daily generated power in MWh for the month of April 2024**

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

**Figure 21: Unit 3 daily generated power in MWh for the month of April 2024****Figure 22: Unit 4 daily generated power in MWh for the month of April 2024**

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 23: Unit 5 daily generated power in MWh for the month of April 2024




Figure 24: Unit 6 daily generated power in MWh for the month of April 2024

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.5 Pollutant Tonnages

The emitted pollutant tonnages for April 2024 are provided in table 6.

Table 6: Pollutant tonnages for the month of April 2024

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	79.2	5 327.5	853.6
Unit 2	64.4	3 339.5	479.4
Unit 3	97.2	5 115.1	858.3
Unit 4	18.7	789.8	153.1
Unit 5	357.3	3 399.6	639.9
Unit 6	57.4	2 719.0	575.7
SUM	674.3	20 690.5	3 560.0

2.6 Operating days in compliance to PM AEL Limit

Table 7: Operating days in compliance with PM AEL limit of April 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	16	2	0	6	8	43.8
Unit 2	19	5	0	2	7	41.8
Unit 3	22	6	0	2	8	41.8
Unit 4	3	2	0	2	4	52.0
Unit 5	0	2	0	26	28	179.5
Unit 6	24	4	0	1	5	42.8
SUM	84	21	0	39	60	

2.7 Operating days in compliance to SOx AEL Limit

Table 8: Operating days in compliance with SOx AEL limit of April 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	25	1	0	0	1	2 787.9
Unit 2	28	0	0	0	0	2 165.6
Unit 3	30	0	0	0	0	2 242.9
Unit 4	9	0	0	0	0	1 795.5
Unit 5	29	0	0	0	0	1 664.4
Unit 6	30	0	0	0	0	1 964.0
SUM	151	1	0	0	1	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Operating days in compliance to NO_x AEL Limit

Table 9: Operating days in compliance with NO_x AEL limit of April 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
Unit 1	26	0	0	0	0	445.4
Unit 2	28	0	0	0	0	310.7
Unit 3	30	0	0	0	0	377.1
Unit 4	9	0	0	0	0	347.9
Unit 5	29	0	0	0	0	313.0
Unit 6	30	0	0	0	0	417.9
SUM	152	0	0	0	0	

2.9 Reference values

Table 10: Reference values for data provided, April 2024

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	6.35	7.44	6.57	8.65	7.06	11.01
Moisture	%	4.13	3.75	3.94	2.98	4.04	2.02
Velocity	m/s	26.2	21.0	26.7	21.1	23.5	25.4
Temperature	°C	132.3	123.7	128.6	108.4	120.1	161.5
Pressure	mBar	918.3	924.0	917.1	964.3	983.3	914.4

2.10 Continuous Emission Monitors

2.10.1 Reliability

Continuous emission monitors were available for more than 80% of the reporting period except for unit 4 gas monitors due unit start up. The emitted pollutant tonnages for April 2024 are provided in table 6.

Table 11: Average percentage (%) availability of monitors for the month of April 2024.

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	100.0	99.8	99.8
Unit 2	99.7	99.9	99.9
Unit 3	100.0	99.7	99.7
Unit 4	100.0	6.4	6.4
Unit 5	87.7	100.0	100.0
Unit 6	100.0	97.9	97.9

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.2 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

Unit 2

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

Unit 3

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

Unit 4

- Returned to service from outage.

Unit 5

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

Unit 6

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.3 Sampling dates and times**Table 12:** Dates of last full conducted CEMS verification tests for PM for unit 4 and 6 only

Name of service provider:		Stacklabs Environmental Services CC		
Address of service provider:		10 Chisel Street Boltonia Krugersdorp 1739		
Stack/ Unit	PM	SO₂	NO_x	CO₂
1	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
2	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
3	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
4	2021/07/13 14h31	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
5	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
6	2020/09/09 06h41	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13

Note: The CEMS verification tests for PM, SO₂ and NO_x were performed in October 2022 and failed. The spot tests were done in August 2023.

Table 13: Dates of last conducted CEMS Spot verification tests for PM, SO₂ and NO_x (without unit 4 and 6 PMs)

Name of service provider:		Levego Environmental services		
Address of service provider:		Building R6 Pineland site Ardeer Road Modderfontein 1645		
Stack/ Unit	PM	SO₂	NO_x	CO₂
1	2023/08/01 19h33	2023/08/01 19:33	2023/08/01 19:33	2023/08/01 19:33
2	2023/07/29 21:17	2023/07/29 21:17	2023/07/29 21:17	2023/07/29 21:17
3	2023/08/06 03:00	2023/08/06 03:00	2023/08/06 03:00	2023/08/06 03:00
4	Dates in table 12 above	2023/08/04 19:39	2023/08/04 19:39	2023/08/04 19:39
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30
6	Dates in table 12 above	2023/08/05 15:52	2023/08/05 15:52	2023/08/05 15:52

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Note: The CEMS Spot verification tests for PM, SO₂ and NO_x were performed in August 2023. PM spot verification test results for units 4 and 6 failed and old curves are still in use.

2.11 Units Start-up information

Table 14: Start-up information

Unit	1	
Fires in	2024/04/04	08h12
Synchronization with Grid	2024/04/04	12h43
Emissions below limit	2024/04/04	19h00
Fires in, to synchronization	4.31	HOURS
Synchronization to < Emission limit	6.17	HOURS

Unit	1	
Fires in	2024/04/21	01h47
Synchronization with Grid	2024/04/21	06h21
Emissions below limit	2024/04/21	09h00
Fires in, to synchronization	4.34	HOURS
Synchronization to < Emission limit	2.39	HOURS

Unit	2	
Fires in	2024/04/09	07h01
Synchronization with Grid	2024/04/09	21h50
Emissions below limit	2024/04/10	06h03
Fires in, to synchronization	14.49	HOURS
Synchronization to < Emission limit	8.13	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	4	
Fires in	2024/04/23	02h21
Synchronization with Grid	2024/04/23	03h58
Emissions below limit	2024/04/23	03h59
Fires in, to synchronization	1.37	HOURS
Synchronization to < Emission limit	0.01	HOURS

Unit	4	
Fires in	2024/04/30	11h36
Synchronization with Grid	2024/04/30	16h55
Emissions below limit	2024/04/30	18h00
Fires in, to synchronization	5.19	HOURS
Synchronization to < Emission limit	1.05	HOURS

Unit	5	
Fires in	2024/04/01	04h56
Synchronization with Grid	2024/04/02	01h04
Emissions below limit	2024/04/12	09h45
Fires in, to synchronization	20.08	HOURS
Synchronization to < Emission limit	248.41	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	6	
Fires in	2024/04/23	22h06
Synchronization with Grid	2024/04/24	08h24
Emissions below limit	2024/04/25	06h01
Fires in, to synchronization	10.18	HOURS
Synchronization to < Emission limit	21.37	HOURS

2.12 Emergency generation

Table 15: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	744	744	744	744	744	744
Emergency Hours declared including hours after standing down	608.6	657.6	720.0	201.8	696.0	713.1
Days over the Limit during Emergency Generation	8	7	8	4	28	5

During the period under review all Units were on emergency generation in force from 01 April 2024 until 30 April 2024.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.13 Complaints register.

Table 16: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

2.14 Air quality improvements and social responsibility conducted.

Air quality improvements

None

Social responsibility conducted.

None

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.15 Ambient air quality monitoring

Marapong ambient air quality monitoring station was relocated from the previous location to Ditheku primary school and commissioned to service on 20 March 2024. The May 2024 ambient air quality monitoring report is sent with the report as addendum.

2.16 Electrostatic precipitator and Sulphur plant status

Unit 1

- 9 fields out of service, will be repaired during next opportunity.
- No abnormalities on the SO₃ plant. Preventive maintenance done during the month.

Unit 2

- Unit returned to service.

Unit 3

- 1 field out of service, will be repaired during next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 4

- Unit returned to service.

Unit 5

- 4 fields out of service, will be repaired during next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

Unit 6

- 8 fields out of service, will be repaired during next opportunity.
- No abnormalities on the SO₃ plant. Preventative maintenance done during the month.

SO₃ common plant

- No abnormalities on the sulphur storage plant.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.17 General

Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

Ambient air quality monitoring report

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.