

Dr Patience Gwaze
National Air Quality Officer
Department of Forestry, Fisheries and the Environment
473 Steve Biko Street,
Arcadia,
Pretoria
0001

Date: 05 September 2024 Enquiries: Lesiba Kgobe Tel: 013 699 7817

By email: pgwaze@dffe.gov.za

Cc: dmakhubele@dffe.gov.za simelanenl@nkangaladm.gov.za

Dear Dr Gwaze,

JULY 2024 MONTHLY PROGRESS REPORT ON THE POSTPONEMENT OF MINIMUM EMISSION STANDARD CONDITIONS FOR KUSILE POWER STATION: REF: LSA223027

ESKOM WAS ISSUED A MINIMUM EMISSION STANDARDS (MES) POSTPONEMENT IN RESPECT OF KUSILE'S SO_2 LEVELS BY THE DFFE ON 5 JUNE 2023. THE VARIED ATMOSPHERIC EMISSION LICENCE (AEL) WAS ISSUED BY THE NKANGALA DISTRICT MUNICIPALITY ON 13 JUNE 2023. BOTH THE MES APPROVAL AND THE AEL ALLOW ESKOM TO OPERATE THE TEMPORARY STACKS WITHOUT FGD. THE APPROVALS ARE ISSUED SUBJECT TO SEVERAL CONDITIONS, INCLUDING THAT ESKOM IMPLEMENT MEASURES TO MINIMISE THE IMPACT ON HUMAN HEALTH.

This letter provides an update on key issues, including specific reporting requirements identified by the authorities in the various approvals for the Kusile temporary stacks project. Monitoring and mitigation is being implemented as far as practical in line with the programme in the Kusile Power Station Temporary Stack Monitoring Framework approved by the authorities on 18 September 2023.

As an initial point, I would like to confirm that no exceedances of the stack or ambient trigger level conditions were recorded during July 2024.

- Progress of repairs of permanent stacks for the duration of the operation of the temporary stacks.
 - The target date for the recovery of the West stack currently forecasted to January 2025.

Generation Division – Coal New Build Unit Management Department (Kusile Power Station) R545 Kendal/Balmoral Road, Haartebeesfontein Farm, Witbank Postnet Suite 283 Private Bag X 7297 Witbank 1035 SA Tel+27 13 693 4320 Fax +27 86 768 3030 www.eskom.co.za

Risks:

- Alimak operation is not possible during windy conditions and wind direction can result in flue gas contamination at the top of the stack from units 1 or 3 preventing safe access to the stack.
- II. The slurry build-up removed during the cleaning process totally different from original samples taken, posing a risk with the cleaning process progress. Cleaning process changed to manual hand cleaning.

The Permanent Stack recovery progress report is attached (Annexures A).

2. Temporary Stack Emission Monitoring

Continuous Emission Monitoring (CEMS):

- I. Unit 1, 2 and 3 CEMS are installed and commissioned.
- II. Unit 1 is operated with unity curve for PM and Unit 3 is operating on spot curve for PM, due to monitor replaced and Unit 2 PM is also operating with a spot check due to a failed correlation test. Correlation tests for Unit 2 and 3 completed on 07/08/2024 and 17/08/2024 respectively. Correlation test for Unit 1 will be planned and dates will be reported in the future reporting. Unit 2 emissions monitoring will be retrofitted upon finalization of correlation test and implementation of correlation curves.
- III. All units are operating with valid parallel curves.

Stack Performance:

- I. The Kusile Monthly Emission report for July 2024, which includes emission data for Units 1,2, 3 and 4 is attached (Annexure B).
- II. Based on the available data information, Kusile Unit 1, 2 and 3 operated in compliance with the AEL emission limits for PM, NOx or SO₂ during July 2024.

3. Health Screening for the increased SO₂ emission and associated health impacts

- Communication system is developed to enable communication with the health ambassadors in the various receptor areas.
- II. Two SMS's have been communicated thus far to the ambassadors and communities. The first SMS was to assure ambassadors that the stacks are operating within the MES limit, and the second SMS was to keep ambassadors on the loop and that they shall be contacted with regards to emergencies and general update on the operations of the temporary stacks SO₂ limits.
- III. The IT department has finalized the toll-free line for the communities to use should a need arise regarding the SO₂ emission. A pre-loaded voice messaging will be loaded on the toll free line, which will guide the community members on the various health enquiries that they will be having. The process is at its final stage, pending the recording and voice upload stage.
- IV. Kusile Power Station Stakeholder Management is engaging with Emalahleni FM for voice recording.
- V. Engagement with GHB Farms and Topigs will be conducted once the date had been agreed upon.

4. Occupational Health and Hygiene status

4.1. Continuous SO₂ Perimeter Monitoring:

- I. Weekly monitoring of the plant's perimeter for SO₂ surges were conducted throughout July 2024.
- II. SO₂ levels along the perimeter remained below detection levels, meeting the statutory requirement of 0.5 ppm OEL-STEL/C.

4.2. Conclusion:

Our continuous SO₂ perimeter monitoring indicated compliance with regulatory limits with no ongoing issues. We will continue to monitor and investigate any anomalies to ensure the safety and well-being of both our workers and the surrounding community.

5. Stakeholder Engagement Plan and Status

Stakeholders	Method of engagement Involvement			
Employees	 Awareness sessions Leadership briefings (GM's address) Employee engagements 	Once a monthEvery FridayMonthly	Complete	
Local Municipalities	Face-to-face meeting	Once a quarter	Meeting was held on the 9 th of July 2024, follow up meeting planned for 3 rd September 2024	
Media	AdvertPrint	When required	Eskom media desk to publish	

6. Ambient Air Quality Monitoring

- In order to better assess compliance with national ambient air quality standards, identify potential sources of pollution, protect public health and the environment and establish a baseline for future mitigation measures Eskom has installed additional ambient air quality monitoring stations at Balmoral and Wilge. The existing air quality monitoring stations (Kendal, Phola and Chicken Farm) will complement the additional monitoring sites to reduce uncertainties and improve the understanding of air quality issues in the area.
- II. The Balmoral and Wilge monitoring stations are equipped to monitor ambient concentrations of sulphur dioxide (SO₂) continuously. In addition, meteorological parameters of wind velocity, wind direction and ambient temperature, humidity, ambient pressure and rainfall, amongst others, are also recorded.
- III. The following parameters, nitrogen dioxide (NO2), ozone (O3) and fine particulate matter of particulate size <10µm and particulate size <2.5µm in diameter (PM10 and PM2.5) will be monitored from 01 July 2024.
- IV. The data for this reporting period (01 30 July 2024) were analysed for ambient SO2 as monitored at Balmoral, Chicken Farm, Phola and Wilge air quality monitoring stations. The Particulate Matter and NO2 data were further analysed for Chicken Farm and Phola.

- V. Full dynamic calibration audits are carried out on the gas analysers (SO₂, NO₂ and O₃ analysers) quarterly and particulate matter analysers are calibrated every six months. All calibration results and certificates are filed in the laboratory for assessment purposes. Inter-laboratory calibrations are routinely carried out with other accredited laboratories, to enhance quality control.
- VI. There were no exceedances of the NO₂ hourly limit of 106 ppb recorded at the monitoring stations during the July 2024 monitoring period.
- VII. There were two (2) exceedances of SO₂ 10-minutes limit of 191 ppb at both Balmoral and Chicken Farm and three (3) exceedances at Phola recorded during the monitoring period. There were exceedances of SO₂ hourly limit of 134 ppb at all the monitoring site under review.
- VIII. There were twenty (20) exceedances of the PM2.5 daily limit of 40 μg/m3 at Phola, and ten (10) exceedances of the PM2.5 daily limit of 40 μg/m3the Chicken Farm monitoring station. There were eighteen (18) exceedances of PM10 daily limit of 75 μg/m3 at Phola air quality monitoring station and twenty-nine (29) exceedances of PM10 daily limit of 75 μg/m3 recorded at Chicken Farm air quality monitoring station.
- IX. There were no events that triggered the notification of stakeholders in terms of the agreed AEGL recorded in July 2024.

Table 1 Highest SO₂ concentrations recorded (in ppb)

Monitoring Stations	10-min average	Date	Hourly average	Date	Daily average	Date
Balmoral	325.9	05/07/2024 10:30	197.0	05/07/2024 11h00	15.1	13/07/2024
Chicken Farm	228.8	21/07/2024 12:40	149.1	21/07/2024 13:00	32.4	21/07/2024
Phola	236.6	25/07/2024 20:30	145.0	17/07/2024 09:00	42.0	13/07/2024
Wilge	166.9	13/07/2024 08:00	150.8	13/07/2024 08:00	30.1	13/07/2024

- X. Good representative percentage data was recovered for all the parameters monitored during the monitoring period under review at all the monitoring stations.
- XI. The raw monitoring data, downloaded at 1-minute averages, is available in real-time to the DFFE-managed South African Air Quality Information System (SAAQIS) since the 14th of December 2023 for all Eskom air quality monitoring sites.
- XII. The detailed July 2024 Kusile ambient monitoring report is attached (Annexure C).

7. Poultry Health Monitoring

- I. A service provider had been appointed for Kendal Poultry monitoring per the condition of environmental authorisation (record of decision) and the MES approval. Execution of the monitoring is on hold due to the outbreak of Avian Influenza.
- II. Engagements between Eskom and Kendal Poultry are ongoing regarding resumption of monitoring.
- III. Alternative options are being explored by Kendal Poultry and Eskom on how to resume monitoring and analysis production data to assess any potential impacts.

8. Animal Health Monitoring

- I. Eskom has reached an agreement with Topigs and GHB farms regarding animal/pig health monitoring continues since March 2024.
- II. Monitoring is carried out according to prescribed protocol.

9. Emergency preparedness and response

- There has been no incidence of exceedance that required emergency response from Kusile Power Station, however the Emergency Response Team (ERT) remain on high alert.
- II. The ERT is in regular communication with Emalahleni Local Municipality Emergency Services as per the Mutual Aid Agreement.
- III. Emalahleni Local Municipality Emergency Services representatives in Disaster Management, Fire and Emergency Services, and Environment were added in Kusile Power Station Distribution List for regular updates.
- IV. All other Service Level Agreement (SLA's) with relevant stakeholder (Kendal Power Station) remain in force for duration of the temporal stack.

In conclusion, I believe the above illustrates that Eskom is committed to complying with the conditions of the approvals granted with respect to the Kusile temporary stacks. Eskom is implementing measures to ensure that it understands its impact and can limit its operations' environmental and health impact. Further, where full implementation of the conditions is not yet completed, Eskom is working with relevant stakeholders with focus to ensure the remaining issues are resolved as soon as possible.

I hope the above is in order. Please contact our team if you require any further information.

Christopher Nani

Yours sincerely

ACTING GENERAL MANAGER (KUSILE POWER STATION)

DATE: 05/09/2024

List of annexures

Annexure A: Kusile West Chimney Recovery Project - July 2024

Annexure B: Kusile Monthly Emission Report – July 2024 Annexure C: Kusile Ambient Air Quality Report – July 2024



Dr P. Gwaze
National Air Quality Officer
Department of Forestry, Fisheries and Environment
Private Bag X 447
PRETORIA
0001

Date: 15 August 2024

Enquiries: S Mahlangu Tel: 013 699 7097

Monthly Progress Report for Kusile Power Station West Stack Recovery July 2024:

	Status	Start Date	End Date
Clean vertical flue unit 2	0%	3 September 24	11 October 24
Clean vertical flue unit 1	65%	6 June 2024	30 August 2024
Clean vertical flue unit 3:	95%	12 June 2024	19 August 2024
Fabricate new Lobster for K1(First			
Delivery	80%	7 June 2024	16 August 24
Fabricate new 55 m platform	20%	7 June 2024	30 Aug 2024

NOTES:

West Stack:

• The target date for the recovery of the West stack currently forecasted to January 2025.

Risks

- Alimak operation is not possible during windy conditions and wind direction can result in flue gas contamination at the top of the stack from units 1 or 3 preventing safe access to the stack.
- The slurry build-up removed during the cleaning process totally different from original samples taken, posing a risk with the cleaning process progress. Cleaning process changed to manual hand cleaning.
- Flue lining blocks found to be cracked and/ or damaged underneath the slurry build-up. Significant replacement will be required.

Remedial action under review due to time lost and recovery program is being developed. Processes activated in term of funding required for liner replacement.

Trust, you find the above in order.

P. 11/e

Kind Regards,

Zandi Shange

General Manager - Kusile Power Station Project

Generation Division - Group Capital Kusile Power Station Project R545 Kendal/Balmoral Rd Haartebeesfontein Farm Witbank Postnet Suite 46 Emalahleni 1035 SA Tel +27 13 699 7097 www.eskom.co.za



Ms Nompumelelo Simelane Nkangala District Municipality PO Box 437 Middleburg 1050

Date:

August 2024

Enquiries: Lesiba Kgobe Tel: +27 13 699 7817

Ref: Kusile Power Station AEL (17/4/AEL/MP311/12/01)

Dear Ms. Simelane

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR JULY 2024


This serves as the monthly report required in terms of Section 7.6 in Kusile Power Station's Atmospheric Emission License: 17/4/AEL/MP311/12/01. The emissions are for the month of July 2024.

Hoping the above will meet your satisfaction.

Yours sincerely

hristopher Nani ACTING GENERAL MANAGER

1. KUSILE POWER STATION MONTHLY EMISSIONS REPORT: Atmospheric Emission License 17/4/AEL/MP311/12/01



2. Raw Materials and Products

Raw	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate July-2024	
Materials and	Coal	Tons	1 818 083	744 712	
Products	Fuel Oil	Tons	5 533	2816.31	
	Limestone	Tons	72 917	10436	
	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate July-2024	
Dunduntina	Energy	GWh	3 214.08	1 411.46	
Production Rates	Ash	Tons	796 300	206 732.17	
	Gypsum	Tons	155 100	5 844.16	
	RE PM	kg/MWh	not specified	0.07	
	RE SOx	kg/MWh	not specified	5.46	

3. Energy source characteristics

Fuel Characteristic	Units	Stipulated Range	Monthly Average Content
Coal Sulphur	%	1.3	0.74
Ash in Coal	%	38	27.76
Fuel Oil Sulphur	%	3.5	2.97

4. Emissions Limits (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NOx
North	50	3500	750
South	50	1000	750

5. Abatement Technology (%)

Associated Unit/Stack	Technology Type	Efficiency Jul- 2024	Utilisation Jul - 2024	Technology Type	Efficiency Jul-2024	Utilisation Jul- 2024
Unit 1	FFP	99.92%	100%	FGD	Out of service	Out of service
Unit 2	FFP	99.97%	100%	FGD	Out of service	Out of service
Unit 3	FFP	99.94%	100%	FGD	Out of service	Out of service
Unit 4	FFP	99.99%	100%	FGD	99.93%	100%

Note: Both the FFP and FGD does not have bypass mode operation, hence plant 100% Utilised.

6. Monitoring reliability (%)

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	100.0	100.0	100.0
Unit 2	100.0	100.0	100.0
Unit 3	100.0	100.0	100.0
Unit 4	100.0	62.3	86.8

Unit 4: From the 15th of July 2024 Unit 4 SO2 monitor was fault, the monitor was fixed and calibrated.

7. Emissions Performance

Table 7.1: Monthly tonnages for the month of July - 2024

Associated Unit/Stack	PM	SO ₂	NO _x
Unit 1	43.3	2 899	884
Unit 2	13.1	1 240	346
Unit 3	35.5	3 437	1 040
Unit 4	0.7	125	595
SUM	92.6	7 701	2 865

Table 7.2: Operating days in compliance to PM AEL Limit - July 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
Unit 1	31	0	0	0	0	18.5
Unit 2	26	0	0	0	0	14.5
Unit 3	31	0	0	0	0	16.8
Unit 4	26	0	0	0	0	0.5
SUM	114	0	0	0	0	

Table 7.3: Operating days in compliance to SO₂ AEL Limit – July 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm³)
Unit 1	31	0	0	0	0	1 208.7
Unit 2	30	0	0	0	0	1 290.0
Unit 3	31	0	0	0	0	1 650.5
Unit 4	27	0	0	0	0	95.0
SUM	119	0	0	0	0	


Table 7.4: Operating days in compliance to NOx AEL Limit - July 2024


Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	31	0	0	0	0	370.8
Unit 2	30	0	0	0	0	353.6
Unit 3	31	0	0	0	0	498.9
Unit 4	27	0	0	0	0	409.5
SUM	119	0	- 0	0	0	


Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO2


Table 7.5: Legend Description


Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions
































8. Correlation and Parallel test status

Unit 1:

- Unit 1 is operating with unity curve for PM. PM correlation test is invalid due to the monitor that was replaced, and the full correlation tests is planned for 30/08/2024 to 06/09/2024.
- The unit is operating with a valid parallel curve.

Unit 2:

- Unit 2 is operating with spot check. Correlation tests completed on 07/08/2024. Station awaiting report from service provider.
- The unit is operating with a valid parallel curve.

Unit 3

 Unit 3 is operating with spot check test curve. PM correlation test is invalid due to the monitor that was replaced, a new correlation tests completed on 17/08/2024. Station awaiting report from service provider.

Unit 4:

• Unit 4 is operated with valid correlation and parallel curves.

9. Shut down and Light up information

Unit No. 1	Event 1				
Breaker Open (BO)	6:40 am	2024/07/09			
Draught Group (DG) Shut Down (SD)	6:40 am	2024/07/09			
BO to DG SD (duration)	00:00:00	DD:HH:MM			
Fires in time	8:05 am	2024/07/09			
Synch. to Grid (or BC)	10:25 pm	2024/07/09			
Fires in to BC (duration)	00:14:20	DD:HH:MM			
Emissions below limit from BC (end date)	not > limit	not > limit			
Emissions below limit from BC (duration)	n/a	DD:HH:MM			

Unit No. 2	Event 1	Eve	nt 2
Breaker Open (BO)		3:15 pm	2024/07/24
Draught Group (DG) Shut Down (SD)		DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	DD:HH:MM	n/a	DD:HH:MM
Fires in time			
Synch. to Grid (or BC)			
Fires in to BC (duration)	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)			
Emissions below limit from BC (duration)	DD:HH:MM		DD:HH:MM

Unit No. 4	Eve	nt 1	Ever	nt 2	
Breaker Open (BO)	4:20 am	2024/07/15	10:25 am	2024/07/24	
Draught Group (DG) Shut Down (SD)	4:20 am	2024/07/15	7:35 pm	2024/07/24	
BO to DG SD (duration)	00:00:00	DD:HH:MM	00:09:10	DD:HH:MM	
Fires in time	4:45 am	2024/07/15	11:00 am	2024/07/29	
Synch. to Grid (or BC)	12:1,5 pm	2024/07/15	8:40 pm	2024/07/29	
Fires in to BC (duration)	00:07:30	DD:HH:MM	00:09:40	DD:HH:MM	
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit	
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	

11.Complaints

No complaints reported for the month of July 2024

Date and time complaint was received	Complaint received	Source code name	Root cause analysis	Calculation of impact/emissions associated with incidents and dispersion modelling of pollutants where applicable.	Measures implemented or to be implemented to prevent recurrence	Date by which measures will be implemented
No complair	nts reported f	or the mor	nth of July 2	2024		

⊗Eskom

Kusile Ambient Air Quality Monitoring

JULY 2024

1. INTRODUCTION

At the request of Environmental Management, Research, Testing and Development Department (RT&D) air quality team initiated an additional ambient air quality monitoring site at Balmoral and Wilge, in the vicinity of Kusile power station. The objective is to assess compliance with national ambient air quality standards, identify potential sources of pollution, protect public health and the environment and establish a baseline for future mitigation measures to enable Eskom to operate temporary stacks at the Kusile power stations at emission levels above the levels authorised in the station's Atmospheric Emission Licence (AEL). The existing air quality monitoring stations (Phola and Chicken Farm) will complement the additional monitoring stations to reduce uncertainties, as each monitoring station has an objective linked to a power station of interest.

The commissioning of Ogies air quality monitoring station has been delayed due to procurement issues, however Kusile Power station, Research, Testing and Development and Generation Environmental Management (GEM) are working tirelessly to resolve it and a new date will be communicated to the Department of Fisheries, Forestry and Environment.

The Balmoral and Wilge monitoring stations are currently equipped to continuously monitor ambient concentrations of sulphur dioxide (SO₂) and nitrogen dioxide (NO₂). In addition, meteorological parameters of wind velocity, wind direction and ambient temperature, humidity, ambient pressure and rainfall, amongst others are also recorded.

The following parameters, Ozone (O₃) and fine particulate matter of particulate size <10μm and particulate size <2.5μm in diameter (PM₁₀ and PM_{2.5}) will be monitored from 01st of October 2024.

The data for this reporting period (01 – 31 July 2024) were analysed for ambient SO_2 and NO_2 as monitored at Balmoral, Chicken Farm, Phola and Wilge air quality monitoring stations. The Particulate Matter (PM_{10} and $PM_{2.5}$) data were further analysed for Chicken Farm and Phola.

This report focuses on the results of the ambient air quality monitoring stations; results from stack monitoring, fugitive dust and animal health are addressed in other reports.

2. DATA ACQUISITION AND QUALITY CONTROL

Each monitoring station is visited every two weeks by trained technicians for routine service. Zero and span checks are carried out on each analyser during routine services and any discrepancies are logged and used during data verification at Eskom RT&D Sustainability Department.

Full dynamic calibration audits are carried out on the gas analysers (SO_2 , NO_2 and O_3 analysers) quarterly and particulate matter analysers are calibrated every six months. All calibration results and certificates are filed in the laboratory for assessment purposes. Interlaboratory calibrations are routinely carried out with other accredited laboratories, to enhance quality control.

Data at the monitoring stations are logged directly using dedicated CR-1000 Campbell Scientific data loggers. Permanent data records of all calculated 10-minutes mean values of all parameters monitored, together with minimum and maximum values, are stored on the logging device. These are derived from 10-second scans and are also logged and saved in 1-minute intervals. The raw 1-minute average data is also transferred live to the South African Ambient Air Quality Information System (SAAQIS) server since the 14th of December 2023

daily however due to system challenges the transfer stopped. In the event that the data is not available on the SAAQIS portal the stakeholders are advised to contact Eskom air quality monitoring team at RT&D. Recorded data are downloaded remotely from the site through communicators that are connected to the Eskom network and transferred onto a central computer for verification and validation.

3. MONITORING STATION LOCATIONS

Figure 1 below indicates the locations of the air quality monitoring stations in relation to the Kusile power station. The new monitoring stations, Balmoral and Wilge, are denoted by green icons and the pre-existing monitoring stations, Chicken Farm and Phola, by yellow icons. Kendal air quality monitoring station commenced in 1993 in response to research needs identified to understand the short-range impacts from Kendal power station. The monitoring station was located to monitor the worst-case impacts of emissions from the power station as highest impacts have been proven to be 2-5km from point of source. The data has been made available to Department of Forestry, Fisheries and the Environment (DFFE).



Figure 1: Air Quality Monitoring stations in relation to Kusile power station

4. MONITORING RESULTS AND DISCUSSIONS

The data is statistically analysed to assess the diurnal and monthly variations of the air pollutants, as well as to evaluate it against the current national ambient air quality standards for SO₂, NO₂, O₃, PM_{2.5} and PM₁₀.

4.1. DATA RECOVERY

The SANAS guideline figure of 90% data availability per parameter monitored is used as a standard for representative data capture. This describes the required completeness of data set for the reporting of averages and is based on standard arithmetic calculations. The completeness calculations for data sets exclude zero and span data and times where service and/or maintenance is being conducted on the instruments in question. Station availability is reported as a measure of the percentage of time that electrical power was available to the monitoring station.

Kusile AQ Report: July 2024

Table 1: Percentage data recovery per parameter monitored in July 2024

Stations name	SO ₂	NO ₂	O ₃	PM _{2.5}	PM ₁₀	WSP	WDR	Station Availability
Balmoral (BL)	99.3	NM	NM	NM	NM	99.7	99.7	99.7
Chicken Farm (CF)	96.4	98.0	99.5	75.1	95.8	99.9	98.5	99.9
Phola (PO)	99.1	98.9	98.7	98.5	69.4	99.7	99.7	99.3
Wilge (WL)	99.9	69.2	NM	NM	NM	9.3	9.3	100

NM - not monitored.

Good representative percentage data was recovered for most of parameters monitored during the monitoring period under review at all the monitoring stations. Wilge monitoring station reported low data for meteorological parameters due to a faulty wind sensor, however it has been replaced.

4.2. METEOROLOGICAL OBSERVATIONS

The distributions of wind direction and wind speed for daytime and night-time hours for the reporting period are summarised on polar diagrams. The centre of the wind rose depicts the position of the air quality monitoring site. The positions of the spokes in the polar diagram represent directions from which the wind was blowing. The length of the segment indicates the percentage of the time the wind blew from that direction and the speed in the various categories are denoted by colours and width.

4.2.1. BALMORAL AIR QUALITY MONITORING STATION

The wind at Balmoral monitoring station was coming from the north, east to north-north-westerly directions during the day and from the southerly to west south-west, westerly to north-westerly directions during the night time. The monitoring station is north-east of Kusile power station.




Figure 2: Wind profiles at Balmoral monitoring station

4.2.2. CHICKEN FARM AIR QUALITY MONITORING STATION

The dominant wind directions at Chicken Farm monitoring station during the day were west-south-west, west-north-west and north-west. During the night, the dominant wind directions were north, north-east, south and north-west. The monitoring station is south of Kusile power station.

Kusile AQ Report: July 2024 Page No: 3




Figure 3: Wind profiles at Chicken Farm monitoring station

4.2.3. PHOLA AIR QUALITY MONITORING STATION

The dominant wind directions at Phola monitoring station during the day were south-west, west, west-north-west and north-west. During the night, the dominant wind directions were east-south-east, south-east and south-south-east. The monitoring station is south-east of Kusile power station.




Figure 4: Wind profiles at Phola monitoring station.

4.2.4. WILGE AIR QUALITY MONITORING STATION

The wind at Wilge monitoring station was coming from the north-east, west to west-north-west and north-north-west directions during the day. The dominant wind sectors during the night are east-north-east, west-north-west and north-west. The monitoring station is south-east of Kusile power station.




Figure 5: Wind profiles at Wilge monitoring station.

4.3. EXCEEDANCES OF THE NATIONAL AMBIENT AIR QUALITY LIMITS

Table 2: National Ambient Air Quality Standards

Pollutant	Unit	Period	Limit	Number of annual exceedances allowed	Source
Carbon Monoxide	Ppm	1hr	26.	88.	DFFE
Carbon Monoxide	Ppm	8hr	8.7	11.	DFFE
(PM ₁₀) by Beta gauge	μg/m³	24hr	75.	4.	DFFE
(PM ₁₀) by Beta gauge	μg/m³	1year	40.	0.	DFFE
(PM _{2.5}) by Beta gauge	μg/m³	24hr	40	4	DFFE
(PM _{2.5}) by Beta gauge	μg/m³	1year	20	0	DFFE
Nitrogen dioxide	Ppb	1year	21.	0.	DFFE
Nitrogen dioxide	Ppb	1hr	106.	88.	DFFE
Ozone	Ppb	8hr	61.	11.	DFFE
Sulphur dioxide	Ppb	1hr	134.	88.	DFFE
Sulphur dioxide	Ppb	10min	191.	526.	DFFE
Sulphur dioxide	Ppb	24hr	48.	4.	DFFE
Sulphur dioxide	Ppb	1year	19.	0.	DFFE

The National Department of Forestry, Fisheries and the Environment (DFFE) has set the South African Ambient Air Quality Standards for the criteria pollutants as illustrated in Table 2.

Table 3: Highest SO₂ concentration recorded (in ppb).

Monitoring Stations	10-min average	Date	Hourly average	Date	Daily average	Date
Balmoral	325.9	05/07/2024 10:30	197.0	05/07/2024 11h00	15.1	13/07/2024
Chicken Farm	228.8	21/07/2024 12:40	149.1	21/07/2024 13:00	32.4	21/07/2024
Phola	236.6	25/07/2024 20:30	145.0	17/07/2024 09:00	42.0	13/07/2024
Wilge	166.9	13/07/2024 08:00	150.8	13/07/2024 08:00	30.1	13/07/2024

Kusile AQ Report: July 2024 Page No: 5

There were two (2) exceedances of SO_2 10-minutes limit of 191 ppb at both Balmoral and Chicken Farm and three (3) exceedances at Phola recorded during the monitoring period. There were exceedances of SO_2 hourly limit of 134 ppb at all the monitoring site under review. The highest SO_2 concentrations recorded at the monitoring stations are indicated in Table 3 and figures 6 to 9 below.




Figure 6: Time series graph for the SO₂ daily mean concentrations at Wilge AQM station




Figure 7: Time series graph for the SO₂ daily mean concentrations at Balmoral AQM station




Figure 8: Time series graph for the SO₂ daily mean concentrations at Phola AQM station




Figure 9: Time series graph for the SO₂ daily mean concentrations at Chicken Farm AQM station

There were no exceedances of the NO_2 hourly limit of 106 ppb recorded at the monitoring stations during the July 2024 monitoring period. There were twenty (20) exceedances of the $PM_{2.5}$ daily limit of 40 μ g/m³ at Phola, and ten (10) exceedances of the $PM_{2.5}$ daily limit of 40 μ g/m³ the Chicken Farm monitoring station. There were eighteen (18) exceedances of PM_{10} daily limit of 75 μ g/m³

at Phola air quality monitoring station and twenty-nine (29) exceedances of PM₁₀ daily limit of 75 µg/m³ recorded at Chicken Farm air quality monitoring station. See Figure 10 to 11 below.




Figure 10: Time series graph for the PM₁₀ daily mean concentrations at Chicken Farm AQM station




Figure 10: Time series graph for the PM_{2.5} daily mean concentrations at Chicken Farm AQM station




Figure 11: Time series graph for the PM₁₀ daily mean concentrations at Phola AQM station




Figure 12: Time series graph for the PM_{2.5} daily mean concentrations at Phola AQM station

Table 4: Exceedances above national ambient air quality limits

	PM ₁₀ Daily Exceedances (Phola)								
Pollutant	Limit	Year	Month	Day	Conc. (µg/m³)				
PM ₁₀ .	75	2024	July	01	90.3				
PM ₁₀ .	75	2024	July	02	76.1				
PM ₁₀ .	75	2024	July	04	89.8				
PM ₁₀ .	75	2024	July	06	86.2				
PM ₁₀ .	75	2024	July	07	104.7				
PM ₁₀ .	75	2024	July	08	81.4				
PM ₁₀ .	75	2024	July	18	80.3				
PM ₁₀ .	75	2024	July	19	161.7				
PM ₁₀ .	75	2024	July	20	128.2				
PM ₁₀ .	75	2024	July	22	118.7				
PM ₁₀ .	75	2024	July	23	111.8				
PM ₁₀ .	75	2024	July	24	104				
PM ₁₀ .	75	2024	July	25	91.1				
PM ₁₀ .	75	2024	July	26	111.5				
PM ₁₀ .	75	2024	July	27	100.8				
PM ₁₀ .	75	2024	July	28	101.6				
PM ₁₀ .	75	2024	July	30	97.2				
PM ₁₀ .	75	2024	July	31	77.5				
<u>"</u>		PM _{2.5} C	Daily Excee	dances	(Phola)				
PM _{2.5}	40	2024	July	01	50.7				
PM _{2.5}	40	2024	July	02	43.1				
PM _{2.5}	40	2024	July	07	48.5				
PM _{2.5}	40	2024	July	10	41.7				
PM _{2.5}	40	2024	July	11	43.8				
PM _{2.5}	40	2024	July	12	79.6				
PM _{2.5}	40	2024	July	13	79.9				
PM _{2.5}	40	2024	July	14	59.8				
PM _{2.5}	40	2024	July	16	42.0				
PM _{2.5}	40	2024	July	17	61.7				
PM _{2.5}	40	2024	July	18	52.1				
PM _{2.5}	40	2024	July	19	67.2				
PM _{2.5}	40	2024	July	20	51.8				
PM _{2.5}	40	2024	July	22	61.9				
PM _{2.5}	40	2024	July	23	55.6				
PM _{2.5}	40	2024	July	24	45.0				
PM _{2.5}	40	2024	July	25	42.4				
PM _{2.5}	40	2024	July	26	51.2				
PM _{2.5}	40	2024	July	27	56.7				
PM _{2.5}	40	2024	July	30	41.6				
		PM ₁₀ Daily	Exceedand	ces (Chi	cken Farm)				
PM ₁₀ .	75	2024	July	01	123.7				
PM ₁₀ .	75	2024	July	02	110.8				
PM ₁₀ .	75	2024	July	03	85.4				
PM ₁₀ .	75	2024	July	04	176.8				
PM ₁₀ .	75	2024	July	05	175.7				
PM ₁₀ .	75	2024	July	06	184.3				
PM ₁₀ .	75	2024	July	07	123.4				
PM ₁₀ .	75	2024	July	08	228.6				
PM _{10.}	75	2024	July	09	84.7				
PM ₁₀ .	75	2024	July	10	97.6				
PM ₁₀ .	75	2024	July	12	83.4				

PM ₁₀ .	75	2024	July	13		1	38.3		
PM ₁₀ .	75	2024	July	14		1	78.4		
PM ₁₀ .	75	2024	July	15		1;	38.5		
PM ₁₀ .	75	2024	July	16	180.7				
PM ₁₀ .	75	2024	July	17		1	90.0		
PM ₁₀ .	75	2024	July	18		1	30.8		
PM ₁₀ .	75	2024	July	19		1	31.1		
PM ₁₀ .	75	2024	July	20		1	87.5		
PM ₁₀ .	75	2024	July	21		1	07.6		
PM ₁₀ .	75	2024	July	22		1.	27.9		
PM ₁₀ .	75	2024	July	23		1	84.1		
PM ₁₀ .	75	2024	July	24			04.3		
PM ₁₀ .	75	2024	July	25			13.2		
PM ₁₀ .	75	2024	July	26			29.7		
PM ₁₀ .	75	2024	July	27			00.6		
PM ₁₀ .	75	2024	July	28			47.5		
PM ₁₀ .	75 	2024	July	30			08.9		
PM ₁₀ .	75	2024	July	31	<u> </u>		45.1		
	PM _{2.5} Daily Exceedances (Chicken Farm)								
Pollutant	Limit	Year	Month	Day			. (μg/m³)		
PM _{2.5}	40	2024	July	01			52.5		
PM _{2.5}	40	2024	July	02	52.7				
PM _{2.5}	40	2024	July	07	47.9				
PM _{2.5}	40 40	2024 2024	July	08 13	46.6 74.7				
PM _{2.5}	40	2024	July July	14			37.9		
PM _{2.5}	40	2024	July	17			75.9		
PM _{2.5}	40	2024	July	18			58.8		
PM _{2.5}	40	2024	July	19			61.5		
PM _{2.5}	40	2024	July	31			51.8		
1 1712.5	10		rly Exceeda		almoral)		71.0		
Pollutant	Limit	Year	Month	Day	WSP	WDR	Time	Conc.	
SO ₂	134	2024	July	05	2.37	W	11h00	196.99	
302	134					VV	111100	130.33	
			urly Exceed	1			I	_	
Pollutant	Limit	Year	Month	Day	WSP	WDR	Time	Conc.	
SO ₂	134	2024	July	13	0.29	SSW	10h00	143.91	
SO ₂	134	2024	July	17	0.19	WSW	09h00	144.98	
<u></u>	S	O ₂ Hourly	Exceedance	es (Chi	cken Far	m)			
Pollutant	Limit	Year	Month	Day	WSP	WDR	Time	Conc.	
SO ₂	134	2024	July	21	1.32	N	13h00	149.1	
332	107						101100	1 10.1	
D.II.	1		urly Exceed	1		14/55	T =:		
Pollutant	Limit	Year	Month	Day	WSP	WDR	Time	Conc.	
SO ₂	134	2024	July	05	0.69	NNE	13h00	152.1	
SO ₂	134	2024	July	13	1.14	N	08h00	154.72	
SO ₂	134	2024	July	21	1.29	WSW	11h00	153.82	

Table 5: Exceedances of the NAAQ Limits per pollutant- July 2024

Averaging Period	Balmoral	Chicken Farm	Phola	Wilge
SO ₂ 10-min	2	2	3	0
SO ₂ Hourly	1	1	2	3
SO ₂ Daily	0	0	0	0
NO ₂ Hourly	NM	0	0	0
O ₃ 8-hourly	NM	0	11	NM
PM _{2.5} Daily	NM	10	20	NM
PM ₁₀ Daily	NM	29	18	NM

NM – not monitored.

A summary of all exceedances per pollutant for July 2024 is shown in Table 5.

SO₂ trigger levels or emergency response levels will be based on the United States Acute Exposure Guideline Levels for Hazardous Substances. (AEGL) as amended for South African circumstances. Levels confirmed with the authorities are as follows.

- a. AEGL 1 the cautionary notification level (non-disabling level) is based on the South African NAAQS limit for SO_2 this will be 191 ppb over 10-minute for exposure more than 4 hours.
- b. AEGL 2 the warning notification level (disabling level for those with asthma) is aligned to the US AEGL approach for SO₂ will be 744 ppb over a 10-minute for exposure up to 8 hours.
- c. AEGL the lethality level for SO₂, this will be 29 771 ppb over a 10-minute period.

There were no events that triggered the notification of stakeholders in terms of the agreed AEGL recorded in July 2024.

Table 6: Number of exceedances recorded from November 2023 to July 2024

SITES					
	CF	РО	BL	WL	Allowed No. of Exceedances (November 2023 to July 2024)
PM ₁₀ (Daily)	61	63	NM	NM	4
PM _{2.5} (Daily)	78	62	NM	NM	4
NO ₂ (hourly)	0	0	NM	0	88
SO ₂ (Hourly	0	2	1	7	88
SO ₂ (Daily)	0	0	0	0	4
O ₃ (8h moving)	355	82	NM	NM	11
SO ₂ (10 minute)	0	4	3	8	526

Kusile AQ Report: July 2024 Page No: 10

NM - not monitored.

Chicken Farm air quality monitoring station is in non-compliance with national ambient air quality limits of PM_{2.5} daily limit of 40 μ g/m³, PM₁₀ daily limit of 75 μ g/m³ and O₃ 8 hourly limit of 61 ppb. The sources that have an impact on Chicken farm are Eva high Steel and Vanadium in the northeast, Phola Township in the east-south-east, Klipspruit Colliery in the south-east and Kusile Power station in the north to north-west sectors.

The monitoring of particulate matter (PM_{2.5}) at Chicken Farm was started with the temporary stack project in November 2023. Phola air quality monitoring station site is in non-compliance with national ambient air quality limits of PM_{2.5} daily limit of 40 μ g/m³, PM₁₀ daily limit of 75 μ g/m³ and O₃ 8 hourly limit of 61 ppb.

Both Phola and Chicken Farm are characterised by elevated levels of air pollutants, particularly particulate matter (PM_{10} and $PM_{2.5}$ and Ozone (O_3) with exceedances observed at the monitoring stations. These general trends of increasing both PM_{10} and $PM_{2.5}$ might be due low levels activities (burning of coal) for both cooking and heating from low income areas during the winter months in Phola.

5. DFFE AND SAAQIS REPORTING

The raw monitoring data, downloaded at 1-minute averages is available in real-time to the DFFE-managed South African Air Quality Information System (SAAQIS) since the 14th of December 2023 for all Eskom air quality monitoring stations daily however due to system challenges the transfer stopped. In the event that the data is not available on the SAAQIS portal the stakeholders are advised to contact Eskom air quality monitoring team at RT&D.

6. CONCLUSIONS

There were no exceedances of the NO₂ hourly limit of 106 ppb recorded at the monitoring stations during the July 2024 monitoring period.

There were two (2) exceedances of SO_2 10-minutes limit of 191 ppb at both Balmoral and Chicken Farm and three (3) exceedances at Phola recorded during the monitoring period. There were exceedances of SO_2 hourly limit of 134 ppb at all the monitoring site under review.

There were twenty (20) exceedances of the $PM_{2.5}$ daily limit of 40 $\mu g/m^3$ at Phola, and ten (10) exceedances of the $PM_{2.5}$ daily limit of 40 $\mu g/m^3$ the Chicken Farm monitoring station. There were eighteen (18) exceedances of PM_{10} daily limit of 75 $\mu g/m^3$ at Phola air quality monitoring station and twenty-nine (29) exceedances of PM_{10} daily limit of 75 $\mu g/m^3$ recorded at Chicken Farm air quality monitoring station.

Both Chicken Farm air quality monitoring station and Phola sites are in non-compliance with national ambient air quality limits of PM_{2.5} daily limit of 40 μ g/m³, PM₁₀ daily limit of 75 μ g/m³ and O₃ 8 hourly limit of 61 ppb.

There were no events that triggered the notification of stakeholders in terms of the agreed AEGL recorded in July 2024.

Kusile AQ Report: July 2024 Page No: 11