



	Technical and Generic Report	Matimba Power Station
-----------------------------------------------------------------------------------	------------------------------	-----------------------

Title:	Matimba Power Station September 2024 emissions report	Document Identifier:	RP/247/052
		Plant Location:	Emission management
		Area of Applicability:	Matimba Power Station
		Functional Area Applicability:	Environment
		Revision:	1
		Total Pages:	30
		Report Date:	September 2024
		Disclosure Classification:	Controlled

Compiled by	Reviewed by	Functional Responsibility	Authorized by
			
Kamogelo Kwata Environmental Officer (GIT)	Helry Ramahlare Senior Advisor Environment	MC Mamabolo Environmental Manager	Obakeng Mabotja General Manager
Date: 2024-10-30	Date: 2024-10-30	Date: 31.10.2024	Date: 2024-11-01

## Content

	Page
1. Report Summary .....	5
2. Emission information .....	6
2.1 Raw materials and products.....	6
2.2 Abatement technology.....	6
2.3 Emissions reporting.....	7
Particulate Matter Emissions.....	7
Gaseous Emissions.....	10
Total Volatile Organic Compounds .....	17
Greenhouse gas (CO <sub>2</sub> ) emissions.....	18
2.4 Daily power generated. ....	18
2.5 Pollutant Tonnages .....	22
2.6 Operating days in compliance to PM AEL Limit .....	22
2.7 Operating days in compliance to SO <sub>x</sub> AEL Limit .....	22
2.8 Operating days in compliance to NO <sub>x</sub> AEL Limit .....	23
2.9 Reference values .....	23
2.10 Continuous Emission Monitors.....	23
2.10.1 Reliability.....	23
2.10.2 Changes, downtime, and repairs .....	24
2.10.3 Sampling dates and times.....	25
2.11 Units Start-up information .....	26
2.12 Emergency generation .....	28
2.13 Complaints register. ....	28
2.14 Air quality improvements and social responsibility conducted. ....	28
Air quality improvements.....	28
Social responsibility conducted. ....	28
2.15 Ambient air quality monitoring.....	29
2.16 Electrostatic precipitator and Sulphur plant status.....	29
2.17 General.....	30
3. Attachments.....	30
4. Report Conclusion .....	30
Table 1: Quantity of Raw Materials and Products used/produced for the month. ....	6
Table 2: Abatement Equipment Control Technology Utilised.....	6
Table 3: Energy Source Material Characteristics. ....	7
Table 4: Total volatile compound estimates .....	17
Table 5: Daily power generated per unit in MWh for the month of September 2024 .....	18
Table 6: Pollutant tonnages for the month of September 2024.....	22

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 7: Operating days in compliance with PM AEL limit of September 2024 .....	22
Table 8: Operating days in compliance with SOx AEL limit of September 2024.....	22
Table 9: Operating days in compliance with NOx AEL limit of September 2024 .....	23
Table 10: Reference values for data provided, September 2024.....	23
Table 11: Monitor reliability percentage (%).....	23
Table 12: Average percentage (%) availability of monitors for the month of September 2024.....	24
Table 13: Dates of last full conducted CEMS verification tests for PM for unit 4 and 6 only .....	25
Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO <sub>2</sub> and NOx (without unit 4 and 6 PMs) .....	25
Table 15: Start-up information .....	26
Table 16: Emergency generation .....	28
Table 17: Complaints.....	28

## Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of September 2024 .....	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of September 2024 .....	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of September 2024 .....	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of September 2024 .....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of September 2024 .....	9
Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of September 2024 .....	10
Figure 7: SO <sub>2</sub> daily average emissions against emission limit for unit 1 for the month of September 2024 ...	10
Figure 8: SO <sub>2</sub> daily average emissions against emission limit for unit 2 for the month of September 2024 ...	11
Figure 9: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of September 2024 ...	11
Figure 10: SO <sub>2</sub> daily average emissions against emission limit for unit 3 for the month of September 2024.....	12
Figure 11: SO <sub>2</sub> daily average emissions against emission limit for unit 5 for the month of September 2024.....	12
Figure 12: SO <sub>2</sub> daily average emissions against emission limit for unit 6 for the month of September 2024.....	13
Figure 13: NOx daily average emissions against emission limit for unit 1 for the month of September 2024.....	13
Figure 14: NOx daily average emissions against emission limit for unit 2 for the month of September 2024.....	14

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Figure 15: NOx daily average emissions against emission limit for unit 3 for the month of September 2024.....	14
Figure 16: NOx daily average emissions against emission limit for unit 4 for the month of September 2024.....	15
Figure 17: NOx daily average emissions against emission limit for unit 5 for the month of September 2024.....	15
Figure 18: NOx daily average emissions against emission limit for unit 6 for the month of September 2024.....	16
Figure 19: Unit 1 daily generated power in MWh for the month of September 2024 .....	19
Figure 20: Unit 2 daily generated power in MWh for the month of September 2024 .....	19
Figure 21: Unit 3 daily generated power in MWh for the month of September 2024 .....	20
Figure 22: Unit 4 daily generated power in MWh for the month of September 2024 .....	20
Figure 23: Unit 5 daily generated power in MWh for the month of September 2024 .....	21
Figure 24: Unit 6 daily generated power in MWh for the month of September 2024 .....	21

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for September 2024. The information recorded in the report is obtained from Matimba Emission Reporting tool V02.2024VF.



During the period under review, Matimba experienced ninety-one (91) exceedances of the daily particulate matter emission limit (50mg/Nm<sup>3</sup>), fifty-six (56) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence and thirty-five (35) exceedances occurred within the 48-hour grace period.

There were no exceedances of the monthly SO<sub>x</sub> limit (3500mg/Nm<sup>3</sup>). There were four (4) exceedances of the daily NO<sub>x</sub> emission limit (750mg/Nm<sup>3</sup>).

Flue gas conditioning plant availability was above 80% for units except unit 2 and unit 3. Unit 2 SO<sub>3</sub> plant was constantly on hold for the month of September 2024 due to electrostatic precipitators temperature being too low. Unit 3 SO<sub>3</sub> plant availability was low due to low load. Defects were addressed and plants returned to service.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

More information regarding above mentioned issues is provided in the relevant sections within the report.

## 2. Emission information

### 2.1 Raw materials and products

**Table 1:** Quantity of Raw Materials and Products used/produced for the month.

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	817 492
	Fuel Oil	Tons/month	1 200	1991.738
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	1078.661

The consumption rates for fuel oil for the month of September 2024 exceeded the permitted maximum limits due to multiple combustion support and units light ups trips.

### 2.2 Abatement technology

**Table 2:** Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99.998%
Unit 2	Electrostatic Precipitator	100%	99.999%
Unit 3	Electrostatic Precipitator	100%	99.998%
Unit 4	Electrostatic Precipitator	100%	99.998%
Unit 5	Electrostatic Precipitator	100%	99.999%
Unit 6	Electrostatic Precipitator	100%	99.989%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO <sub>3</sub> Plant	100%	92%
Unit 2	SO <sub>3</sub> Plant	100%	84%
Unit 3	SO <sub>3</sub> Plant	100%	70%
Unit 4	SO <sub>3</sub> Plant	100%	91%
Unit 5	SO <sub>3</sub> Plant	100%	97%
Unit 6	SO <sub>3</sub> Plant	100%	0%

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was below 90% for unit 2 and unit 3. Unit 2 SO<sub>3</sub> plant was constantly on hold for the month of September 2024 due to electrostatic precipitators temperature being too low. Unit 3 SO<sub>3</sub> plant availability was low due to low load. Unit 6 is on outage. Defects were addressed and plants returned to service.

**Table 3: Energy Source Material Characteristics.**

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.313%
	Ash Content	40%	35.665%


Energy source characteristics remained within the ranges stipulated in the license.

## 2.3 Emissions reporting

### Particulate Matter Emissions

The emission monitors Correlation spot test were performed in August 2023 and the results were applied and used for gaseous emissions calculation for September 2024. The spot test results for PM emissions does not meet the minimum requirements outlined in the Eskom emission calculation Methodology and were not applied.

#### Unit 1 Particulate Emissions



**Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of September 2024**


**Interpretation:** Unit 1 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 8,9,14 to 16, 23,27 and 28 September 2024. The exceedance on 16 September 2024 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedance was due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


## Unit 2 Particulate Emissions



**Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of September 2024**

**Interpretation:** Unit 2 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1 to 4, 6, 12 to 17 and 20 to 30 September 2024. The exceedances from 1 to 4, 14 to 17 and 22 to 30 September 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

## Unit 3 Particulate Emissions



**Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of September 2024**

**Interpretation:** Unit 3 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 1 to 4, 6 to 20 and 30 September 2024. The exceedances from 3, 4 and 8 to 20 September 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to dust handling plants defects leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).


## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




## Unit 4 Particulate Emissions



**Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of September 2024**

**Interpretation:** Unit 4 exceeded the daily particulate emission limit of 50mg/Nm<sup>3</sup> on 7,8,10 to 14, 16 to 18, 22 and 24 to 30 September 2024. The exceedances from 12 to 14, 16 to 18 and 26 to 30 September 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to dust handling plants defects leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

## Unit 5 Particulate Emissions



**Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of September 2024**


**Interpretation:** Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on 1,3,5 to 7,9 to 14,16,17,19 to 21,23 to 27 and 29 September 2024. Exceedances from 1,7,11 to 14,21 and 23 to 27 September 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to defects on the dust handling plants leading to high hopper levels within the flue gas cleaning system and reducing the efficiency of the abatement technology (electrostatic precipitator fields).

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Unit 6 Particulate Emissions




**Figure 6: Particulate matter daily average emissions against emission limit for unit 6 for the month of September 2024**

**Interpretation:** Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm<sup>3</sup> on the 6 September 2024. The exceedance occurred within the 48-hour grace period.

## Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in September 2024 as per the Eskom emission standard requirement.

The quality assurance spot tests were performed on the monitors in August 2023 and the test results are used for the September 2024 emission calculation.

Unit 1 SO<sub>2</sub> Emissions

**Figure 7: SO<sub>2</sub> daily average emissions against emission limit for unit 1 for the month of September 2024**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 SO<sub>2</sub> Emissions

Figure 8: SO<sub>2</sub> daily average emissions against emission limit for unit 2 for the month of September 2024

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.


Unit 3 SO<sub>2</sub> Emissions


Figure 9: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of September 2024

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

## CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO<sub>2</sub> Emissions

**Figure 10: SO<sub>2</sub> daily average emissions against emission limit for unit 3 for the month of September 2024**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

Unit 5 SO<sub>2</sub> Emissions


**Figure 11: SO<sub>2</sub> daily average emissions against emission limit for unit 5 for the month of September 2024**

**Interpretation:** All daily averages below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

## CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 SO<sub>2</sub> Emissions

**Figure 12: SO<sub>2</sub> daily average emissions against emission limit for unit 6 for the month of September 2024**

**Interpretation:** All daily averages remained below SO<sub>2</sub> emission monthly limit of 3500 mg/Nm<sup>3</sup>.

Unit 1 NO<sub>x</sub> Emissions

**Figure 13: NO<sub>x</sub> daily average emissions against emission limit for unit 1 for the month of September 2024**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO<sub>x</sub> Emissions

Figure 14: NO<sub>x</sub> daily average emissions against emission limit for unit 2 for the month of September 2024

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


Unit 3 NO<sub>x</sub> Emissions

Figure 15: NO<sub>x</sub> daily average emissions against emission limit for unit 3 for the month of September 2024

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 NO<sub>x</sub> Emissions

Figure 16: NO<sub>x</sub> daily average emissions against emission limit for unit 4 for the month of September 2024

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.


Unit 5 NO<sub>x</sub> Emissions


Figure 17: NO<sub>x</sub> daily average emissions against emission limit for unit 5 for the month of September 2024

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 NO<sub>x</sub> Emissions

**Figure 18: NO<sub>x</sub> daily average emissions against emission limit for unit 6 for the month of September 2024**

**Interpretation:** All daily averages below NO<sub>x</sub> emission limit of 750 mg/Nm<sup>3</sup>.

**CONTROLLED DISCLOSURE**


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



## Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Monday, 14 October 2024	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center"><b>MONTHLY INPUT DATA FOR THE STATION</b></p> <p align="center">Please only insert relevant monthly data inputs into the <u>blue cells</u> below</p> <p align="center">Choose from a dropdown menu in the <u>green cells</u></p> <p align="center">The total VOC emissions for the month are in the <u>red cells</u></p> <p align="center">IMPORTANT: Do not change <u>any</u> other cells without consulting the AQ CoE</p>		
MONTH:	September	
<b>GENERAL INFORMATION:</b>		<b>Data Unit</b>
Total number of fuel oil tanks:	4	NA
Height of tank:	13.34	m
Diameter of tank:	9.53	m
Net fuel oil throughput for the month:	1991.738	
Molecular weight of the fuel oil:	166.00	Lb/lb-mole
<b>METEROLOGICAL DATA FOR THE MONTH</b>		<b>Data Unit</b>
Daily average ambient temperature	23.43	°C
Daily maximum ambient temperature	31.06	°C
Daily minimum ambient temperature	16.52	°C
Daily ambient temperature range	14.54	°C
Daily total insolation factor	4.41	kWh/m <sup>2</sup> /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0.68	NA
<b>FINAL OUTPUT:</b>		<b>Result Unit</b>
Breathing losses:	0.54 kg/month	
Working losses:	0.06 kg/month	
<b>TOTAL LOSSES (Total TVOC Emissions for the month):</b>	<b>0.60 kg/month</b>	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Tritech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## Greenhouse gas (CO<sub>2</sub>) emissions

CO<sub>2</sub> emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

## 2.4 Daily power generated.

**Table 5:** Daily power generated per unit in MWh for the month of September 2024

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2024/09/01	Unit off	10621	10118.8	Unit off	10957	8114.33
2024/09/02	Unit off	10311.1	10197.2	Unit off	11800.4	8093.67
2024/09/03	Unit off	10276.2	9914.32	Unit off	10890.1	8103.64
2024/09/04	Unit off	10281.5	8835.24	Unit off	11275	8112.38
2024/09/05	Unit off	10799	8943.84	Unit off	12767.8	8248.11
2024/09/06	Unit off	12402.4	10122.5	4229.39	13921.6	1389.83
2024/09/07	798.314	11831.7	10328.6	11627.7	13159.6	Unit off
2024/09/08	9809.33	10153.6	10327.9	5999.99	10983.3	Unit off
2024/09/09	8868.34	11791.9	9562.8	4185.56	11808.1	Unit off
2024/09/10	10279	13328.9	10366.7	11316.9	12982.7	Unit off
2024/09/11	10592.3	13421	10353.5	12201.5	11959.8	Unit off
2024/09/12	10516.7	12484.1	10304.1	10429.6	13194.1	Unit off
2024/09/13	10005.4	11373.9	10171	10146.3	11706.9	Unit off
2024/09/14	10697.4	10796.3	10135.5	8235.84	11796.6	Unit off
2024/09/15	10825.7	11017.3	10037.4	5554.09	10447.7	Unit off
2024/09/16	10366.6	10826.2	10109.3	11344.8	12314.2	Unit off
2024/09/17	11428	12351.2	10105.8	11086.1	12077.3	Unit off
2024/09/18	11707.7	11265.7	10086.6	10152.8	11494.5	Unit off
2024/09/19	10691	11499	10109.7	10582.3	10866	Unit off
2024/09/20	13091	13633.5	10116.3	12534.3	11895.7	Unit off
2024/09/21	13225.7	13147.9	7949.11	12726.4	10302.7	Unit off
2024/09/22	13586	11834	7946.78	12653.3	8684.91	Unit off
2024/09/23	14030.2	10861.9	5565.13	12634.4	10190	Unit off
2024/09/24	13556.7	11404.9	6425.95	12456.7	10182.1	Unit off
2024/09/25	11847.2	11769	6405.81	11575.2	10425.9	Unit off
2024/09/26	10241.3	10743.6	6376.34	10856.6	9950.52	Unit off
2024/09/27	10526.2	11045.2	6386.13	10600.7	9768.31	Unit off
2024/09/28	10833.7	11446.3	6431.23	10207.2	10631.9	Unit off
2024/09/29	9296.1	10094.9	6404.06	9443.44	10468.3	Unit off
2024/09/30	9906.4	11098	3202.93	9955.03	11177.2	Unit off

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 19: Unit 1 daily generated power in MWh for the month of September 2024





Figure 20: Unit 2 daily generated power in MWh for the month of September 2024


#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 21: Unit 3 daily generated power in MWh for the month of September 2024**




**Figure 22: Unit 4 daily generated power in MWh for the month of September 2024**


#### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**Figure 23: Unit 5 daily generated power in MWh for the month of September 2024**



**Figure 24: Unit 6 daily generated power in MWh for the month of September 2024**

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.5 Pollutant Tonnages

The emitted pollutant tonnages for September 2024 are provided in table 6.

**Table 6:** Pollutant tonnages for the month of September 2024

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)
Unit 1	81.8	4 202.6	758.0
Unit 2	135.4	4 718.7	700.3
Unit 3	144.2	3 991.6	754.2
Unit 4	135.5	2 775.9	539.3
Unit 5	197.7	4 306.1	814.6
Unit 6	8.1	331.9	83.7
<b>SUM</b>	<b>702.6</b>	<b>20 326.7</b>	<b>3 650.2</b>

## 2.6 Operating days in compliance to PM AEL Limit

**Table 7:** Operating days in compliance with PM AEL limit of September 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm <sup>3</sup> )
Unit 1	15	7	0	1	8	63.1
Unit 2	8	5	0	17	22	67.4
Unit 3	10	5	0	15	20	75.4
Unit 4	4	7	0	11	18	121.6
Unit 5	8	10	0	12	22	106.0
Unit 6	5	1	0	0	1	38.7
<b>SUM</b>	<b>50</b>	<b>35</b>	<b>0</b>	<b>56</b>	<b>91</b>	

## 2.7 Operating days in compliance to SO<sub>x</sub> AEL Limit

**Table 8:** Operating days in compliance with SO<sub>x</sub> AEL limit of September 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO <sub>2</sub> (mg/Nm <sup>3</sup> )
Unit 1	24	0	0	0	0	2 683.6
Unit 2	30	0	0	0	0	2 371.9
Unit 3	30	0	0	0	0	2 120.9
Unit 4	25	0	0	0	0	2 130.1
Unit 5	30	0	0	0	0	2 170.9
Unit 6	6	0	0	0	0	1 385.4
<b>SUM</b>	<b>145</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.8 Operating days in compliance to NOx AEL Limit

**Table 9: Operating days in compliance with NOx AEL limit of September 2024**

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	24	0	0	0	0	382.3
Unit 2	30	0	0	0	0	351.5
Unit 3	30	0	0	0	0	404.8
Unit 4	25	0	0	0	0	409.6
Unit 5	30	0	0	0	0	399.0
Unit 6	6	0	0	0	0	354.4
<b>SUM</b>	<b>145</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

## 2.9 Reference values

**Table 10: Reference values for data provided, September 2024**

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	8.17	7.41	8.35	9.26	9.21	10.78
Moisture	%	3.54	3.54	3.07	3.26	3.75	2.43
Velocity	m/s	25.6	24.3	24.9	23.8	29.0	24.8
Temperature	°C	132.9	127.5	128.0	121.9	119.3	153.9
Pressure	mBar	937.7	924.0	944.1	921.7	916.0	912.6

## 2.10 Continuous Emission Monitors

### 2.10.1 Reliability

**Table 11: Monitor reliability percentage (%)**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO
Unit 1	98.1	100.0	100.0
Unit 2	100.0	100.0	99.6
Unit 3	100.0	100.0	100.0
Unit 4	95.3	71.2	69.7
Unit 5	98.8	99.4	100.0
Unit 6	100.0	91.7	89.6

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Continuous emission monitors were available for more than 80% of the reporting period except for Unit 4. Unit 6 went on outage during the first week of the month of the reporting period.

**Table 12:** Average percentage (%) availability of monitors for the month of September 2024.

Unit	SO <sub>2</sub>	NO <sub>x</sub>	PM	CO <sub>2</sub>
1	100.0	100.0	98.1	100.0
2	100.0	99.6	100.0	99.9
3	100.0	100.0	100.0	51.0
4	71.2	69.7	95.3	97.7
5	99.4	100.0	98.8	98.5
6	91.7	89.6	100.0	76.4

### 2.10.2 Changes, downtime, and repairs

#### Unit 1

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

#### Unit 2

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

#### Unit 3

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

#### Unit 4

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

#### Unit 5

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

#### Unit 6

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.



**2.10.3 Sampling dates and times****Table 13:** Dates of last full conducted CEMS verification tests for PM for unit 4 and 6 only

<b>Name of service provider:</b>		Stacklabs Environmental Services CC		
<b>Address of service provider:</b>		10 Chisel Street Boltonia Krugersdorp 1739		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
1	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
2	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
3	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
4	2021/07/13 14h31	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
5	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
6	2020/09/09 06h41	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13

Note: The CEMS verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> were performed in October 2022 and failed. The spot tests were done in August 2023.

**Table 14:** Dates of last conducted CEMS Spot verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> (without unit 4 and 6 PMs)

<b>Name of service provider:</b>		Levego Environmental services		
<b>Address of service provider:</b>		Building R6 Pineland site Ardeer Road Modderfontein 1645		
<b>Stack/ Unit</b>	<b>PM</b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO<sub>2</sub></b>
1	2023/08/01 19h33	2023/08/01 19:33	2023/08/01 19:33	2023/08/01 19:33
2	2023/07/29 21:17	2023/07/29 21:17	2023/07/29 21:17	2023/07/29 21:17
3	2023/08/06 03:00	2023/08/06 03:00	2023/08/06 03:00	2023/08/06 03:00
4	Dates in table 12 above	2023/08/04 19:39	2023/08/04 19:39	2023/08/04 19:39
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30
6	Dates in table 12 above	2023/08/05 15:52	2023/08/05 15:52	2023/08/05 15:52

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Note: The CEMS Spot verification tests for PM, SO<sub>2</sub> and NO<sub>x</sub> were performed in August 2023. PM spot verification test results for units 4 and 6 failed and old curves are still in use.

## 2.11 Units Start-up information

**Table 15:** Start-up information

<b>Unit</b>	1	
<b>Fires in</b>	2024/09/07	13h10
<b>Synchronization with Grid</b>	2024/09/07	19h03
<b>Emissions below limit</b>	2024/09/07	21h46
<b>Fires in, to synchronization</b>	5.53	HOURS
<b>Synchronization to &lt; Emission limit</b>	2.43	HOURS

<b>Unit</b>	3	
<b>Fires in</b>	2024/09/23	19h45
<b>Synchronization with Grid</b>	2024/09/23	23h09
<b>Emissions below limit</b>	2024/09/24	02h00
<b>Fires in, to synchronization</b>	3.24	HOURS
<b>Synchronization to &lt; Emission limit</b>	45.9	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	2024/09/06	04h16
<b>Synchronization with Grid</b>	2024/09/06	11h58
<b>Emissions below limit</b>	2024/09/08	14h00
<b>Fires in, to synchronization</b>	7.42	HOURS
<b>Synchronization to &lt; Emission limit</b>	50.2	HOURS

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

<b>Unit</b>	4	
<b>Fires in</b>	2024/09/09	07h06
<b>Synchronization with Grid</b>	2024/09/09	12h27
<b>Emissions below limit</b>	2024/09/09	15h02
<b>Fires in, to synchronization</b>	5.21	HOURS
<b>Synchronization to &lt; Emission limit</b>	2.35	HOURS

<b>Unit</b>	4	
<b>Fires in</b>	2024/09/15	07h19
<b>Synchronization with Grid</b>	2024/09/15	09h32
<b>Emissions below limit</b>	2024/09/15	10h23
<b>Fires in, to synchronization</b>	2.13	HOURS
<b>Synchronization to &lt; Emission limit</b>	0.51	HOURS

<b>Unit</b>	5	
<b>Fires in</b>	2024/09/22	00h55
<b>Synchronization with Grid</b>	2024/09/22	03h11
<b>Emissions below limit</b>	2024/09/22	05h00
<b>Fires in, to synchronization</b>	2.16	HOURS
<b>Synchronization to &lt; Emission limit</b>	1.49	HOURS

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.12 Emergency generation

**Table 16:** Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
<b>Emergency Generation hours declared by national Control</b>	744	744	744	744	744	744
<b>Emergency Hours declared including hours after standing down</b>	560.58	720.00	705.55	560.87	720.00	125.27
<b>Days over the Limit during Emergency Generation</b>	8	22	20	18	22	1

During the period under review all Units were on emergency generation in force from 01 September 2024 until 30 September 2024.

## 2.13 Complaints register.

**Table 17:** Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

## 2.14 Air quality improvements and social responsibility conducted.

### Air quality improvements

None

### Social responsibility conducted.

None

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.15 Ambient air quality monitoring

Marapong ambient air quality monitoring station was relocated from the previous location to Ditheku primary school and commissioned to service on 20 March 2024. The September 2024 ambient air quality monitoring report is sent with the report as addendum.

## 2.16 Electrostatic precipitator and Sulphur plant status

### Unit 1

- 9 fields defective.
- No abnormalities on the SO3 plant.

### Unit 2

- 2 fields defective.
- No abnormalities on the SO3 plant.

### Unit 3

- 2 fields defective.
- No abnormalities on the SO3 plant.

### Unit 4

- 3 fields defective.
- No abnormalities on the SO3 plant.

### Unit 5

- 2 fields defective.
- No abnormalities on the SO3 plant.

### Unit 6

- On outage

### SO3 common plant

- No abnormalities on the sulphur storage plant.

## CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

## 2.17 General

### Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
  - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
  - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

### Sampling locations:

1. Stack one
  - a. Particulates:
    - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues
2. Stack two
  - a. Particulates:
    - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
  - b. Gas:
    - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
  - c. Stack height
    - i. 250 meter consist of 3 flues

## 3. Attachments

None

## 4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely

GENERAL MANAGER: MATIMBA POWER STATION

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.