

Lukhanyo Mgadle Chief Air Quality Officer Buffalo City Metropolitan Municipality 2 Beaconsfield Road North End East London 5201 Date:

3 January 2025

Enquiries: Hilton Westman

(021) 9415856

Ref: PRX/2024/12

Dear Mr Mgadle

ESKOM PORT REX POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF DECEMBER 2024

Atmospheric Emissions License: ECBC_000603

This serves as the monthly report and the information is applicable for the month of December 2024.

1. Raw Materials and Products (Section 6.1)

Quantity of Raw Materials and Products used/produced for the month.

Element	Performance	Reporting Unit
Fuel type: Diesel		
Total Fuel Consumption	4.434	Tons
Electricity Produced	7	MWh
Average Fuel Consumption	0.633	Tons / MWh
Maximum fuel consumption rate	4667	Kg / per hour

2. Operating times of units (Section 5.4)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production		
	Hours and minutes	Litres	MWh		
Unit One	Ohrs 16min		0		
Unit Two	0hrs 27min	5365	4		
Unit Three	Ohrs 14min		3		

b. Detailed operating times

See Annexure 1

3. Complaints Register (Section 7.6)

No complaints were registered for the month of December 2024.

4. General

Port Rex was not requested to generate for the grid to supplement power availability and minimise national load shedding.

Fuel was used when performed after 4 monthly routine service, and test run up to SCO after trip.

We trust that the above information complies with your requirements.

Yours sincerely

Pamela Mrubata Plant Manager

PORT REX POWER STATION

Annexure1. Hours of Operation

	Unit One			Unit two		Unit 3			
Date	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1									
2									
3									
4				16:24:00	16:41:00	0:17:00			
5									
6							13:09:00	13:23:00	0:14:00
7									
8									
9									
10									
11									
12									
13									
14				08:36:00	08:46:00	0:10:00			
15									
16									
17									
18	22:21:00	22:37:00	0:16:00						
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									

Load Factor

0.127 %