	Technical and Generic Report	Matimba Power Station
---	-------------------------------------	------------------------------

Title: **Matimba Power Station November 2024 emissions report** Document Identifier: **RP/247/054**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**





Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **30**

Report Date: **November 2024**

Disclosure Classification: **Controlled**

Compiled by	Reviewed by	Functional Responsibility	Authorized by
	pp 	p.p.  pp	
Kamogelo Kwata Environmental Officer (GIT)	Helry Ramahlare Senior Advisor Environment	MC Mamabolo Environmental Manager	Obakeng Mabotja General Manager
Date: <u>2024-12-27</u>	Date: <u>2024-12-31</u>	Date: <u>2024-12-31</u>	Date: <u>2025-01-03</u>

Content

	Page
1. Report Summary	5
2. Emission information	6
2.1 Raw materials and products	6
2.2 Abatement technology.....	6
2.3 Emissions reporting.....	7
2.3.1 Particulate Matter Emissions	7
2.3.2 Gaseous Emissions	10
2.3.2.a SOx Emissions	10
2.3.2.b NOx Emissions	13
2.3.3 Total Volatile Organic Compounds	16
2.3.4 Greenhouse gas (CO ₂) emissions	17
2.4 Daily power generated.....	17
2.5 Pollutant Tonnages	20
2.6 Operating days in compliance to PM AEL Limit	21
2.7 Operating days in compliance to SOx AEL Limit.....	21
2.8 Operating days in compliance to NOx AEL Limit	21
2.9 Reference values	22
2.10 Continuous Emission Monitors	22
2.10.1 Reliability	22
2.10.2 Changes, downtime, and repairs	23
2.10.3 Sampling dates and times	24
2.11 Units Start-up information	25
2.12 Emergency generation	27
2.13 Complaints register.	28
2.14 Air quality improvements and social responsibility conducted.....	28
Air quality improvements	28
Social responsibility conducted.....	28
2.15 Ambient air quality monitoring	29
2.16 Electrostatic precipitator and Sulphur plant status	29
2.17 General	30
3. Attachments	30
4. Report Conclusion	30
Table 1: Quantity of Raw Materials and Products used/produced for the month.	6
Table 2: Abatement Equipment Control Technology Utilised.....	6

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 3: Energy Source Material Characteristics.....	7
Table 4: Total volatile compound estimates	16
Table 5: Daily power generated per unit in MWh for the month of November 2024	17
Table 6: Pollutant tonnages for the month of November 2024.....	20
Table 7: Operating days in compliance with PM AEL limit of November 2024	21
Table 8: Operating days in compliance with SO _x AEL limit of November 2024	21
Table 9: Operating days in compliance with NO _x AEL limit of November 2024	21
Table 10: Reference values for data provided, November 2024.....	22
Table 11: Monitor reliability percentage (%)	22
Table 12: Average percentage (%) availability of monitors for the month of November 2024.	22
Table 13: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 4 and 6 only	24
Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO ₂ and NO _x (without unit 4 and 6 PMs)	24
Table 15: Start-up information.....	25
Table 16: Emergency generation	27
Table 17: Complaints	28

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of November 2024	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of November 2024	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of November 2024	8
Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of November 2024	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of November 2024	9
Figure 6: SO ₂ daily average emissions against emission limit for unit 1 for the month of November 2024.....	10
Figure 7: SO ₂ daily average emissions against emission limit for unit 2 for the month of November 2024.....	11
Figure 8: SO ₂ daily average emissions against emission limit for unit 3 for the month of November 2024.....	11

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Figure 9: SO ₂ daily average emissions against emission limit for unit 4 for the month of November 2024.....	12
Figure 10: SO ₂ daily average emissions against emission limit for unit 5 for the month of November 2024.....	12
Figure 11: NO _x daily average emissions against emission limit for unit 1 for the month of November 2024.....	13
Figure 12: NO _x daily average emissions against emission limit for unit 2 for the month of November 2024.....	14
Figure 13: NO _x daily average emissions against emission limit for unit 3 for the month of November 2024.....	14
Figure 14: NO _x daily average emissions against emission limit for unit 4 for the month of November 2024.....	15
Figure 15: NO _x daily average emissions against emission limit for unit 5 for the month of November 2024.....	15
Figure 16: Unit 1 daily generated power in MWh for the month of November 2024	18
Figure 17: Unit 2 daily generated power in MWh for the month of November 2024	18
Figure 18: Unit 3 daily generated power in MWh for the month of November 2024	19
Figure 19: Unit 4 daily generated power in MWh for the month of November 2024	19
Figure 20: Unit 5 daily generated power in MWh for the month of November 2024	20

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for November 2024. The information recorded in the report is obtained from Matimba Emission Reporting tool V10.2024.



During the period under review, Matimba experienced seventy-eight (78) exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$), sixty-one (61) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence and seventeen (17) exceedances occurred within the 48-hour grace period.

There were no exceedances of the monthly SO_x limit ($3500\text{mg}/\text{Nm}^3$). There were no exceedances of the daily NO_x emission limit ($750\text{mg}/\text{Nm}^3$).

Flue gas conditioning plant availability was above 80% for all units except unit 2 which operated at availability of 39%. Unit 2 SO_3 plant was off due to the faulty sulphur process flow transmitter.

The consumption rates for fuel oil for the month of November 2024 exceeded the limit of 1200 tons by 2776.456 tons due to multiple units light up trips and unit 6 cold start up from outage.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month.

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	813 234
	Fuel Oil	Tons/month	1 200	2776.456
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	1904.135

The consumption rates for fuel oil for the month of November 2024 exceeded the permitted maximum limits due to multiple units light up trips and unit 6 cold start up from outage.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99.998%
Unit 2	Electrostatic Precipitator	100%	99.997%
Unit 3	Electrostatic Precipitator	100%	99.998%
Unit 4	Electrostatic Precipitator	100%	99.998%
Unit 5	Electrostatic Precipitator	100%	99.997%
Unit 6	Electrostatic Precipitator	100%	Off
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	98%
Unit 2	SO ₃ Plant	100%	39%
Unit 3	SO ₃ Plant	100%	84%
Unit 4	SO ₃ Plant	100%	100%
Unit 5	SO ₃ Plant	100%	87%
Unit 6	SO ₃ Plant	100%	Off

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was below 90% for unit 2, unit 3 and unit 5. Unit 2 SO₃ plant was off from the due to the faulty sulphur process flow transmitter. Unit 3 SO₃ plant was on hold for the month of November 2024 due to low load, Unit 5 SO₃ was on hold due to process blower air flow transmitter faulty. Unit 1 SO₃ plant availability was at 93%. Unit 4 SO₃ plant availability was 100% for the month of November 2024.

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.302%
	Ash Content	40%	34.471%

Energy source characteristics remained within the ranges stipulated in the license.

2.3 Emissions reporting

2.3.1 Particulate Matter Emissions

The emission monitors Correlation spot test were performed in August 2023 and the results were applied and used for gaseous emissions calculation for November 2024. The spot test results for PM emissions does not meet the minimum requirements outlined in the Eskom emission calculation Methodology and were not applied.

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of November 2024

Interpretation: Unit 1 exceeded the daily particulate emission limit of 50mg/Nm³ on 7,8,10 to 17 and 21 November 2024. The exceedances on 10th to 17th November 2024 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency. Unit 1 was on light up on the 9th November 2024.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of November 2024

Interpretation: Unit 2 did not exceed particulate emission limit of 50 mg/Nm³.

Unit 3 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 3 for the month of November 2024

Interpretation: Unit 3 exceeded the daily particulate emission limit of 50mg/Nm³ on 1 to 22 and 24 to 30 November 2024. The exceedances from 1 to 22 and 26 to 30 November 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 4 for the month of November 2024

Interpretation: Unit 4 exceeded the daily particulate emission limit of 50mg/Nm³ on 3 to 5, 8 and 10 to 30 November 2024. The exceedances on 5th and 12th to 30th November 2024 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

Unit 5 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 5 for the month of November 2024

Interpretation: Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 2, 5, 6, 22, 23 and 25 to 30 November 2024. The exceedances on 25 to 30 November 2024 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency. Unit 5 was on light up on the 4th, 10th, 21st and 24th November 2024.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions

Unit 6 is on outage.

2.3.2 Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in November 2024 as per the Eskom emission standard requirement.

The quality assurance spot tests were performed on the monitors in August 2023 and the test results are used for the November 2024 emission calculation.

2.3.2.a SO_x Emissions

Unit 1 SO₂ Emissions




Figure 6: SO₂ daily average emissions against emission limit for unit 1 for the month of November 2024

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 SO₂ Emissions

Figure 7: SO₂ daily average emissions against emission limit for unit 2 for the month of November 2024

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


Unit 3 SO₂ Emissions

Figure 8: SO₂ daily average emissions against emission limit for unit 3 for the month of November 2024

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³. Unit 3 gaseous monitor stopped working from the 17th of November 2024 and ACU (Analyser Control Unit) was taken offsite to consult with the OEM (Original Equipment Manufacturer). The monitor used the monthly average for the period (17th to 30th November 2024) when the monitor was off.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 SO₂ Emissions

Figure 9: SO₂ daily average emissions against emission limit for unit 4 for the month of November 2024

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


Unit 5 SO₂ Emissions

Figure 10: SO₂ daily average emissions against emission limit for unit 5 for the month of November 2024

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

Unit 6 SO₂ Emissions

Unit 6 is on outage.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.2.b NO_x Emissions

Unit 1 NO_x Emissions




Figure 11: NO_x daily average emissions against emission limit for unit 1 for the month of November 2024

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 2 NO_x Emissions

Figure 12: NO_x daily average emissions against emission limit for unit 2 for the month of November 2024

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.


Unit 3 NO_x Emissions

Figure 13: NO_x daily average emissions against emission limit for unit 3 for the month of November 2024

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³. Unit 3 gaseous monitor stopped working from the 17th November 2024 and ACU (Analyser Control Unit) was taken offsite to consult with the OEM (Original Equipment Manufacturer). The monitor used the monthly average for the period (17th to 30th November 2024) when the monitor was off.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.


Unit 4 NO_x Emissions

Figure 14: NO_x daily average emissions against emission limit for unit 4 for the month of November 2024

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.


Unit 5 NO_x Emissions

Figure 15: NO_x daily average emissions against emission limit for unit 5 for the month of November 2024

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

Unit 6 NO_x Emissions

Unit 6 is on outage.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Wednesday, 18 December 2024	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the blue cells below</p> <p align="center">Choose from a dropdown menu in the green cells</p> <p align="center">The total VOC emissions for the month are in the red cells</p> <p align="center">IMPORTANT: Do not change any other cells without consulting the AQ CoE</p>		
MONTH:	November	
GENERAL INFORMATION:	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13.34	m
Diameter of tank:	9.53	m
Net fuel oil throughput for the month:	2776.456	
Molecular weight of the fuel oil:	166.00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH	Data	Unit
Daily average ambient temperature	26.22	°C
Daily maximum ambient temperature	32.63	°C
Daily minimum ambient temperature	20.19	°C
Daily ambient temperature range	12.44	°C
Daily total insolation factor	6.14	kWh/m²/day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0.68	NA
FINAL OUTPUT:	Result	Unit
Breathing losses:	0.59 kg/month	
Working losses:	0.08 kg/month	
TOTAL LOSSES (Total TVOC Emissions for the month):	0.67 kg/month	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.4 Daily power generated.

Table 5: Daily power generated per unit in MWh for the month of November 2024

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2024/11/01	11207.4	7983.26	10283.6	10199.7	13041.2	Unit off
2024/11/02	10613.2	7971.34	10391	10194.1	537.59	Unit off
2024/11/03	10424	8051.68	10483.2	10170.1	Unit off	Unit off
2024/11/04	10331.6	4955.68	10643.2	10148.8	8057.96	Unit off
2024/11/05	10179.8	6795.99	10321.5	10493.3	13080.1	Unit off
2024/11/06	10958.2	8076.2	8535.13	11002	13987.6	Unit off
2024/11/07	12175.7	8123.53	8665.82	11430.7	8219.95	Unit off
2024/11/08	8929.63	8124.4	8711.12	10660.7	Unit off	Unit off
2024/11/09	6391.06	8117.66	8695.71	12066	Unit off	Unit off
2024/11/10	10165.1	8085.45	10440.5	11672.2	3933.93	Unit off
2024/11/11	10666.5	8124.03	10108.6	9929.11	11358	Unit off
2024/11/12	11714.7	8123.4	10883.8	10754.2	7013.88	Unit off
2024/11/13	11798.9	8121.11	10844.7	12085.1	Unit off	Unit off
2024/11/14	11750.4	5436.05	12125.5	12203.3	Unit off	Unit off
2024/11/15	11110.9	8099.92	10490.5	11126.2	Unit off	Unit off
2024/11/16	10043.6	8086.1	10187.1	10451.8	Unit off	Unit off
2024/11/17	10046.1	8025.45	10167.4	11915.3	Unit off	Unit off
2024/11/18	9323.66	8020.46	10157.9	12038.2	Unit off	Unit off
2024/11/19	9763.42	8062.51	10191.2	12033.8	Unit off	Unit off
2024/11/20	11222.8	8066.82	11649.9	10847.1	Unit off	Unit off
2024/11/21	12229.1	8050.52	10920.5	9332.18	2671	Unit off
2024/11/22	11215.2	7802.52	10347.6	9337.17	13492.8	Unit off
2024/11/23	11352.7	7800.13	10236.5	9338.23	12808.8	Unit off
2024/11/24	11548.1	7813.31	10227.1	9337.3	13709.8	0.067
2024/11/25	11180.6	7808.53	10225	9329.59	13489.6	Unit off
2024/11/26	10984.6	7903.72	10228.8	9333.68	13404.1	Unit off
2024/11/27	11349.5	8062.83	10200.6	9328.68	11996	Unit off
2024/11/28	11334.2	8071.37	11097.4	9375.27	10366.9	Unit off
2024/11/29	11215.5	8140.81	11297.5	9475.53	10846.1	Unit off
2024/11/30	7255.37	8111.75	10796	11533.1	9768.36	35.054

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 16: Unit 1 daily generated power in MWh for the month of November 2024




Figure 17: Unit 2 daily generated power in MWh for the month of November 2024

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 18: Unit 3 daily generated power in MWh for the month of November 2024




Figure 19: Unit 4 daily generated power in MWh for the month of November 2024

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 5 daily generated power in MWh for the month of November 2024

2.5 Pollutant Tonnes

The emitted pollutant tonnages for November 2024 are provided in table 6.

Table 6: Pollutant tonnages for the month of November 2024

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	121.3	6 186.1	857.1
Unit 2	35.1	4 628.4	674.9
Unit 3	250.9	4 885.0	1 005.7
Unit 4	203.1	4 461.7	876.2
Unit 5	109.0	3 159.8	550.1
Unit 6	Exempt	0.0	0.0
SUM	719.4	23 321.0	3 964.0

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.
No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.6 Operating days in compliance to PM AEL Limit

Table 7: Operating days in compliance with PM AEL limit of November 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	18	3	0	8	11	61.0
Unit 2	29	0	0	0	0	23.4
Unit 3	1	2	0	27	29	108.6
Unit 4	5	5	0	20	25	114.4
Unit 5	2	7	0	6	13	129.5
Unit 6	Exempt	Exempt	Exempt	Exempt	Exempt	Exempt
SUM	55	17	0	61	78	

2.7 Operating days in compliance to SOx AEL Limit

Table 8: Operating days in compliance with SOx AEL limit of November 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	29	1	0	0	1	2 989.0
Unit 2	30	0	0	0	0	2 858.2
Unit 3	30	0	0	0	0	2 111.5
Unit 4	30	0	0	0	0	2 463.0
Unit 5	18	1	0	0	1	2 546.2
Unit 6	0	0	0	0	0	
SUM	137	2	0	0	2	

2.8 Operating days in compliance to NOx AEL Limit

Table 9: Operating days in compliance with NOx AEL limit of November 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm ³)
Unit 1	30	0	0	0	0	411.4
Unit 2	30	0	0	0	0	417.2
Unit 3	30	0	0	0	0	434.5
Unit 4	30	0	0	0	0	480.3
Unit 5	19	0	0	0	0	442.1
Unit 6	0	0	0	0	0	
SUM	139	0	0	0	0	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.9 Reference values

Table 10: Reference values for data provided, November 2024

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	7.39	8.61	7.24	8.43	6.79	
Moisture	%	3.68	3.77	3.29	2.65	4.12	
Velocity	m/s	25.4	21.7	26.9	23.7	27.5	
Temperature	°C	131.5	120.5	132.5	123.3	122.7	
Pressure	mBar	938.5	924.0	965.8	923.3	919.7	

2.10 Continuous Emission Monitors

2.10.1 Reliability

Table 11: Monitor reliability percentage (%)

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	98.7	100.0	99.9
Unit 2	100.0	99.9	99.9
Unit 3	99.4	52.1	52.2
Unit 4	94.6	100.0	100.0
Unit 5	100.0	100.0	99.6
Unit 6	Exempt	0.0	0.0

Note: NO_x emissions are measured as NO in PPM. Final NO_x value is expressed as total NO₂.

Continuous emission monitors were reliable for more than 80% of the reporting period except for unit 3. Unit 3 gaseous monitor stopped working from the 17th November 2024 and ACU was taken offsite to consult with the OEM.

Table 12: Average percentage (%) availability of monitors for the month of November 2024.

Unit	SO ₂	NO _x	PM	CO ₂
1	100.0	99.9	98.7	100.0
2	99.9	99.9	100.0	99.9
3	52.1	52.2	99.4	100.0
4	100.0	100.0	94.6	70.0
5	100.0	99.6	100.0	97.5
6	Off	Off	Off	Off

Continuous emission monitors were available for more than 80% of the reporting period except for unit 3 SO₂, NO_x and unit 4 CO₂. Unit 3 gaseous monitor stopped working from the 17th November 2024 and ACU was taken offsite to consult with the OEM. Unit 4 CO₂ availability was low due to CO₂ probe being faulty.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.2 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 2

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 3

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 4

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 5

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 6

- Unit off load.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.3 Sampling dates and times**Table 13:** Dates of last full conducted CEMS verification tests for PM for unit 2, unit 4 and 6 only

Name of service provider:		Stacklabs Environmental Services CC		
Address of service provider:		10 Chisel Street Boltonia Krugersdorp 1739		
Stack/ Unit	PM	SO₂	NO_x	CO₂
1	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
2	2024/07/02 08h50	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
3	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
4	2021/07/13 14h31	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
5	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13
6	2020/09/09 06h41	New sampling tests in table 13	New sampling tests in table 13	New sampling tests in table 13

Note: The CEMS verification tests for PM, SO₂ and NO_x were performed in November 2022 and failed. The spot tests were done in August 2023.

Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO₂ and NO_x (without unit 4 and 6 PMs)

Name of service provider:		Levego Environmental services		
Address of service provider:		Building R6 Pineland site Ardeer Road Modderfontein 1645		
Stack/ Unit	PM	SO₂	NO_x	CO₂
1	2023/08/01 19h33	2023/08/01 19:33	2023/08/01 19:33	2023/08/01 19:33
2	Dates in table 12 above	2023/07/29 21:17	2023/07/29 21:17	2023/07/29 21:17
3	2023/08/06 03:00	2023/08/06 03:00	2023/08/06 03:00	2023/08/06 03:00
4	Dates in table 12 above	2023/08/04 19:39	2023/08/04 19:39	2023/08/04 19:39
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

6	Dates in table 12 above	2023/08/05 15:52	2023/08/05 15:52	2023/08/05 15:52
---	-------------------------	------------------	------------------	------------------

Note: The CEMS Spot verification tests for PM, SO₂ and NO_x were performed in August 2023. PM spot verification test results for units 4 and 6 failed and old curves are still in use.

2.11 Units Start-up information

Table 15: Start-up information

Unit	1	
Fires in	2024/11/09	06h22
Synchronization with Grid	2024/11/09	08h35
Emissions below limit	2024/11/09	20h10
Fires in, to synchronization	2.13	HOURS
Synchronization to < Emission limit	11.35	HOURS

Unit	1	
Fires in	2024/11/30	17h10
Synchronization with Grid	2024/11/30	20h07
Emissions below limit	2024/12/01	00h01
Fires in, to synchronization	2.57	HOURS
Synchronization to < Emission limit	3.54	HOURS

Unit	2	
Fires in	2024/11/04	20h32
Synchronization with Grid	2024/11/05	01h55
Emissions below limit	2024/11/05	08h00
Fires in, to synchronization	5.23	HOURS
Synchronization to < Emission limit	6.5	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	2	
Fires in	2024/11/14	03h56
Synchronization with Grid	2024/11/14	08h34
Emissions below limit	2024/11/14	11h00
Fires in, to synchronization	4.38	HOURS
Synchronization to < Emission limit	2.26	HOURS

Unit	5	
Fires in	2024/11/04	00h01
Synchronization with Grid	2024/11/04	06h13
Emissions below limit	2024/11/04	09h00
Fires in, to synchronization	6.12	HOURS
Synchronization to < Emission limit	2.47	HOURS

Unit	5	
Fires in	2024/11/10	06h24
Synchronization with Grid	2024/11/10	12h59
Emissions below limit	2024/11/11	08h00
Fires in, to synchronization	6.35	HOURS
Synchronization to < Emission limit	19.1	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	5	
Fires in	2024/11/21	08h49
Synchronization with Grid	2024/11/21	16h25
Emissions below limit	2024/11/24	12h00
Fires in, to synchronization	7.36	HOURS
Synchronization to < Emission limit	67.35	HOURS

Unit	5	
Fires in	2024/11/29	21h41
Synchronization with Grid	2024/11/29	23h28
Emissions below limit	2024/11/30	04h00
Fires in, to synchronization	1.47	HOURS
Synchronization to < Emission limit	4.32	HOURS

2.12 Emergency generation

Table 16: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	744	744	744	744	744	744
Emergency Hours declared including hours after standing down	709.120	707.030	720.000	720.000	390.740	Off
Days over the Limit during Emergency Generation	11	0	29	25	13	Off

During the period under review all Units were on emergency generation in force from 01 November 2024 until 30 November 2024.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.13 Complaints register.

Table 17: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None					

2.14 Air quality improvements and social responsibility conducted.

Air quality improvements

None

Social responsibility conducted.

None

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.15 Ambient air quality monitoring

Marapong ambient air quality monitoring station was relocated from the previous location to Ditheku primary school and commissioned to service on 20 March 2024. The November 2024 ambient air quality monitoring report is attached to this report as an addendum.

2.16 Electrostatic precipitator and Sulphur plant status

Unit 1

- 9 fields defective.
- No abnormalities on the SO3 plant.

Unit 2

- 2 fields defective.
- No abnormalities on the SO3 plant.

Unit 3

- 2 fields defective.
- No abnormalities on the SO3 plant.

Unit 4

- 5 fields defective.
- No abnormalities on the SO3 plant.

Unit 5

- 4 fields defective.
- No abnormalities on the SO3 plant.

Unit 6

- Off load.

SO3 common plant

- No abnormalities on the sulphur storage plant.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.17 General

Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

- Fugitive dustfall out monitoring report and Ambient air quality report.
- Marapong ambient air quality report

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely

Wikus J van Rensburg

GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.