

Ian Gildenhuys
Air Quality Management
246 Voortrekker Road
Vasco
7460

Date:
3 March 2025

Enquiries: Hilton Westman
(021) 9415856

Ref: ACP/2025/02

Dear Mr Gildenhuys

ACACIA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF FEBRUARY 2025

This serves as the monthly report required in terms of Section 6.4.1 of Acacia Power Station's Atmospheric Emission License **WCCT023**. The information is applicable for the month of February 2025.

1. Raw Materials and Products (Section 7.)

Quantity of Raw Materials and Products used/produced for the month

Element	Performance	Reporting Unit
Fuel type: Diesel		
Total Fuel Consumption	297.91	Tons
Electricity Produced	1058	MWh
Average Fuel Consumption	0.282	Tons / MWh
Maximum fuel consumption rate	14 019	Kg per hour

2. Operating times of units (Section 6.4.1)

a. Total Hours

	Hours operated	Total Fuel Consumption	Energy Production
	Hours and minutes	Litres	MWh
Unit One	7hrs 8minutes	360 887	353
Unit Two	7hrs 9minutes		353
Unit Three	7hrs 8minutes		352

b. Detailed operating times

See Annexure1.

3. Complaints Register (Section 8.6.1)

No complaints were recorded for February 2025.

4. General

Acacia was requested to generate for the grid to supplement power availability and reduce national load shedding. Maintenance test runs was also performed on units after A service outage.

The monthly Ambient Air Quality Report compiled by Argos Scientific for air quality monitoring at the Acacia AQM station, will be sent to your office as soon as it is received.

We trust that the above information complies with your requirements.

Yours sincerely



Zukile Tshisa
O&M Manager
ACACIA POWER STATION

Annexure 1. Acacia Hours of operation

	Unit One			Unit two			Unit 3		
Date	Start	Finish	Total Hours	Start	Finish	Total Hours	Start	Finish	Total Hours
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14	13:35:00	13:50:00	00:15:00						
15									
16				14:50:00	15:06:00	00:16:00			
17									
18									
19							13:44:00	13:54:00	00:15:00
20									
21									
22	07:34:00	10:15:00	02:41:00	07:34:00	10:15:00	02:41:00	07:34:00	10:15:00	02:41:00
	17:16:00	21:28:00	04:12:00	17:16:00	21:28:00	04:12:00	17:16:00	21:28:00	04:12:00
23									
24									
25									
25									
26									
27									
28									

Load Factor

3.18 %