

Dr Johan Schoeman
Air Quality Management Services
Eden District Municipality
PO Box 12
GEORGE
6530

Date:
10 March 2025

Enquiries:
021 573 6162

Ref: GOU/2025/02

Dear Dr Schoeman

GOURIKWA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF FEBRUARY 2025

This serves as the monthly report required in terms of Section 9 in Gourikwa Power Station's Atmospheric Emission License (WCED013). The report addresses the period from 1-28 February 2025 and covers Particulate Matter, CO, SO₂ and NO_x (as NO₂) emissions.

1. Raw Materials and Products

Table 1: Quantity of Raw Materials and Products used/produced in Normal Operation

Raw Materials and Products	Raw Material Type	Units	Max Permitted Consumption Rate/unit/hour	Consumption Rate per unit/hr Feb 2025	Station fuel consumption for Feb 2025
	Diesel	Litres	40 000	Unit 11: 37 436.87 Unit 12: 34 149.28 Unit 13: 36 836.72 Unit 21: 39 489.43 Unit 22: 36 555.48	56 074 811,63
Production Rates	Product/By-product	Units	Max Production Capacity Permitted/unit	Production capacity per unit	Station Production Rate: Feb 2025
	Energy	MW	170	Unit 11: 34490.50 Unit 12: 34449.50 Unit 13: 37509.50 Unit 21: 39151.62 Unit 22: 38015.86	156 996.02

2. Abatement Technology

Table 2: Abatement Equipment Control Technology utilisation for the month of February

Associated Unit/Stack	Technology Type	Actual Utilisation (%) for the month
Unit 11	Low NOx burners	100%
Unit 12	Low NOx burners	100%
Unit 13	Low NOx burners	100%
Unit 21	Low NOx burners	100%
Unit 22	Low NOx burners	100%

3. Emissions Reporting

Table 3: Total monthly emission rates and Licence limits

	Date & time	CO (mg/N m ³)	NO _x (mg/Nm ³)	PM (mg/Nm ³)	SO ₂ (mg/Nm ³)
Hourly Licence Limit mg/Nm³			250	50	500
Unit 11	2025/02/01	1.33	128	0.19	4.2
	2025/02/16	0.89	138.58	0.23	0.53
	2025/02/17	0.77	101	0.16	0.87
	2025/02/18	0.58	105.56	0.18	1.08
	2025/02/19	0.89	108	0.15	1.83
	2025/02/20	0.69	106.5	0.17	1.44
	2025/02/21	0	59	0.1	0
	2025/02/22	0.09	58.9	0	0.11
	2025/02/23	0.25	57.17	0	0.56
	2025/02/24	0.47	61.43	0.1	3.11
	2025/02/25	0.42	63.76	0.06	3.55
	2025/02/26	0.61	68.06	0.06	5.99
	2025/02/27	0.92	72	0.07	8.75
	2025/02/28	1.06	73.61	0.08	10.23
Unit 12	2025/02/01	0	0	0	0
	2025/02/05	0	0	0	0
	2025/02/06	0	0	0	0
	2025/02/16	0	0	0	0
	2025/02/17	0	0	0	0
	2025/02/18	0	0	0	0

	2025/02/19	0	0	0	0
	2025/02/20	0	0	0	0
	2025/02/21	0	0	0	0
	2025/02/22	0	0	0	0
	2025/02/23	0	0	0	0
	2025/02/24	0	0	0	0
	2025/02/25	0	0	0	0
	2025/02/26	0	0	0	0
	2025/02/27	0	0	0	0
	2025/02/28	0	0	0	0
Unit 13	2025/02/01	0.76	96.28	0	0.41
	2025/02/05	1.38	145.38	0	0.36
	2025/02/06	1.22	105.64	0	0.95
	2025/02/16	1.15	135.46	0	0.31
	2025/02/17	1.16	122.05	0	0.12
	2025/02/18	2	126.12	0	3.93
	2025/02/19	1.87	139	0	1.47
	2025/02/20	1.55	137.74	0	0.08
	2025/02/21	1.68	95.24	0	3.14
	2025/02/22	1.82	102.17	0	2.31
	2025/02/23	1.84	137.88	0	0.12
	2025/02/24	1.75	137.17	0	0.32
	2025/02/25	2.37	104.33	0	0.43
	2025/02/26	9.26	1.29	0	7.58
	2025/02/27	1.22	3.47	0	17.84
	2025/02/28	1.31	101.47	0	10.6
Unit 21	2025/02/01	14.74	173.29	60	0.01
	2025/02/05	8.18	186.63	60	0.34
	2025/02/06	10.19	180.85	60	0.06
	2025/02/16	8.33	175.85	60	0.3
	2025/02/17	11.62	176.42	60	0.19
	2025/02/18	14.89	167.71	60	0.18
	2025/02/19	10	181.83	60	0.3
	2025/02/20	16.57	173.43	60	0.23
	2025/02/21	22.13	174.45	60	0.23

	2025/02/22	21.92	173.67	60	0.06
	2025/02/23	19.42	175.65	60	0.22
	2025/02/24	13.45	172.83	60	0.1
	2025/02/25	12.67	176.47	60	0.1
	2025/02/26	10.33	178.76	60	0.14
	2025/02/27	12.49	175	60	0.32
	2025/02/28	14.7	174.83	60	0.13
Unit 22	2025/02/01	45.26	152.57	0	0.67
	2025/02/05	35.25	159.13	0	0.55
	2025/02/06	37.49	157.11	0	1.42
	2025/02/16	13.53	143.75	0	1.96
	2025/02/17	14.64	143.65	0	1.11
	2025/02/18	20.02	140	0	1.14
	2025/02/19	14.77	150.43	0	1.25
	2025/02/20	19	156.5	0	0.66
	2025/02/21	23.45	150.04	0	0.50
	2025/02/22	22.74	151.57	0	1.08
	2025/02/23	22.54	149.47	0	0.95
	2025/02/24	20.4	147	0	1.53
	2025/02/25	18.75	152.53	0	0.99
	2025/02/26	15.87	157.41	0	1.29
	2025/02/27	17.91	156.61	0	1.14
	2025/02/28	20.64	156.67	0	1.47
Total Emission mass (tons)		10.665	108.85	0	0.397

GT12 recorded zero readings even under normal conditions

Table 4: Each unit and respective days operating under normal operation

Unit	Hours operating under normal operation	Hours of start-up and shut-down	Total
11	217	73	290
12	230	81	311

13	224	73	297
21	246	55	301
22	252	70	322
Total	1169	352	1521

Table 5: Monitoring Equipment-Continuous Emission Monitoring System (CEMS) availability

Associated Unit/Stack	Technology Type	Availability of CEMS	Actual Utilisation/reliability (%) for the month
Unit 11	CEMS	100%	30.56%
Unit 12	CEMS	100%	0
Unit 13	CEMS	100%	67.72%
Unit 21	CEMS	100%	100%
Unit 22	CEMS	100%	100%

Note: Continuous Emission Monitoring System (CEMS) is always online unless a fault is reported. The system auto calibrates every four (4) hours and raises an alarm if auto calibration is out of spec. Onsite technicians calibrate the system with calibration gas annually.

Table 6: Average Point Source Emissions released during start-up, maintenance and shut-down for the month of February 2025 in mg/Nm³

Unit	NO _x	SO ₂
11	77.57	2.77
12	0	0
13	93.41	5.08
21	163.54	0.92
22	156.58	1.41

4. Comments on the performance and availability of each unit

- All 5 units were available to generate power for the month of February 2025
- Leak Detection and Repair programme-** No leaks were reported during February 2025.

5. Load Factor: 36.97%

6. Complaints Register

Table 7: Complaints

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
None	N/A	N/A	N/A	N/A	N/A

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission reports sent to your office.

For any related queries, please do not hesitate to contact me on 021 573 6162

Yours sincerely



Pamela Mrubata

GOURIKWA POWER STATION