

	<b>Monthly Report</b>	<b>Matla Power Station</b>
---	-----------------------	----------------------------

Title: **Matla Power Station Monthly Emissions Report – January 2025**

Document Identifier: **06C-31482**

Alternative Reference: **31482**  
Number:

Area of Applicability: **Matla Power Station**





Functional Area: **Environmental Department**

Revision: **0**

Total Pages: **13**

Next Review Date: **N/A**

Disclosure Classification: **Controlled Disclosure**

<b>Compiled by</b>	<b>Verified by</b>	<b>Verified by</b>	<b>Supported by</b>
 M.P Chipa	 M Gcaleka	 N Molefe	 L.A Murovhi
<b>Initials and Surname</b> Officer Environmental	<b>Initials and Surname</b> Senior Advisor Engineer Boiler	<b>Initials and Surname</b> C&I System Engineer	<b>Initials and Surname</b> Environmental Manager (Acting)
Date: 21/02/2025	Date: 21/02/2025	Date: 25/02/2025	Date: 25/02/2025

Supported by



J Makuleka

Supported by



L Ngobese

Authorized by



M Lesolang

Initials and Surname

Boiler Engineering  
Manager

Initials and Surname

Engineering Group  
Manager

Initials and Surname

General Manager

Date: 26/02/2015

Date: 20/02/27

Date: 27/02/2015

**Content**

1. Introduction.....	4
2. Raw Materials and Products.....	4
3. Abatement Technology.....	4
4. Energy Source Characteristics .....	5
5. Emissions Reporting.....	5
5.1 PM Daily Averages.....	5
5.2 Sox Daily Averages.....	7
5.3 NOx Daily Averages .....	9
6. Continuous Emissions Monitoring System (CEMS) .....	12
7. CEMS Calibration and Equipment Used for Calibration .....	12
8. Validity of Correlation and Parallel Test.....	12
9. Complaint Register .....	13

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

## 1. Introduction

### MATLA POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF JANUARY 2024

This document serves as the monthly emissions report required in terms of Section 7.6 of Matla Power Station Provisional Atmospheric Emission License (AEL), 17/4/AEL/MP312/11/14

This report reflects Unit 1 to Unit 6 gaseous and particulate emissions performance against the AEL limit for the month of JANUARY 2024 only.

## 2. Raw Materials and Products

Table 1- Quantity of Raw Materials and Products Consumption in 01/2025

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption – 01/2025
	Coal	Tons/month	1 475 000	775 038
	Fuel Oil	Tons/month	3 500	700
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of 01/2025
	Energy	GWh	2 745	1 400
	Ash Produced	Tons/month	471 000	226 079

## 3. Abatement Technology

Table 2-Abatement Equipment Control Technology Efficiency in 01/2025

Associated Unit/Stack	Technology Type	Efficiency	ESP Utilization
South Stack (Unit 1, 2 and 3)	Electrostatic Precipitators (ESP)	99.230%	100%
	Electrostatic Precipitators (ESP)		
	Electrostatic Precipitators (ESP)		
Unit 4	Electrostatic Precipitators (ESP)	99.585%	100%
Unit 5	Electrostatic Precipitators (ESP)	99.505%	100%
Unit 6	Electrostatic Precipitators (ESP)	Off	Off

**Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.**

**CONTROLLED DISCLOSURE**



#### 4. Energy Source Characteristics

Table 3: Energy Source Material Characteristics for 01/2025


Characteristic	Stipulated Range (% by weight on a dry basis)	Monthly Average Content (% by weight on a dry basis)
Coal		
Sulphur Content	0.8-1.1	1.00
Ash Content	21-40	29.17

#### 5. Emissions Reporting

Table 4- Emission Limits are as follows:

SO <sub>2</sub> Monthly = 3500 mg/Nm <sup>3</sup>	Dust Daily= 200 mg/Nm <sup>3</sup> (South Stack and Unit 4) Dust Daily= 100 mg/Nm <sup>3</sup> (Unit 5 and 6)	NO <sub>2</sub> Daily= 1200 mg/Nm <sup>3</sup>
---	--	--

##### 5.1 PM Daily Averages



Matla South Stack Exceeded PM AEL limit of 200 mg/Nm<sup>3</sup> on the 10<sup>th</sup> of January 2025, due to Unit 3 SO<sub>3</sub> plant warm-up that took time to be in service where (sulphur flow could not be established because of blocked SO<sub>3</sub> lance). The station incurred a Legal Contravention for this incident.

**CONTROLLED DISCLOSURE**

Figure 2: Matla Unit 4 PM Emissions - January 2025






Figure 3: Matla Unit 5 PM Emissions - January 2025




Matla Unit 5 Exceeded PM AEL limit of 100 mg/Nm<sup>3</sup> on the 05<sup>th</sup> of January 2025, due to unit 5 SO<sub>3</sub> that took time to be in service. Unit 5 operated without SO<sub>3</sub> flow because the burner temperature took time to warm up and that resulted to the station incurring a Legal Contravention.

CONTROLLED DISCLOSURE

Figure 4: Matla Unit 6 PM Emissions - January 2025





## 5.2 Sox Daily Averages


Figure 5: Matla South Stack SO<sub>2</sub> Emissions - January 2025

CONTROLLED DISCLOSURE




Figure 6: Matla Unit 4 SO<sub>2</sub> Emissions - January 2025Figure 7: Matla Unit 5 SO<sub>2</sub> Emissions - January 2025**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Figure 8: Matla Unit 6 SO<sub>2</sub> Emissions - January 2025

### 5.3 NO<sub>x</sub> Daily Averages

Figure 9: Matla South Stack NO<sub>x</sub> Emissions - January 2025

### CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30




Figure 10: Matla Unit 4 NOx Emissions - January 2025



Figure 11: Matla Unit 5 NOx Emissions - January 2025



CONTROLLED DISCLOSURE

**Table 5-Monthly Tonnages for 01/2025**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>2</sub>
Unit 1	260.6	2 041.7	736.3
Unit 2	477.4	3 991.7	1 439.5
Unit 3	207.8	2 083.6	751.4
Unit 4	198.1	3 383.2	1 247.8
Unit 5	162.4	1 888.1	787.9
Unit 6	Off	Off	Off
SUM	1 306.4	13 388.4	4 962.9

**Table 6-Monthly Averages Concentration for 01/2025 in mg/Nm<sup>3</sup>**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>2</sub>
South Stack	241.3	1 873.5	675.6
Unit 4	100.7	1 725.6	636.3
Unit 5	164.5	1 874.4	783.6
Unit 6	Off	Off	Off

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

## 6. Continuous Emissions Monitoring System (CEMS)

**Table 7- Periods during which was inoperative/malfunctioning.**

Date	CEMS status	Comments
January 2025	Malfunctioning	<p>The communication fibre cable that sends communication to the gas monitor seemed damaged because signal was not reaching the Procal server. This occurred on the 10<sup>th</sup> of December 2024, mainly on the South stack and remains unavailable on the South Stack during this reporting period. The station gas monitors have been struggling, however parallel tests averages were used for the purpose of accurate reporting of the gases.</p> <p>The station is in a process of sourcing some of components for the gas monitors such Lenses, Zirconium cells for O<sub>2</sub> and Heater gaskets to improve the Monitor reliability and CO<sub>2</sub>+O<sub>2</sub> relationship hence the Monitor reliability is not reported on the table above.</p>

**Table 8-CEMS Monitor Reliability Percentage**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>2</sub>	O <sub>2</sub>
South Stack	90.5	-	-	-
Unit 4	100.0	-	-	-
Unit 5	100.0	-	-	-
Unit 6	Off	Off	Off	Off

Note: Parallel tests averages were used for the purpose of accurate reporting of the gases. The station is in a process of sourcing some of components for the gas monitors such Lenses, Zirconium cells for O<sub>2</sub> and Heater gaskets to improve the Monitor reliability and CO<sub>2</sub>+O<sub>2</sub> relationship hence the Monitor reliability is not reported on the table above.

## 7. CEMS Calibration and Equipment Used for Calibration

Calibration certificates to be made available upon request.

## 8. Validity of Correlation and Parallel Test

**Table 9-Validity of Correlation and Parallel Test.**

Associated Unit/Stack	Correlation Test (PM)	Parallel Test (NO <sub>2</sub> , CO <sub>2</sub> , O <sub>2</sub> , SO <sub>2</sub> )
South Stack	Invalid Since 31 August 2024. The station completed the tests and awaits preliminary correlation report.	Valid until 30 October 2025
Unit 4	Valid until 30 July 2025	Valid until 30 April 2025
Unit 5	Valid Until 25 August 2026	Valid until 30 April 2025
Unit 6	Valid until 02 August 2026	Valid until 30 June 2025

**CONTROLLED DISCLOSURE**



**9. Complaint Register****Table 10-Complaints for the month of 01/2025**

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Action taken to resolve the complaint	Date when the action was implemented.
N/A	N/A	N/A	N/A	N/A	N/A

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30