

HENDRINA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/16



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted Consumption Rate	Consumption Rate Nov-2024
	Coal	Tons	820 000	258 120.0
	Fuel Oil	Tons	3 200	1155.93
Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Production Rate Nov-2024
	Energy	GWh	1440	368.65
	Ash	Tons	290 000	44 957
	RE PM	kg/MWh	not specified	0.122

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 to < 1	0.61
Ash Content	%	20 to < 35	22.05

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
North	50	3200	1100
South	50	3200	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Nov-2024
Unit 1	Fabric Filter Plant (FFP)	Unit Off-line
Unit 2	Fabric Filter Plant (FFP)	100%
Unit 3	Fabric Filter Plant (FFP)	Unit Off-line
Unit 4	Fabric Filter Plant (FFP)	Unit Off-line
Unit 5	Fabric Filter Plant (FFP)	100%
Unit 6	Fabric Filter Plant (FFP)	100%
Unit 7	Fabric Filter Plant (FFP)	100%
Unit 8	Fabric Filter Plant (FFP)	Unit Off-line
Unit 9	Fabric Filter Plant (FFP)	Unit Off-line
Unit 10	Fabric Filter Plant (FFP)	100%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

-North Stack SO₂, and NO not available due to monitor defects.

Associated Unit/Stack	PM	SO ₂	NO	O ₂	CO ₂
North	100				
South	100	100	100	100	100

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of November-2024

Associated Unit/Stack	PM (tons)	SO _x (tons)	NO _x (tons)
North	17.8		
South	27.1	1 365.1	707.4
SUM	45.0	1 365.1	707.4

-North Stack SO₂, and NO not available due to monitor defects. Mitigation measures outlined at section 9 of this report: General

Table 6.2: Operating days in compliance to PM AEL Limit - November 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
North	30	0	0	0	0	13.1
South	23	2	0	0	2	35.2
SUM	53	2	0	0	2	

-North Stack SO₂, and NO₂ not available due to monitor defects. Mitigation measures outlined at section 9 of this report: General

Table 6.3: Operating days in compliance to SO₂ AEL Limit - November 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
North						
South	27	0	0	0	0	1 593.0
SUM	27	0	0	0	0	

-North Stack SO₂, and NO not available due to monitor defects. Mitigation measures outlined at section 9 of this report: General


Table 6.4: Operating days in compliance to NO_x AEL Limit - November 2024

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
North						
South	27	0	0	0	0	800.6
SUM	27	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions


Figure 1: Hendrina North Stack PM Emissions - November 2024



-Upset conditions on the South Ash Plant due to unplanned failure of D booster glands.

-Data not available since there were no units on load between 4 and 7 November on the North Stack

Figure 2: Hendrina South Stack PM Emissions - November 2024







Figure 6: Hendrina South Stack NOx Emissions - November 2024



Gaseous Emission Trends (NOx and SOx) for the North Stack have been removed due to erroneous data from the Continuous Emission Monitoring System (CEMS). Spot Check measurements have been performed internally and they confirm the error. The parallel tests reports review has been completed, however it was discovered that during the testing period the monitors were faulty and therefore the tests for the North Stack must be conducted again. The Station has conducted correlation tests for both stacks via services of a SANAS Accredited service provider and the reports are still in review phase. The station shall implement the correlation factors once the review phase of the report is complete and identified comments addressed. The report will be shared with the Licencing Authority.

7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1 PM Start-up information for the month of November-2024

North Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 2		Unit 2		Unit 5		Unit 5	
Breaker Open (BO)	BO previously	BO previously	11:55 am	2024/11/14	BO previously	BO previously	8:55 pm	2024/11/12
Draught Group (DG) Shut Down (SD)	n/a	n/a	3:25 pm	2024/11/16	n/a	n/a	9:15 pm	2024/11/12
BO to DG SD (duration)	n/a	DD:HH:MM	02:03:30	DD:HH:MM	n/a	DD:HH:MM	00:00:20	DD:HH:MM
Fires in time	10:35 pm	2024/11/05			02:07:35	2024/11/02	2024/11/12	2024/11/12
Synch. to Grid (or BC)	3:20 pm	2024/11/07			6:00 pm	2024/11/02	3:10 am	2024/11/13
Fires in to BC (duration)	01:16:45	DD:HH:MM		DD:HH:MM	00:10:25	DD:HH:MM	00:04:55	DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit			not > limit	not > limit	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No	Unit 6		Unit 6		Unit 7		Unit 7	
Breaker Open (BO)	10 35 am	2024/11/03	11 15 pm	2024/11/24	1 35 am	2024/11/02	12 45 am	2024/11/16
Draught Group (DG) Shut Down (SD)	1 55 am	2024/11/04	12 35 pm	2024/11/25	1 35 pm	2024/11/02	2 55 am	2024/11/16
BO to DG SD (duration)	00 15 20	DD HH MM	00 13 20	DD HH MM	00 12 00	DD HH MM	00 02 10	DD HH MM
Fires in time	10 15 pm	2024/11/06			09 23 45	2024/11/09	2024/11/16	2024/11/16
Synch to Grid (or BC)	8 00 am	2024/11/07			5 20 pm	2024/11/10	5 40 pm	2024/11/16
Fires in to BC (duration)	00 09 45	DD HH MM		DD HH MM	00 17 35	DD HH MM	00 06 45	DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit			not > limit	not > limit	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD HH MM		DD HH MM	n/a	DD HH MM	n/a	DD HH MM


South Stack Continued	Event 1		Event 2		Event 3		Event 4	
Unit No	Unit 7		no event		no event		no event	
Breaker Open (BO)	11 45 am	2024/11/25						
Draught Group (DG) Shut Down (SD)	5 05 pm	2024/11/25						
BO to DG SD (duration)	00 05 20	DD HH MM		DD HH MM		DD HH MM		DD HH MM
Fires in time	10 35 pm	2024/11/25						
Synch to Grid (or BC)	4 40 am	2024/11/26						
Fires in to BC (duration)	00 06 05	DD HH MM		DD HH MM		DD HH MM		DD HH MM
Emissions below limit from BC (end date)	not > limit	not > limit						
Emissions below limit from BC (duration)	n/a	DD HH MM		DD HH MM		DD HH MM		DD HH MM


8 Complaints register

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where	Date measure will be implemented	Measures implemented to prevent
The Station did not receive complaints related to air quality during the month of November 2024					

09 General


The station has taken to execute short term and long term mitigations to ensure reliability of the CEMS. The short term action include implementation of the parallel curves. For the long term, the station will engage the Licencing Authority regarding replacement of the CEMS as required by Paragraph b) of General Condition 4.1 of the AEL.

 20/12/2024
 Compiled Environmental Officer
 A. Boja Date

 23/12/2024
 Verified by System Engineer Boiler/ FFP
 Moyahabo Cetlyff Maoto Date

p p  23/12/2024
 Validated by Manager Boiler Engineering Manager
 G. Kgatlhe Date

 24/12/2024
 Authorised by GM
 T. Lekalakala Date

 23/12/2024
 Supported by Environmental Manager
 L. Ntula Date

Compiled by Environmental Department/ Boiler Engineering Department

FFP SE/ Environmental Officer

For Nkangala District Municipality

Air Quality Officer

Copies Eskom Environmental Management

D Herbst
B Mccourt

Group Technology Engineering

R Rampiar
E Patel

Hendrina Power Station

Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager
System Engineer Boiler Engineering
Environmental Officer
C & I Engineering Manager
Production Manager
Environmental Manager
PSGM