

Ms Tebogo Mogakabe
 Manager: Municipal Environmental Services
 Gert Sibande District Municipality
 PO BOX 1748
 ERMELO
 2350

Date: 09 April 2025

Enquiries: Johan Swanepoel
 Tel +27 17 799 2047

MAJUBA POWER STATION'S MONTHLY EMISSIONS REPORT FOR THE MONTH OF MARCH 2025

This serves as the monthly report required in terms of Majuba Power Station's Atmospheric Emission License (MPS/0014/2019/F03) under section 7 routine reporting and record keeping. The emissions are for the month of March 2025. Verified emissions of particulates are included. SO₂ and NO_x (as NO₂) emissions are included for all units. Greenhouse gasses are excluded as per the agreement reached between Eskom and the Department of Forestry, Fisheries and the Environmental in the first quarter of 2017/18 financial year's MINTEC and MINMEC management meeting.

Raw Materials and Products

Table 1. Quantity of Raw Materials and Products used/produced for the month of March 2025

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption/ Rate in Month of March 2025
	Coal	Tons/month	1 800 000	1 158 952
	Fuel Oil	Tons/month	6 000	4 825.5
Production Rates	Product/ By-Product Name	Unit	Maximum Production Rate Permitted (Quantity)	Production Rate in Month of March 2025
	Energy	*GWh	*3 058	1 632.8
	Ash	Tons/month	Not stated in the license	346 874.33

*Majuba AEL stipulates a maximum production capacity of 4110 MW. This equates to a production rate of 3058 GWh per month when converted, as indicated above. This is to align to the monthly production rates reported.

Abatement Technology

Table 2. Abatement Equipment Control Technology for the month of March 2025

Associated Unit	Technology Type	Actual Utilisation (%) for the month of July 2024	*Minimum Control Efficiency (%)
Unit 1	Fabric Filter Plant	100	99.82
Unit 2	Fabric Filter Plant	100	99.84
Unit 3	Fabric Filter Plant	100	99.90
Unit 4	Fabric Filter Plant	100	99.97
Unit 5	Fabric Filter Plant	100	99.96
Unit 6	Fabric Filter Plant	100	99.95

*Calculated from the assumption of 90% fly ash to 10% bottom ash and percentage ash as measured in coal

Energy Source Characteristics

Table 3. Energy Source Material Characteristics for the month of March 2025

Characteristic	Stipulated Limit (Unit)	Monthly Average Content
Sulphur Content	0.94%	0.60
Ash Content	30%	29.93

Emissions Reporting




Figure 1. Particulate Matter emissions (daily averages) for the month of March 2025 against emission limit for Unit 1.




Figure 2. Particulate Matter emissions (daily averages) for the month of March 2025 against emission limit for Unit 2.




Figure 3. Particulate Matter emissions (daily averages) for the month of March 2025 against emission limit for Unit 3.




Figure 4. Particulate Matter emissions (daily averages) for the month of March 2025 against emission limit for Unit 4.




Figure 5. Particulate Matter emissions (daily averages) for the month of March 2025 against emission limit for Unit 5.




Figure 6. Particulate Matter emissions (daily averages) for the month of March 2025 against emission limit for Unit 6.




Figure 7. SO₂ emissions (daily averages) for the month of March 2025 against emission limit for Unit 1.




Figure 8. SO₂ emissions (daily averages) for the month of March 2025 against emission limit for Unit 2.




Figure 9. SO₂ emissions (daily averages) for the month of March 2025 against emission limit for Unit 3.




Figure 10. SO₂ emissions (daily averages) for the month of March 2025 against emission limit for Unit 4.




Figure 11. SO₂ emissions (daily averages) for the month of March 2025 against emission limit for Unit 5.




Figure 12. SO₂ emissions (daily averages) for the month of March 2025 against emission limit for Unit 6.




Figure 13. NO_x emissions (daily averages) for the month of March 2025 against emission limit for Unit 1.




Figure 14. NO_x emissions (daily averages) for the month of March 2025 against emission limit for Unit 2.




Figure 15. NOx emissions (daily averages) for the month of March 2025 against emission limit for Unit 3.




Figure 16. NOx emissions (daily averages) for the month of March 2025 against emission limit for Unit 4




Figure 17. NOx emissions (daily averages) for the month of March 2025 against emission limit for Unit 5




Figure 18. NO_x emissions (daily averages) for the month March 2025 against emission limit for Unit 6

Table 4: Monthly tonnages for the month of March 2025

Unit	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	89.7	5 089	2 788
Unit 2	98.7	5 136	2 212
Unit 3	57.9	2 363	1 480
Unit 4	11.0	1 991	1 180
Unit 5	20.7	2 076	1 174
Unit 6	29.9	5 391	1 810

Table 5: Average monthly concentrations (mg/Nm³) for the month of March 2025

Unit	PM (Mg/Nm ³)	SO ₂ (Mg/Nm ³)	NO _x (Mg/Nm ³)
1	43.1	2 312.8	1 267.2
2	41.6	2 091.3	901.3
3	51.1	2 007.8	1 255.5
4	11.2	1 762.0	1 043.1
5	18.4	1 749.8	982.8
6	12.6	2 234.0	749.2

Table 6: Each unit and respective days operating in compliance to the AEL Emission Limits (SO₂, NO_x, and PM)

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance
Unit 1	28	0	0	0	0
Unit 2	29	0	0	0	0
Unit 3	30	0	0	0	0
Unit 4	19	0	0	0	0
Unit 5	21	0	0	0	0
Unit 6	31	0	0	0	0

Table 7: MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO	O ₂
Unit 1	100.0	0.0	0.0	99.9
Unit 2	98.6	100.0	100.0	0.0
Unit 3	98.1	100.0	100.0	100.0
Unit 4	98.1	99.5	99.5	85.5
Unit 5	100.0	95.8	95.5	95.5
Unit 6	99.7	100.0	100.0	100.0

Table 8: CO₂ and O₂ deviations of the Month of March 2025

*Blank spaces indicate that the unit was offline during that period

2025/04/03	CO ₂ (Actual Dry %)						Final O ₂ CEMS Data (%)						SUM CO ₂ + O ₂ CEMS Data (%)					
Date	U1	U2	U3	U4	U5	U6	U1	U2	U3	U4	U5	U6	U1	U2	U3	U4	U5	U6
2025/03/01		9.4	9.7	9.1		11.8		10.3	11.0	12.4		10.1		19.7	20.7	21.5		21.9
2025/03/02		9.8	9.7	9.5		11.0		10.3	10.9	11.3		10.4		20.1	20.6	20.8		21.5
2025/03/03	9.2	9.4	9.6	9.3		10.6	9.8	10.3	11.3	11.1		10.7	19.0	19.7	20.9	20.4		21.4
2025/03/04	8.8	9.2	9.6	9.4		10.7	10.3	10.3	11.8	11.9		10.6	19.1	19.5	21.3	21.2		21.2
2025/03/05	8.6	8.8	9.7	9.1		10.7	10.5	10.3	11.7	11.5		10.3	19.1	19.1	21.4	20.6		21.0
2025/03/06	9.0	8.6	9.8	8.9	8.3	10.8	10.1	10.3	11.8	11.5	12.4	10.9	19.1	18.9	21.6	20.3	20.7	21.7
2025/03/07	8.6	9.0	9.7	9.1	10.5	10.7	10.5	10.3	11.7	11.8	9.9	11.1	19.1	19.3	21.4	20.9	20.4	21.8
2025/03/08	8.7	8.8	9.7	9.2	10.6	10.6	10.4	10.3	11.5	11.2	9.9	11.0	19.1	19.1	21.2	20.3	20.5	21.6
2025/03/09	8.4		9.7	8.9	11.1	10.7	10.8		11.5	11.8	9.5	10.8	19.2		21.3	20.7	20.6	21.5
2025/03/10	8.7	8.6	9.7		10.8	10.7	10.4	10.3	11.5		10.0	10.8	19.1	18.9	21.3		20.9	21.4
2025/03/11	9.0	9.2	9.6		10.7	10.7	10.1	10.3	11.1		10.2	10.8	19.1	19.5	20.8		20.9	21.5
2025/03/12	8.8	9.3	9.7		11.1	10.7	10.4	10.3	11.3		9.7	10.7	19.1	19.6	21.0		20.8	21.4
2025/03/13	8.8	9.4	9.8		11.3	10.7	10.3	10.3	11.5		9.5	10.6	19.1	19.7	21.3		20.9	21.4
2025/03/14	8.3	9.3	9.6	7.9	10.6	10.7	10.9	10.3	11.3	12.6	10.3	10.6	19.2	19.6	20.9	20.5	20.9	21.3
2025/03/15	8.0	9.1	9.7	7.8	11.1	10.6	11.3	10.3	11.3	13.8	9.6	10.8	19.3	19.4	21.0	21.6	20.7	21.3
2025/03/16	8.3	9.3	9.7	7.9	11.2	10.5	11.0	10.3	11.1	14.0	9.5	10.5	19.2	19.6	20.8	21.8	20.7	21.1
2025/03/17	8.6	9.1	9.8	7.6	11.1	10.6	10.5	10.3	11.2	13.8	9.3	10.6	19.1	19.4	21.0	21.4	20.4	21.2
2025/03/18	8.7	9.2	9.8	7.6	10.6	10.6	10.5	10.3	11.6	14.0	10.1	10.9	19.1	19.5	21.4	21.6	20.7	21.5
2025/03/19	7.6	8.9	9.8	7.4	10.5	10.6	11.8	10.3	11.8	13.5	10.4	11.5	19.4	19.2	21.6	20.9	20.9	22.0
2025/03/20	8.2	8.6	9.7	7.9	10.7	10.6	11.0	10.3	12.5	13.4	10.1	11.5	19.2	18.9	22.2	21.3	20.8	22.2
2025/03/21	9.0	8.9	9.8	8.0	11.4	10.7	10.1	10.3	11.6	12.7	9.0	10.3	19.1	19.2	21.4	20.7	20.4	21.0
2025/03/22	8.7	9.0	9.8	7.2	11.5	10.7	10.4	10.3	11.4	13.3	8.9	10.7	19.1	19.3	21.2	20.5	20.5	21.4
2025/03/23	9.1	9.2	9.8		11.4	10.7	10.0	10.3	11.3		9.8	10.6	19.0	19.5	21.1		21.2	21.3
2025/03/24	9.0	9.0	9.8		11.5	10.6	10.0	10.3	11.0		11.7	10.9	19.1	19.3	20.8		23.2	21.5
2025/03/25	9.0	8.8	9.8		8.8	10.7	10.0	10.3	11.0		10.1	10.9	19.1	19.1	20.8		18.9	21.6
2025/03/26	8.6	9.0	9.8			10.7	10.5	10.3	11.1			10.8	19.1	19.3	21.0			21.5
2025/03/27	8.9	9.1	9.7			10.7	10.2	10.3	11.5			11.4	19.1	19.4	21.2			22.1
2025/03/28	7.9	9.2	9.8		10.9	10.8	11.4	10.3	11.5		12.2	12.3	19.3	19.5	21.3		23.0	23.1
2025/03/29	8.6	9.0	9.6	7.3	11.6	10.8	10.7	10.3	12.1	12.9	9.6	12.8	19.3	19.3	21.7	20.3	21.3	23.6
2025/03/30	8.5	8.8	8.5	8.0	11.8	10.8	10.6	10.3	12.5	13.4	10.0	13.2	19.1	19.1	21.0	21.4	21.7	23.9
2025/03/31	8.5	9.0	8.5	7.9	11.7	10.8	10.7	10.3	12.3	13.6	10.2	12.2	19.1	19.3	20.8	21.5	21.9	23.0

Calculation: CO₂% + O₂% = 19.5-21.5%

Emergency Generation

Table 9: Emergency Generation for the month of March 2025

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	0	0	0	0	0	0
Emergency Hours declared including hours after stand down	0	0	0	0	0	0
Hours over the Limit during Emergency Generation	0	0	0	0	0	0

Comments on the performance and availability of each unit

UNIT 1

The unit base loaded for most of the days during the month and off for two days. Seventy fabric filter bags were replaced during the month.

UNIT 2

The unit base loaded for most of the days during the month and off for one day. Seventy-five fabric filter bags were replaced during the month.

UNIT 3

The unit base loaded for all the days during the month. One-hundred and five fabric filter bags were replaced during the month.

UNIT 4

The unit base loaded for most of the days during the month and off for ten days. Thirty-two fabric filter bags were replaced during the month.

UNIT 5

The unit base loaded for most of the days during the month and off for seven days. Twenty-two fabric filter bags were replaced during the month.

UNIT 6

The unit base loaded for all the days during the month. Fourteen fabric filter bags were replaced during the month.

Complaints Register

Table 10: Complaints for the month of March 2025


Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
	No complaints were received during the month of March 2025.				

General

Unit 1 SO₂ & NO_x and unit 2 O₂ monitors are faulty. The Original Equipment Manufacturer came to site for inspection, they need to source spares to repair the faulty monitors. The Station will update the licensing authority once the monitors have been repaired.

Yours sincerely

Report compiled by:



Faith Kagoda

ENVIRONMENTAL MANAGER: (MAJUBA)

Date 09/04/2025

Report verified by:



Lindani Madonsela

BOILER ENGINEERING MANAGER: (MAJUBA)

Date 10/04/2025

Report approved by:



Johan Swanepoel

ENGINEERING MANAGER: (MAJUBA)

2025/04/10
Date