

HENDRINA POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License 17/4/AEL/MP312/11/16



1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted Consumption Rate	Consumption Rate Jan-2025
	Coal	Tons	820 000	216 189.0
	Fuel Oil	Tons	3 200	2146.05
Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Production Rate Jan-2025
	Energy	GWh	1488	311.11
	Ash	Tons	290 000	62 904
	RE PM	kg/MWh	not specified	0.202

2 ENERGY SOURCE CHARACTERISTICS

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
Sulphur Content	%	0.6 to < 1	0.66
Ash Content	%	20 to < 35	21.63

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
North	50	3200	1100
South	50	3200	1100

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Jan-2025
Unit 1	Fabric Filter Plant (FFP)	Unit Off-line
Unit 2	Fabric Filter Plant (FFP)	100%
Unit 3	Fabric Filter Plant (FFP)	Unit Off-line
Unit 4	Fabric Filter Plant (FFP)	Unit Off-line
Unit 5	Fabric Filter Plant (FFP)	100%
Unit 6	Fabric Filter Plant (FFP)	100%
Unit 7	Fabric Filter Plant (FFP)	100%
Unit 8	Fabric Filter Plant (FFP)	Unit Off-line
Unit 9	Fabric Filter Plant (FFP)	Unit Off-line
Unit 10	Fabric Filter Plant (FFP)	100%

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

5 MONITOR RELIABILITY (%)

-O₂ monitor faulty.
 -SO₂, and NO not available due to monitor defects.

Associated Unit/Stack	PM	SO ₂	NO	O ₂	CO ₂
North	99.9				
South	100.0	100.0	99.9	99.9	99.9

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂.

6 EMISSION PERFORMANCE

Table 6.1: Monthly tonnages for the month of January-2025

Associated Unit/Stack	PM (tons)	SO _x (tons)	NO _x (tons)
North	37.9	1 500.2	783.0
South	25.0	1 517.5	819.8
SUM	62.9	3 017.7	1 602.8

-North Stack SO₂, and NO_x: Surrogate values measured from QAL 2 Parallel Test Report (RSL411) were used due to monitor defects. Mitigation measures outlined at section 9 of this report: General

Table 6.2: Operating days in compliance to PM AEL Limit - January 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm³)
North	20	6	2	0	8	45.4
South	28	2	1	0	3	26.9
SUM	48	8	3	0	11	

-North Stack SO₂: Surrogate values measured from QAL 2 Parallel Test Report (RSL411) were used due to monitor defects. Mitigation measures outlined at section 9 of this report: General

Table 6.3: Operating days in compliance to SO₂ AEL Limit - January 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm³)
North	31	0	0	0	0	1 561.0
South	31	0	0	0	0	1 604.2
SUM	62	0	0	0	0	

-North Stack NO_x: Surrogate values measured from QAL 2 Parallel Test Report (RSL411) were used due to monitor defects. Mitigation measures outlined at section 9 of this report: General

Table 6.4: Operating days in compliance to NO_x AEL Limit - January 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm³)
North	31	0	0	0	0	814.8
South	31	0	0	0	0	856.6
SUM	62	0	0	0	0	

Table 6.5: Legend Description

Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions





Figure 3: Hendrina North Stack SO₂ Emissions - January 2025




Figure 4: Hendrina South Stack SO₂ Emissions - January 2025




Figure 5: Hendrina North Stack NOx Emissions - January 2025





Figure 6: Hendrina South Stack NOx Emissions - January 2025



Gaseous Emission Trends (NOx and SOx) for the North Stack: Surrogate values from QAL2 (RSL 411) have been used due to erroneous data from the Continuous Emission Monitoring System (CEMS).

Spot Check measurements have been performed internally and they confirm the error. The parallel tests reports review has been completed, however it was discovered that during the testing period the monitors were faulty and therefore the tests for the North Stack must be conducted again.

The Station has conducted correlation tests for both stacks via services of a SANAS accredited service provider and the reports are still in review phase. The station shall implement the correlation factors once the review phase of the report is complete and identified comments addressed. The report will be shared with the Licencing Authority.

7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1 PM Start-up information for the month of January-2025

North Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 4		Unit 5		Unit 5		Unit 5	
Breaker Open (BO)	1:35 pm	2025/01/05	BO previously	BO previously	8:05 am	2025/01/14	8:35 am	2025/01/28
Draught Group (DG) Shut Down (SD)	1:35 pm	2025/01/05	n/a	n/a	6:55 am	2025/01/16	8:45 am	2025/01/28
BO to DG SD (duration)		DD:HH:MM	n/a	DD:HH:MM	01:22:50	DD:HH:MM	00:00:10	DD:HH:MM
Fires in time	1:55 pm	2025/01/05	2025/01/08	2025/01/08	22:09:55	2025/01/22	2025/01/28	2025/01/28
Synch. to Grid (or BC)	11:50 pm	2025/01/05	6:20 pm	2025/01/08	12:00 am	2025/01/23	3:50 pm	2025/01/28
Fires in to BC (duration)	00:09:55	DD:HH:MM	00:15:55	DD:HH:MM	00:14:05	DD:HH:MM	00:06:35	DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit	not > limit	not > limit	not > limit	not > limit
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 7		Unit 10		Unit 10		no event	
Breaker Open (BO)	BO previously	BO previously	7:55 am	2025/01/03	4:15 pm	2025/01/14		
Draught Group (DG) Shut Down (SD)	n/a	n/a	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD		
BO to DG SD (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM
Fires in time	8:05 am	2025/01/02						
Synch. to Grid (or BC)	10:40 pm	2025/01/02						
Fires in to BC (duration)	00:14:35	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit						
Emissions below limit from BC (duration)	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM

08 Complaints register:

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident	Dispersion modeling of pollutants where applicable	Date measure will be implemented	Measures implemented to prevent reoccurrence
The Station did not receive complaints related to air quality during the month of January 2025.					

09 General

The station has taken to execute short term and long term mitigations to ensure reliability of the CEMS. The short term action include implementation of the parallel curves. For the long term, the station will engage the Licencing Authority regarding replacement of the CEMS as required by Paragraph b) of General Condition 4.1 of the AEL.

Reporting as per AEL Condition 7.2.8:

North Stack Hours exceeded between 04-05/01/2025: 30
 North Stack Hours Exceeded between 16-18/01/2025: 64
 South Stack Hours Exceeded on the 27/01/2025: 14



18 February 2025

Compiled by: **Environmental Officer**
Azola Boja

Date



05/05/2025

Authorised by: GM
T. Lekalakala

Date

Compiled by: Boiler Engineering Department

For: Nkangala District Municipality

Copies: Eskom Environmental Management

Group Technology Engineering

Hendrina Power Station:




18/02/2025

Checked by: **System Engineer Boiler/ FFP**
Moyahabo Cettyit Maoto

Date

Validated by Manager:



Boiler Engineering Manager
G. Kgwathe

18/02/2025

Date



Supported by:

Environmental Manager
L. Ntita

30/04/2025

Date

FFP SE/ Environmental Officer

Air Quality Officer

D Herbst
B Mccourt

R Rampiar
E. Patel

Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager
System Engineer: Boiler Engineering
Environmental Officer
C & I Engineering Manager
Production Manager
Environmental Manager
PSM