

Ms Nompumelelo Simelane
Nkangala District Municipality
PO BOX 437
Middelburg
1050

Date:
22 May 2025

Enquiries:
Livhuwani Tshilate
017 615 2317

Ref: 17/AEL/MP312/11/09

Dear Ms. Simelane

KRIEL POWER STATION'S MONTHLY STACK EMISSIONS REPORT FOR THE MONTH OF APRIL 2025

This serves as the monthly report required in terms of Section 7.4 in Kriel Power Station's Atmospheric Emission License 17/AEL/MP312/11/09. The emissions are for the month of April 2025. Verified emissions of particulates matter, SO₂ and NO_x (as NO₂) are also included.

Raw Materials and Products

Table 1: Quantity of Raw Materials and Products used/produced for the month of April 2025

Raw Materials and Products used	Raw Material Type	Units	Maximum Permitted Consumption / Rate (Quantity)	Consumption / Rate in Month of April 2025
	Coal	Tons/month	1 227 600	415 536.00
	Fuel Oil	Tons/month	8 000	5065.38
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of April 2025
	Energy	GWh	3 000/2 232	663.277
	Ash	Tons/month	320 000	3111.9
	RE PM	kg/MWh	not specified	4.141

1/...

Abatement Technology

Table 2: Abatement Equipment Control Technology for April 2025.

Associated Unit/Stack	Technology Type	Actual Efficiency (%)	Technology Type	SO ₃ Utilisation (%)
Unit 1	ESP& SO3	97.24%	SO3 Plant	100.00
Unit 2	ESP& SO3	96.85%	SO3 Plant	100.00
Unit 3	ESP& SO3	98.77%	SO3 Plant	100.00
Unit 4	ESP& SO3	91.14%	SO3 Plant	100.00
Unit 5	ESP& SO3	96.36%	SO3 Plant	100.00
Unit 6	ESP& SO3	Exempt	SO3 Plant	Exempt

Note: ESP plant does not contain bypass mode operation; hence plant 100% Utilised.

Energy Source Characteristics

Table 3: Energy Source Material Characteristics for the month of April 2025

Characteristic	Stipulated Range (Unit)	Monthly Average Content
Sulphur Content	0.6-1.2 (%)	0.75
Ash Content	27-32 (%)	22.82

Monthly Monitor Reliability

Associated Unit/Stack	PM (%)	SO _x (%)	NO _x (%)
North	74.59	96.27	100.00
South	38.13	91.50	100.00

Emissions Reporting

Graph Legend Description

Condition	Colour	Description
Normal	Green	Emissions below Emission Limit Value (ELV)
Grace	Blue	Emissions above the ELV during grace period
Section 30	Orange	Emissions above ELV during a NEMA S30 incident
Contravention	Red	Emissions above ELV but outside grace or S30 incident conditions




Figure 1: PM emissions for the month of April 2025 against daily emission limit (100 mg/Nm³) for the North Stack.




Figure 2: PM emissions for the month of April 2025 against daily emission limit (100 mg/Nm³) for the South Stack. Units 4-6 were not running in the first week of the month due to half station shutdown.




Figure 3. SO₂ emissions for the month of April 2025 against daily emission limit (2800 mg/Nm³) for the North Stack.




Figure 4. SO₂ emissions for the month of April 2025 against daily emission limit (2800mg/Nm³) for the South Stack. Units 4-6 were not running in the first week of the month due to half station shutdown.




Figure 5. NO_x emissions for the month of April 2025 against daily emission limit (1100 mg/Nm³) for the North Stack. Two contraventions due to NO_x exceedances are recorded and investigation for these two exceedances will be carried out.




Figure 6. NO_x emissions for the month of April 2025 against daily emission limit (1100mg/Nm³) for the South Stack. Units 4-6 were not running in the first week of the month due to half station shutdown.

Table 4: Monthly tonnages for the month April 2025

Unit	PM (tons)	SO ₂ (tons)	NO ₂ (tons)
SUM	3111.9	4870.7	3855.0

Table 5: Each unit and respective days operating under normal operation and section 30 days respectively.

Table 5.1: Operating days in non-compliance to PM AEL Limit – April 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Monthly Limit Exceedance	Average PM (mg/Nm ³)
North	8	8	0	14	22	665.8
South	1	7	0	12	19	1584.8

Table 5.2: Operating days in compliance to SO_x AEL Limit - April 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO _x (mg/Nm ³)
North	30	0	0	0	0	1 104.9
South	22	0	0	0	0	1 543.6

Table 5.3: Operating days in compliance to NO_x AEL Limit – April 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
North	28	0	0	2	2	1006.2
South	22	0	0	0	0	974.0

Light up information

Table 6: PM Start-up information for the month of April 2025

North Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 1		Unit 1		Unit 1		Unit 2	
Breaker Open (BO)			6:10 pm	2025/04/03	9:40 am	2025/04/09	3:00 am	2025/04/03
Draught Group (DG) Shut Down (SD)			6:40 pm	2025/04/03	11:45 am	2025/04/09	6:15 am	2025/04/05
BO to DG SD (duration)		DD:HH:MM	00:00:30	DD:HH:MM	00:02:05	DD:HH:MM	02:03:15	DD:HH:MM
Fires in time			6:25 am	2025/04/04	4:30 pm	2025/04/09	6:50 pm	2025/04/05
Synch. to Grid (or BC)			10:40 am	2025/04/04	12:25 am	2025/04/10	9:25 pm	2025/04/05
Fires in to BC (duration)		DD:HH:MM	00:04:15	DD:HH:MM	00:07:55	DD:HH:MM	00:02:35	DD:HH:MM

Emissions below limit from BC (end date)			12:00 am	2025/04/08	12:00 am	2025/04/13	12:00 am	2025/04/08
Emissions below limit from BC (duration)		DD:HH:MM	03:13:20	DD:HH:MM	02:23:35	DD:HH:MM	02:02:35	DD:HH:MM

North Stack ...Cont.	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 3		Unit 3		Unit 2		no event	
Breaker Open (BO)	3:40 am	2025/04/01	3:40 pm	2025/04/22	1:30 am	2025/04/30		
Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	6:35 pm	2025/04/23	DG did not trip or SD	DG did not trip or SD		
BO to DG SD (duration)	n/a	DD:HH:MM	01:02:55	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM
Fires in time	3:40 am	2025/04/01	10:35 pm	2025/04/27	1:30 am	2025/04/30		
Synch. to Grid (or BC)	11:45 am	2025/04/01	9:05 pm	2025/04/28	3:35 am	2025/04/30		
Fires in to BC (duration)	00:08:05	DD:HH:MM	00:22:30	DD:HH:MM	00:02:05	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	10:35 am	2025/05/05	10:35 am	2025/05/05		
Emissions below limit from BC (duration)	n/a	DD:HH:MM	06:13:30	DD:HH:MM	05:07:00	DD:HH:MM		DD:HH:MM

South Stack	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 4		Unit 4		Unit 5		Unit 5	
Breaker Open (BO)								
Draught Group (DG) Shut Down (SD)								
BO to DG SD (duration)		DD:HH:MM		DD:HH:MM		DD:HH:MM		DD:HH:MM
Fires in time			10:10 pm	2025/04/12			11:25 am	2025/04/09
Synch. to Grid (or BC)			9:15 am	2025/04/13			7:25 am	2025/04/10
Fires in to BC (duration)		DD:HH:MM	00:11:05	DD:HH:MM		DD:HH:MM	00:20:00	DD:HH:MM
Emissions below limit from BC (end date)			11:00 pm	2025/04/16			not > limit	not > limit

Emissions below limit from BC (duration)		DD:HH:MM	03:13:45	DD:HH:MM		DD:HH:MM	n/a	DD:HH:MM
--	--	----------	----------	----------	--	----------	-----	----------

South Stack ...Cont.	Event 1		Event 2		Event 3		Event 4	
Unit No.	Unit 4		Unit 5		Unit 5		no event	
Breaker Open (BO)	10:20 pm	2025/04/16	2:40 am	2025/04/19	10:05 pm	2025/04/30		
Draught Group (DG) Shut Down (SD)	10:45 pm	2025/04/16	2:55 pm	2025/04/19	DG did not trip or SD	DG did not trip or SD		
BO to DG SD (duration)	00:00:25	DD:HH:MM	00:12:15	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM
Fires in time	5:45 am	2025/04/17	2:05 am	2025/04/24	10:05 pm	2025/04/30		
Synch. to Grid (or BC)	10:35 am	2025/04/17	12:25 am	2025/04/26	2:30 am	2025/05/01		
Fires in to BC (duration)	00:04:50	DD:HH:MM	01:22:20	DD:HH:MM	00:04:25	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	12:00 am	2025/05/03	12:00 am	2025/05/03		
Emissions below limit from BC (duration)	n/a	DD:HH:MM	06:23:35	DD:HH:MM	01:21:30	DD:HH:MM		DD:HH:MM

Reasons for poor emissions performance for both stacks in April 2025

Table 7: Reasons for poor emissions performance for April 2025

Start Date	Plant	Reason	Impact on Emissions	Actions	Feedback	Completion Date
Continuous Emission Monitoring Systems						
						-
Plant Failures						
12/04/2025	North Stack	Unit 1 faulty sulphur flow sensor	No SO3 injection resulting in high emissions	Maintenance to inspect and carry out necessary repairs	Completed	12/04/2025
18/04/2025-30/04/2025	North and South Stack	The PM emissions increased above the limit from the 18/04/2025 due to unavailability of the overland conveyors (18A and 18B), 18A was not in service to allow for cleaning	The consequence of failure to transport was ash accumulation inside the fields and	Opportunity outage is required for ESP internal inspection.		TBC

		around the 18B tail end pulley. On the 20/04/2025 18B was on PTW to replace overland belt tail end pulley bearings. On the 21/04/2025 18B was available but not transporting due to defective conditioners (1B, 2B, 4B and 5B blocked). Transportation commenced on the 22/04/2025 with conditioner 1B and 4B & Ash conditioner 2B was on PTW until the 25/04/2025.	stuck plate rappers.			
--	--	---	----------------------	--	--	--

Complaints Register

Table 8: Complaint for the month of April 2025

Source Code/ Name	Root Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modeling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
There were no complaints related to air quality received during the month of April 2025.					

General

Units 4-6 were not running in the first week of the month due to half station shutdown. Two contraventions due to NO_x exceedances are recorded on the 26 and 28 of April (North Stack) and investigation for these two exceedances will be carried out.

NB: The rest of the information demonstrating compliance with the emissions license conditions is supplied in the annual emission reports sent to your office.