Ms Nompumelelo Simelane Nkangala District Municipality PO Box 437 Middleburg 1050

Date:

April 2025

Enquiries: Lesiba Kgobe Tel: +27 13 699 7817

Ref: Kusile Power Station AEL (17/4/AEL/MP311/12/01)

Dear Ms. Simelane

KUSILE POWER STATION'S MONTHLY EMISSIONS REPORT FOR MARCH 2025

This serves as the monthly report required in terms of Section 7.6 in Kusile Power Station's Atmospheric Emission License: 17/4/AEL/MP311/12/01. The emissions are for the month of March 2025.

Hoping the above will meet your satisfaction.

Yours sincerely,

Christopher Nani

GENERAL MANAGER DATE: 30/04/2025

1. KUSILE POWER STATION MONTHLY EMISSIONS REPORT: Atmospheric Emission License 17/4/AEL/MP311/12/01



2. Raw Materials and Products

Raw	Raw Material Type	Units	Max Permitted Consumption Rate	Consumption Rate Mar-2025
Materials and	Coal	Tons	1 818 083	896 361
Products	Fuel Oil	Tons	5 533	2007.20
	Limestone	Tons	72 017	23226
	Product / By-Product Name	Units	Max Production Capacity Permitted	Indicative Production Rate Mar-2025
D	Energy	GWh	3 321.216	1 566.35
Production Rates	Ash	Tons	796 300	264 068.06
	Gypsum	Tons	155 100	13 006.56
	RE PM	kg/MWh	not specified	0.01
	RE SOx	kg/MWh	not specified	1.83

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [4 464 MW] x 24 hrs x days in Month/1000 to convert to GWh

3. Energy source characteristics

Fuel Characteristic	Units	Stipulated Range	Monthly Average Content
Coal Sulphur	%	1.3	0.84
Ash in Coal	%	38	29.46
Fuel Oil Sulphur	%	3.5	2.85

4. Emissions Limits (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NOx
Unit 1	50	3500	750
Unit 2	50	1000	750
Unit 3	50	1000	750
South Stack	50	1000	750

5. Abatement Technology (%)

Associated Unit/Stack	Technology Type	Efficiency Mar-2025	Technology Type	Efficiency Mar- 2025	
Unit 1	FFP	99.99%	FGD	Out of service	
Unit 2	FFP	Off	FGD	Out of service	
Unit 3	FFP	99.99%	FGD	99.96%	
Unit 4	FFP	99.99%	FGD	99.95%	
Unit 5	FFP	99.96%	FGD	99.78%	

Note: Both the FFP and FGD does not have bypass mode operation, hence plant 100% Utilised.

6. Monitoring reliability (%)

Associated Unit/Stack	PM	SO ₂	NO ·	
Unit 1	100.0	100.0	100.0	
Unit 2	Off	Off	Off	
Unit 3	100.0	100.0	100.0	
Unit 4	100.0	99.7	100.0	
Unit 5	100.0	99.7	99.9	

7. Emissions Performance

Table 7.1: Monthly tonnages for the month of Mar - 2025

Associated Unit/Stack	РМ	SO ₂	NO _x
Unit 1	5.9	2 424	798
Unit 2	Off	Off	Off
Unit 3	5.6	124	599
Unit 4	1.1	178	683
Unit 5	6.5	162	819
SUM	19.1	2 870	2 900

Table 7.2: Operating days in compliance to PM AEL Limit – March 2025

Associated Unit/Stack	Normal	Normal Grace		Contravention	Total Exceedance	Average PM (mg/Nm³)
Unit 1	27	0	0	0	0	3.5
Unit 2	Off	Off	Off	Off	Off	Off
Unit 3	23	0	0	0	0	3.8
Unit 4	31	0	0	0	0	0.4
Unit 5	31	0	0	0	0	3.6
SUM	112	0	0	0	0	

Table 7.3: Operating days in compliance to SO₂ AEL Limit - March 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm³)
Unit 1	30	0	0	0	0	1 177.9
Unit 2	Off	Off	Off	Off	Off	Off
Unit 3	25	0	0	0	0	60.9
Unit 4	31	0	0	0	0	65.7
Unit 5	31	0	0	0	0	75.9
SUM	117	0	0	0	0	


Table 7.4: Operating days in compliance to NOx AEL Limit – March 2025


Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	30	0	0	0	0	384.0
Unit 2	Off	Off	Off	Off	Off	Off
Unit 3	25	0	0	0	0	359.1
Unit 4	31	0	0	0	0	252.8
Unit 5	31	0	0	0	0	386.4
SUM	117	0	0	0	0	


Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO2


Table 7.5: Legend Description


Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions
































8. Correlation and Parallel test status

Unit 1:

- Unit 1 is operating with unity curve for PM. The existing particulate matter emissions correlation test curves became invalided due to the faulty monitor which was replaced. A new correlation test was conducted, however the correlation test failed. A full PM correlation test completed on the 24th of March 2025. Awaiting report from services provider
- The unit operated with valid parallel factors for gaseous emissions.
- Unit was shut down on 31 March 2025 for Inspection (IN) outage and to connect the unit to the main stack with FGD.

Unit 2:

 The unit was offload in the month of March 2025 due to Guarantee Inspection (GI) outage and to connect the unit to the main stack with FGD.

Unit 3

• The unit is operating with unity curves for particulate matter and gaseous emissions. The full PM emissions correlation test was completed on the 8th of April 2025. The station is waiting for the report from service provider. The gaseous emissions parallel test is planned to be conducted

Unit 4:

• Unit 4 is operating with valid correlation curves and parallel factors.

Unit 5

• Unit 5 is operating with valid correlation curves and parallel factors.

9. Shut down and Light up information

Unit No. 1	Eve	ent 1	Eve	ent 2	E	vent 3	Ev	ent 4
Breaker Open (BO)	3:25 am	2025/03/19	1:30 pm	2025/03/24	6:25 am	2025/03/29	9:30 pm	2025/03/31
Draught Group (DG) Shut Down (SD)	3:30 am	2025/03/19	8:35 am	2025/03/25	DG did not trip or SD	DG did not trip or SD	9:30 am	2025/04/01
BO to DG SD (duration)	00:00:05	DD:HH:MM	00:19:05	DD:HH:MM	n/a	DD:HH:MM	01:09:30	DD:HH:MM
Fires in time	4:15 am	2025/03/19	1:40 pm	2025/03/26				
Synch. to Grid (or BC)	12:35 am	2025/03/20	4:05 pm	2025/03/27				
Fires in to BC (duration)	00:20:20	DD:HH:MM	01:02:25	DD:HH:MM		DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit				
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM		DD:HH:MM

Unit No. 3	Event 1		Event 2		Event 3	
Breaker Open (BO)	10:10 pm	2025/03/05	7:10 pm	2025/03/09	9:00 am	2025/03/23
Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	4:15 pm	2025/03/10	DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	n/a	DD:HH:MM	00:21:05	DD:HH:MM	n/a	DD:HH:MM
Fires in time			10:05 pm	2025/03/15		
Synch. to Grid (or BC)			9:00 am	2025/03/16		
Fires in to BC (duration)		DD:HH:MM	00:10:55	DD:HH:MM		DD:HH:MM
Emissions below limit from BC (end date)			not > limit	not > limit		
Emissions below limit from BC (duration)		DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM

Unit No. 4	Event 1			
Breaker Open (BO)	10:30 am	2025/03/07		
Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD		
BO to DG SD (duration)	n/a	DD:HH:MM		
Fires in time				
Synch. to Grid (or BC)				
Fires in to BC (duration)		DD:HH:MM		
Emissions below limit from BC (end date)				
Emissions below limit from BC (duration)		DD:HH:MM		

Unit No. 5	Eve	ent 1	Eve	ent 2	Evei	nt 3	Event 4		Event 5	
Breaker Open (BO)	11:00 am	2025/0 3/07	2:15 am	2025/0 3/11	12:35 am	2025/0 3/22	10:30 pm	2025/0 3/26	8:25 pm	2025/0 3/30
Draught Group (DG) Shut Down (SD)	DG did not trip or SD	DG did not trip or SD	2:25 am	2025/0 3/11	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD	DG did not trip or SD
BO to DG SD (duration)	n/a	DD:HH: MM	00:00:1 0	DD:HH: MM	n/a	DD:HH: MM	n/a	DD:HH: MM	n/a	DD:HH :MM
Fires in time			3:10 am	2025/0 3/11						
Synch. to Grid (or BC)			12:50 pm	2025/0 3/11						
Fires in to BC (duration)		DD:HH: MM	00:09:4 0	DD:HH: MM		DD:HH: MM		DD:HH: MM		DD:HH :MM
Emissions below limit from BC (end date)			not > limit	not > limit						
Emissions below limit from BC (duration)		DD:HH: MM	n/a	DD:HH: MM		DD:HH: MM		DD:HH: MM		DD:HH :MM

10.Complaints

No complaints reported for the month of March 2025.

Date and time complaint was received	Complaint received	Source code name	Root cause analysis	Calculation of impact/emissions associated with incidents and dispersion modelling of pollutants where applicable	Measures implemented or to be implemented to prevent recurrence	Date by which measures will be implemented	
No complaints reported for the month of March 2025.							