	Monthly Report	Matla Power Station
---	----------------	---------------------

Title: **Matla Power Station Monthly Emissions Report – March 2025**

Document Identifier: **06C-31482**

Alternative Reference: **31482**
Number:

Area of Applicability: **Matla Power Station**





Functional Area: **Environmental Department**

Revision: **0**

Total Pages: **13**

Next Review Date: **N/A**

Disclosure Classification: **Controlled Disclosure**





Compiled by  M.P Chipa	Verified by  M Gcaleka	Verified by  N Molefe	Supported by  L.A Murovhi
Initials and Surname Officer Environmental	Initials and Surname Senior Advisor Engineer Boiler	Initials and Surname C&I System Engineer	Initials and Surname Environmental Manager (Acting)
Date: 22/04/2025	Date: 23/04/2025	Date: 24/04/2025	Date: 24/04/2025

Matla Power Station Monthly Emissions Report

Unique Identifier: 06C-31482

Revision: 0

Page: 2 of 13

Supported by  J Makuleka	Supported by  K Mangope	Supported by  L Ngobese	Authorized by  M Lesolang
Initials and Surname Boiler Engineering Manager	Initials and Surname C&I Engineering Manager	Initials and Surname Engineering Group Manager	Initials and Surname General Manager
Date: 25/04/2025	Date: 29/04/2025	Date: 30/04/2025	Date: 30/04/2025

Content

1. Introduction.....	4
2. Raw Materials and Products.....	4
3. Abatement Technology.....	4
4. Energy Source Characteristics	5
5. Emissions Reporting.....	5
5.1 PM Daily Averages.....	5
5.2 Sox Daily Averages.....	7
5.3 NOx Daily Averages.....	9
6. Continuous Emissions Monitoring System (CEMS)	12
7. CEMS Calibration and Equipment Used for Calibration	12
8. Validity of Correlation and Parallel Test.....	12
9. Complaint Register.....	13

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

1. Introduction

MATLA POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF MARCH 2025

This document serves as the monthly emissions report required in terms of Section 7.6 of Matla Power Station Provisional Atmospheric Emission License (AEL), 17/4/AEL/MP312/11/14

This report reflects Unit 1 to Unit 6 gaseous and particulate emissions performance against the AEL limit for the month of MARCH 2025 only.

2. Raw Materials and Products

Table 1- Quantity of Raw Materials and Products Consumption in 03/2025

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption – 03/2025
	Coal	Tons/month	1 475 000	1 011 680
	Fuel Oil	Tons/month	3 500	441
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of 03/2025
	Energy	GWh	2 745	1 590
	Ash Produced	Tons/month	471 000	290 352

3. Abatement Technology

Table 2-Abatement Equipment Control Technology Efficiency in 03/2025

Associated Unit/Stack	Technology Type	Efficiency	ESP Utilization
South Stack (Unit 1, 2 and 3)	Electrostatic Precipitators (ESP)	99.405%	100%
	Electrostatic Precipitators (ESP)		
	Electrostatic Precipitators (ESP)		
Unit 4	Electrostatic Precipitators (ESP)	99.286%	100%
Unit 5	Electrostatic Precipitators (ESP)	99.831%	100%
Unit 6	Electrostatic Precipitators (ESP)	Off	Off

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

4. Energy Source Characteristics

Table 3: Energy Source Material Characteristics for 03/2025


Characteristic	Stipulated Range (% by weight on a dry basis)	Monthly Average Content (% by weight on a dry basis)
Coal		
Sulphur Content	0.8-1.1	0.72
Ash Content	21-40	28.70

5. Emissions Reporting

Table 4- Emission Limits are as follows:

SO ₂ Monthly = 3500 mg/Nm ³	Dust Daily= 200 mg/Nm ³ (South Stack and Unit 4) Dust Daily= 100 mg/Nm ³ (Unit 5 and 6)	NO ₂ Daily= 1200 mg/Nm ³
---	--	--


5.1 PM Daily Averages




Matla South Stack Exceeded PM AEL limit of 200 mg/Nm³ on the 12th of February 2025, due to Unit 3 shutdown and forced cooling. The exceedance on the 17th of February 2025 was due to unit 1 cold light-up. On the 19th of February 2025 unit 1 precip fields were poorly performing. On the 20th and 26th of February 2025 the exceedance was due to unit 3 light-up.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30



"Matla Power Station unit 4 exceeded the PM limit of 200 mg/Nm³ from the 03rd to the 5th of March 2025. The exceedance was due to DHP defects leading to tripping precip fields, L/H 1, 2, 4 & 6. Further to that K-pump 4 was on Permit to work (PTW) for vent valve seal replacement and L/H Row 2 line was poorly performing which affected L/H precip field 3 and 4. The station experienced maxing out issues with the PM monitor within this period. The station incurred a Legal Contravention.




Matla Power Station South Stack exceeded PM AEL limit of 100 mg/Nm³ from the 25 - 26 of March 2025, due to the unavailability of Sulphur Common Plant.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Figure 4: Matla Unit 6 PM Emissions - March 2025





5.2 Sox Daily Averages


Figure 5: Matla South Stack SO₂ Emissions - March 2025

CONTROLLED DISCLOSURE


When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Figure 6: Matla Unit 4 SO₂ Emissions - March 2025Figure 7: Matla Unit 5 SO₂ Emissions - March 2025**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Figure 8: Matla Unit 6 SO₂ Emissions - March 2025

5.3 NO_x Daily Averages

Figure 9: Matla South Stack NO_x Emissions - March 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

Figure 10: Matla Unit 4 NOx Emissions - March 2025





Figure 11: Matla Unit 5 NOx Emissions - March 2025



CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30




Table 5-Monthly Tonnages for 03/2025

Associated Unit/Stack	PM	SO ₂	NO ₂
Unit 1	354.3	2 209.3	552.5
Unit 2	341.2	2 166.4	541.2
Unit 3	340.8	2 147.3	537.7
Unit 4	181.9	1 383.4	563.3
Unit 5	104.1	2 675.1	1 115.4
Unit 6	Off	Off	Off
SUM	1 322.2	10 581.6	3 310.1

Table 6-Monthly Averages Concentration for 03/2025 in mg/Nm³

Associated Unit/Stack	PM	SO ₂	NO ₂
South Stack	170.6	1 070.6	268.1
Unit 4	274.7	1 553.0	625.6
Unit 5	56.3	1 460.7	608.5
Unit 6	Off	Off	Off

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

6. Continuous Emissions Monitoring System (CEMS)

Table 7- Periods during which was inoperative/malfunctioning.

Date	CEMS status	Comments
March 2025	Malfunctioning	<p>The station gas monitors have been reading inaccurately for South Stack, Unit 4 and Unit 5, however parallel tests averages were used for the purpose of accurate reporting of the gases during this reporting period.</p> <p>The station is in a process of sourcing some of components for the gas monitors such Lenses, Zirconium cells for O₂ and Heater gaskets to improve the Monitor reliability and CO₂+O₂ relationship hence the Monitor reliability is not reported on the table above.</p>

Table 8-CEMS Monitor Reliability Percentage

Associated Unit/Stack	PM	SO ₂	NO ₂	O ₂
South Stack	89.0	-	-	-
Unit 4	99.2	-	-	-
Unit 5	85.1	-	-	-
Unit 6	Off	Off	Off	Off

Note: Parallel tests averages were used for the purpose of accurate reporting of the gases. The station is in a process of sourcing some of components for the gas monitors such Lenses, Zirconium cells for O₂ and Heater gaskets to improve the Monitor reliability and CO₂+O₂ relationship hence the Monitor reliability is not reported on the table above.

7. CEMS Calibration and Equipment Used for Calibration

Calibration certificates to be made available upon request.

8. Validity of Correlation and Parallel Test

Table 9-Validity of Correlation and Parallel Test.

Associated Unit/Stack	Correlation Test (PM)	Parallel Test (NO ₂ , CO ₂ , O ₂ , SO ₂)
South Stack	Valid until 27 February 2027	Valid until 30 October 2025
Unit 4	Valid until 19 May 2025	Valid until 30 April 2025
Unit 5	Valid Until 25 August 2026	Valid until 30 April 2025
Unit 6	Valid until 02 August 2026	Valid until 30 June 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

9. Complaint Register

Table 10-Complaints for the month of 03/2025

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Action taken to resolve the complaint	Date when the action was implemented.
N/A	N/A	N/A	N/A	N/A	N/A

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd. © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30