	Monthly Report	Matla Power Station
---	----------------	---------------------

Title: **Matla Power Station Monthly Emissions Report – April 2025**

Document Identifier: **06C-31482**

Alternative Reference: **31482**  
Number:

Area of Applicability: **Matla Power Station**





Functional Area: **Environmental Department**

Revision: **0**

Total Pages: **13**

Next Review Date: **N/A**

Disclosure Classification: **Controlled Disclosure**





Compiled by  M.P. Chipa	Verified by  M Gcaleka	Verified by  N Molefe	Supported by  L.A Murovhi
Initials and Surname Officer Environmental	Initials and Surname Senior Advisor Engineer Boiler	Initials and Surname C&I System Engineer	Initials and Surname Environmental Manager (Acting)
Date: 27/05/2025	Date: 27/05/2025	Date: 27/05/2025	Date: 27/05/2025

**Matla Power Station Monthly Emissions Report - April**

Unique Identifier: 06C-31482

Revision: 0

Page: 2 of 13

Supported by  J Makuleka	Supported by  K Mangope	Supported by  L Ngobese	Authorized by  B Phahle 2025/05/30
Initials and Surname Boiler Engineering Manager	Initials and Surname C&I Engineering Manager	Initials and Surname Engineering Group Manager	Initials and Surname General Manager (Acting)
Date: 28/05/2025	Date: 28/05/2025	Date: 28/05/2025	Date: 2025/05/30

**Content**

1. Introduction.....	4
2. Raw Materials and Products .....	4
3. Abatement Technology .....	4
4. Energy Source Characteristics .....	5
5. Emissions Reporting.....	5
5.1 PM Daily Averages .....	5
5.2 Sox Daily Averages .....	7
5.3 NOx Daily Averages .....	9
6. Continuous Emissions Monitoring System (CEMS) .....	12
7. CEMS Calibration and Equipment Used for Calibration .....	12
8. Validity of Correlation and Parallel Test .....	12
9. Complaint Register .....	13

**CONTROLLED DISCLOSURE**

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

## 1. Introduction

### MATLA POWER STATION MONTHLY EMISSIONS REPORT FOR THE MONTH OF APRIL 2025

This document serves as the monthly emissions report required in terms of Section 7.6 of Matla Power Station Provisional Atmospheric Emission License (AEL), **17/4/AEL/MP312/11/14**

This report reflects Unit 1 to Unit 6 gaseous and particulate emissions performance against the AEL limit for the month of April 2025 only.

## 2. Raw Materials and Products

**Table 1- Quantity of Raw Materials and Products Consumption in 04/2025**

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption/ Rate (Quantity)	Consumption – 04/2025
	Coal	Tons/month	1 475 000	752 081
	Fuel Oil	Tons/month	3 500	1 491
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate in Month of 04/2025
	Energy	GWh	2 745	1 327
	Ash Produced	Tons/month	471 000	203 814

## 3. Abatement Technology

**Table 2-Abatement Equipment Control Technology Efficiency in 04/2025**

Associated Unit/Stack	Technology Type	Efficiency	ESP Utilization
South Stack (Unit 1, 2 and 3)	Electrostatic Precipitators (ESP)	99.514%	100%
	Electrostatic Precipitators (ESP)		
	Electrostatic Precipitators (ESP)		
Unit 4	Electrostatic Precipitators (ESP)	99.428%	100%
Unit 5	Electrostatic Precipitators (ESP)	99.811%	100%
Unit 6	Electrostatic Precipitators (ESP)	Off	Off

**Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.**

**CONTROLLED DISCLOSURE**

#### 4. Energy Source Characteristics

Table 3: Energy Source Material Characteristics for 04/2025

Characteristic	Stipulated Range (% by weight on a dry basis)	Monthly Average Content (% by weight on a dry basis)
<b>Coal</b>		
<b>Sulphur Content</b>	0.8-1.1	0.8
<b>Ash Content</b>	21-40	27.10


#### 5. Emissions Reporting

In terms of Section 59 of National Environmental Management: Air Quality Act (Act no.39 of 2004) a decision made by the Minister of DFFE, in respect of the Eskom exemption applications for new Minimum Emission Standards (MES) were granted and effective as of 01<sup>st</sup> April 2025.

Table 4- New Minimum Emission Limits are as follows:


SO <sub>2</sub> Monthly = 2600 mg/Nm <sup>3</sup>	Dust Daily= 50 mg/Nm <sup>3</sup> (South Stack) Dust Daily= 100 mg/Nm <sup>3</sup> (Unit 4, 5 and 6)	NO <sub>2</sub> Daily= 1100 mg/Nm <sup>3</sup>
---	---	--

##### 5.1 PM Daily Averages




Matla Power Station South Stack exceeded PM AEL limit of 50mg/Nm<sup>3</sup> from the 01<sup>st</sup> – 12<sup>th</sup> of April 2025 and from 14<sup>th</sup> – 30<sup>th</sup> April 2025, with effect from the MES limit of 50 mg/Nm<sup>3</sup>. The units are still struggling to operate within limit on full load and in some instances exceed on min-gen.

**CONTROLLED DISCLOSURE**




Matla Power Station unit 4 exceeded the PM limit of  $200 \text{ mg/Nm}^3$  on from the 09<sup>th</sup> to the 12<sup>th</sup> of April 2025 and from the 14<sup>th</sup> to the 18<sup>th</sup> of April 2025. The exceedance was due to Unit 4 cold light-up that synchronised on the 08<sup>th</sup> of April 2025. The station experienced maxing out issues with the PM monitor within this period.




Matla Power Station Unit 5 exceeded PM AEL limit of  $100 \text{ mg/Nm}^3$  on the 02<sup>nd</sup> of April 2025, due to precipis isolation and on the 14<sup>th</sup>, 26<sup>th</sup> and 30<sup>th</sup> of April 2025 exceedance was due to Unit cold light-up.



**CONTROLLED DISCLOSURE**




## 5.2 Sox Daily Averages




**CONTROLLED DISCLOSURE**

Figure 6: Matla Unit 4 SO<sub>2</sub> Emissions - April 2025Figure 7: Matla Unit 5 SO<sub>2</sub> Emissions - April 2025**CONTROLLED DISCLOSURE**



### 5.3 NO<sub>x</sub> Daily Averages



**CONTROLLED DISCLOSURE**

Figure 10: Matla Unit 4 NOx Emissions - April 2025





Figure 11: Matla Unit 5 NOx Emissions - April 2025

**CONTROLLED DISCLOSURE**




Table 5-Monthly Tonnages for 04/2025

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>2</sub>
Unit 1	189.8	2 621.0	1 326.0
Unit 2	216.9	2 948.2	1 505.7
Unit 3	222.4	3 032.7	1 543.4
Unit 4	143.3	1 548.9	868.6
Unit 5	102.0	1 385.0	536.5
Unit 6	Off	Off	Off
SUM	874.5	11 535.9	5 780.1

Table 6-Monthly Averages Concentration for 04/2025 in mg/Nm<sup>3</sup>

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>2</sub>
South Stack	114.0	1 573.4	799.3
Unit 4	130.5	1 455.3	792.4
Unit 5	187.0	1 700.6	635.7
Unit 6	Off	Off	Off

**CONTROLLED DISCLOSURE**

## 6. Continuous Emissions Monitoring System (CEMS)

**Table 7- Periods during which was inoperative/malfunctioning.**

Date	CEMS status	Comments
April 2025	Malfunctioning	<p>The station gas monitors have been reading inaccurately for South Stack, however parallel tests averages were used for the purpose of accurate reporting of the gases during this reporting period.</p> <p>The station is in a process of sourcing some of components for the gas monitors such Lenses, Zirconium cells for O<sub>2</sub> and Heater gaskets to improve the Monitor reliability and CO<sub>2</sub>+O<sub>2</sub> relationship hence the Monitor reliability is not reported on the table above.</p>

**Table 8-CEMS Monitor Reliability Percentage**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO <sub>2</sub>	O <sub>2</sub>
South Stack	89.0	-	-	-
Unit 4	99.2	91.9	91.9	-
Unit 5	85.1	80.1	80.1	-
Unit 6	Off	Off	Off	Off

Note: Parallel tests averages were used for the purpose of accurate reporting of the gases for South Stack. The station is in a process of sourcing some of components for the gas monitors such Lenses, Zirconium cells for O<sub>2</sub> and Heater gaskets to improve the Monitor reliability and CO<sub>2</sub>+O<sub>2</sub> relationship hence the Monitor reliability is not reported on the table above.

## 7. CEMS Calibration and Equipment Used for Calibration

Calibration certificates to be made available upon request.

## 8. Validity of Correlation and Parallel Test

**Table 9-Validity of Correlation and Parallel Test.**

Associated Unit/Stack	Correlation Test (PM)	Parallel Test (NO <sub>2</sub> , CO <sub>2</sub> , O <sub>2</sub> , SO <sub>2</sub> )
South Stack	Valid until 27 February 2027	Valid until 30 October 2025
Unit 4	Valid until 19 May 2025	Valid until 11 May 2027
Unit 5	Valid Until 25 August 2026	Valid until 29 May 2027
Unit 6	Valid until 02 August 2026	Valid until 30 June 2025

### CONTROLLED DISCLOSURE

## 9. Complaint Register

Table 10-Complaints for the month of 04/2025

Source Code/ Name	Air pollution complaints received	Calculation of Impacts/ emissions associated with the incident	Date of complaint and date of response by the license holder	Action taken to resolve the complaint	Date when the action was implemented.
N/A	N/A	N/A	N/A	N/A	N/A

### CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30