

The Municipal Manager
Gert Sibande District Municipality
PO Box 1748
ERMELO
2350

Date: 14 April 2025

Enquiries: X. Jila

Tel +27 17 749 5100

E-mail: records@gsibande.gov.za
Email: BulelwaS@gsibande.gov.za

Dear Ms Mthembu

TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

This serves as the monthly report required in terms of Section 7.4 of Tutuka Power Station's Atmospheric Emission License (16/4/Lekwa/Eskom H SOC Ltd TPS/0013/2019/f03). The report includes verified emissions for Particulate Matters, Sulphur, and Nitrogen dioxides for the month of April 2025

The report outlines monthly trends for each monitored pollutant. In April 2025, the Station had four units operational: Units 2, 3, 4, and 5, while Units 1 and 6 remained offline. The NOx limit was exceeded in Unit 3 on the 9th of April and in Unit 5 on 10th of April; however, these exceedances occurred within the 48-hour grace period permitted for start-ups, shutdowns, and upset conditions.

Additionally, unit 3 dust emission limit was exceeded beyond the grace period for a single day on April 25th, 2025

1 RAW MATERIALS AND PRODUCTS

Raw Materials and Products	Raw Material Type	Units	Max. Permitted	Actual Consumption Mar-2025
	Coal	Tons	1 200 000	573 072
	Fuel Oil	Tons	10 000	5455.05
Production Rates	Product / By-Product Name	Units	Max. Production Capacity Permitted	Indicative Production Rate April-2025
	Energy	GWh	2 611	851.92
	Ash	Tons	350 000	1454.1
	RE Ash	kg/MWh	not specified	1.77

Note: Maximum energy rate is as per the maximum capacity stated in the AEL: [3 510 MW] x 24 hrs x days in Month/1000 to convert to GWh

2 ENERGY SOURCE CHARACTERISTICS

Generation
Tutuka Power Station
Standerton/Bethal Road
Private Bag X2016 Standerton 2430 SA
Tel +27 17 749 9237 www.eskom.co.za
Eskom Holdings SOC Ltd Reg No 2002/015527/30



TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

Coal Characteristics	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	16-24	21.71
Sulphur Content	%	0.6 TO 2.6	0.94
Ash Content	%	21 TO 33	24.73

3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	PM	SO ₂	NO _x
Unit 1	300	3400	1200
Unit 2	300	3400	1200
Unit 3	300	3400	1200
Unit 4	300	3400	1200
Unit 5	300	3400	1200
Unit 6	300	3400	1200

4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Efficiency Mar-2025
Unit 1	Electrostatic Precipitators (ESP)	Unit Off
Unit 2	Electrostatic Precipitators (ESP)	99.3%
Unit 3	Electrostatic Precipitators (ESP)	98.2%
Unit 4	Electrostatic Precipitators (ESP)	99.4%
Unit 5	Electrostatic Precipitators (ESP)	98.5%
Unit 6	Electrostatic Precipitators (ESP)	Unit Off

Note: The ESP does not have bypass mode operation, hence plant considered 100% Utilised.

5 MONITOR RELIABILITY (%)

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	Off	Off	Off
Unit 2	100.0	100.0	0.0
Unit 3	100.0	51.5	0.0
Unit 4	98.8	96.0	0.0
Unit 5	100.0	0.0	0.0
Unit 6	Off	Off	Off

SO_x (units 3 and 5) and NO_x (units 2 -5) monitors malfunctioned, and surrogate values were used to estimate the emissions

6 EMISSION PERFORMANCE

TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

Table 6.1: Monthly tonnages for the month of April-2025

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	Off	Off	Off
Unit 2	192.3	1 704	793
Unit 3	702.9	3 714	2 352
Unit 4	197.9	2 641	1 401
Unit 5	361.0	3 275	1 765
Unit 6	Off	Off	Off
SUM	1 454.1	11 335	6 311

Table 6.2: Operating days in compliance to PM AEL Limit - April 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	Off	Off	Off	Off	Off	Off
Unit 2	29	2	0	0	2	219.8
Unit 3	21	6	0	1	7	300.8
Unit 4	31	0	0	0	0	137.4
Unit 5	27	0	0	0	0	226.5
Unit 6	Off	Off	Off	Off	Off	Off
SUM	108	7	0	1	9	

Table 6.3: Operating days in compliance to SO₂ AEL Limit - April 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	Off	Off	Off	Off	Off	Off
Unit 2	26	0	0	0	0	1 942.3
Unit 3	30	0	0	0	0	1 620.8
Unit 4	26	0	0	0	0	1 843.5
Unit 5	22	0	0	0	0	2 046.7
Unit 6	Off	Off	Off	Off	Off	Off
SUM	82	0	0	0	0	

Table 6.4: Operating days in compliance to NO_x AEL Limit - April 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NO _x (mg/Nm ³)
Unit 1	Off	Off	Off	Off	Off	Off
Unit 2	26	0	0	0	0	903.3
Unit 3	29	0	0	1	1	1 027.3
Unit 4	26	0	0	0	0	972.2
Unit 5	21	0	0	1	1	1 111.2
Unit 6	Off	Off	Off	Off	Off	Off
SUM	81	0	0	1	1	

Note: NO_x emissions is measured as NO in PPM. Final NO_x value is expressed as total NO₂

Table 6.5: Legend

Description

Condition	Colour	Description
-----------	--------	-------------

TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention		Emissions above ELV but outside grace or S30 incident conditions

Figure 2: Tutuka Unit 2 PM Emissions - April 2025





Figure 3: Tutuka Unit 3 PM Emissions - April 2025



TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

Figure 4: Tutuka Unit 4 PM Emissions - April 2025





Figure 5: Tutuka Unit 5 PM Emissions - April 2025



TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

Figure 8: Tutuka Unit 2 SO₂ Emissions - April 2025




Figure 9: Tutuka Unit 3 SO₂ Emissions - April 2025





Figure 10: Tutuka Unit 4 SO₂ Emissions - April 2025



TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

Figure 11: Tutuka Unit 5 SO₂ Emissions - April 2025





Figure 14: Tutuka Unit 2 NO_x Emissions - April 2025



TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

Figure 15: Tutuka Unit 3 NOx Emissions - April 2025




Figure 16: Tutuka Unit 4 NOx Emissions - April 2025





Figure 17: Tutuka Unit 5 NOx Emissions - April 2025



TUTUKA POWER STATION MONTHLY REPORT FOR APRIL 2025

7. COMPLAINTS REGISTER

Source Code/Name	Root Cause Analysis	Calculation of Impacts/emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent recurrence	Date by which measure will be implemented
No complaints were received for the month of April 2025.					

Yours Sincerely


Compiled by:



Xoli Jila

SNR ENVIRONMENTAL ADVISOR

Supported by:



Mike Molepo

SNR CHEMIST: BOILER ENGINEERING

Approved by:



Bruce Moyo

GENERAL MANAGER

