

### Generation

Gert Sibande District Municipality
Corner of Joubert & Oosthuise Streets

Ermelo

2350

Attention:

Mrs. T Mogakabe

AND

Directorate: Air Quality Management Services

The Director:

Mr Vumile Senene

Department of Environmental Affairs

Private Bag X447 PRETORIA

0001

Tel: (012) 310 3263

Fax: (012) 320 0488

Date: 2025/07/17

Enquiries: Nomasonto Nsibande

**☎** +27 17 779 8995 **♣** +27 86 507 5108

Enquiries: Thabo Montja

☎ +27 17 779 8834

Total number of pages:

10

Total number of annexes:

## **GROOTVLEI POWER STATION**

Atmospheric Emission License GPS/0015/2015/F02

BOILER ENGINEERING MANAGER

**ENGINEERING MANAGER** 

ENVIRONMENTAL MANAGER

2025/07/17

DATE

2025/07/17

DATE

2025/07/17

DATE



# GROOTVLEI POWER STATION MONTHLY EMISSIONS REPORT

Atmospheric Emission License GPS/0015/2015/F02



## **1 RAW MATERIALS AND PRODUCTS**

Raw Materials and	Raw Material Type	Units	Maximum Permitted Consumption Rate	Consumption Rate Jun-2025
Flouncia	Coal	Tons	650 000	109 675.9
	Fuel Oil	Tons	20 000	3436.07
	Product / By- Product Name	Units	Maximum Production Capacity Permitted	Indicative Production Rate Jun-2025
Production Rates		<b>Units</b> GWh	Production	
Production Rates	Product Name		Production Capacity Permitted	Rate Jun-2025

Note: Maximum energy production is calculated as:(200MW x 6 Units) x 24hrs x Days in month/1000 = GWh.



## **2 ENERGY SOURCE CHARACTERISTICS**

Coal Characteristic	Units	Stipulated Range	Monthly Average Content
CV Content	MJ/kg	18-24	21.13
Sulphur Content	%	< 1.46	0.65
Ash Content	%	24.7 to < 38.1	23.47

# 3 EMISSION LIMITS (mg/Nm³)

Associated Unit/Stack	РМ	SO <sub>2</sub>	NO	
North	100	3500	1100	
South	50	3500	1100	

# 4 ABATEMENT TECHNOLOGY (%)

Associated Unit/Stack	Technology Type	Effieciency
Unit 1	Fabric Filter Plant (FFP)	99.848%
Unit 2	Fabric Filter Plant (FFP)	99.864%
Unit 3	Fabric Filter Plant (FFP)	99.810%
Unit 4	Fabric Filter Plant (FFP)	Unit Off-line
Unit 5	Fabric Filter Plant (FFP)	Unit Off-line
Unit 6	Fabric Filter Plant (FFP)	Unit Off-line

Note: Abatement plant does not have bypass mode operation, hence plant 100% Utilised.

# **5 MONITOR RELIABILITY (%)**

Associated Unit/Stack	PM	SO <sub>2</sub>	NO	O <sub>2</sub>	
North	98.1	0.0	0.0	0.0	
South					

Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO 2



## **6 EMISSION PERFORMANCE**

Table 6.1: Monthly tonnages for the month of June-2025

Associated Unit/Stack	PM (tons)	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	
Unit 1	12.04	495.0	188.7	
Unit 2	19.67	428.0	163.2	
Unit 3	13.72	279.5	106.5	
Unit 4	0.00	0.0	0.0	
Unit 5	0.00	0.0	0.0	
Unit-6	0.00	0.0	0.0	
SUM	45.43	1 202.5	458.4	

Table 6.2: Operating days in compliance to PM AEL Limit - June 2025

Associated Unit/Stack	Normal	Grace	Section 30	Total Exceedance	Average PM (mg/Nm³)
North	25	1	O	1	0.0
South	C	0	O	0	
SUM	25	1	0	1	

Table 6.3: Operating days in compliance to SO<sub>2</sub> AEL Limit - June 2025

Associated Unit/Stack	Normal	Grace	Section 30	Total Exceedance	Average SO <sub>2</sub> (mg/Nm³)
North	27	C	d	0	0.0
South	Q	C	d	0	
SUM	27	0	0	0	

Table 6.4: Operating days in compliance to NOx AEL Limit - June 2025


Associated Unit/Stack	Normal	Grace	Section 30	Total Exceedance	Average NOx (mg/Nm³)
North	27	0	0	0	0.0
South	Q	0	0	0	
SUM	27	0	0	0	


Note: NOx emissions is measured as NO in PPM. Final NOx value is expressed as total NO 2

Table 6.5: Legend Description


Condition	Colour	Description
Normal		Emissions below Emission Limit Value (ELV)
Grace		Emissions above the ELV during grace period
Section 30		Emissions above ELV during a NEMA S30 incident
Contravention	1	
























# 7 SHUT DOWN AND LIGHT UP INFORMATION

Table 7.1. PM Start-up information for the month of June-2025

North Stack	Ev	ent 1	Eve	nt 2	Event 3		E	Event 4	
Unit No.	Unit 1		Unit 1		Unit 1		Unit 2		
Breaker Open (BO)	BO previously	BO previously	5:00 pm	2025/06/03	7:20 am	2025/06/24	5:25 pm	2025/06/20	
Draught Group (DG) Shut Down (SD)	n/a	n/a	5:20 pm	2025/06/03	11:25 pm	2025/06/24	12:30 am	2025/06/21	
BO to DG SD (duration)	n/a	DD:HH:MM	00:00:20	DD:HH:MM	00:16:05	DD:HH:MM	00:07:05	DD:HH:MM	
Fires in time	10:20 am	2025/06/01	4:50 am	2025/06/04	8:20 pm	2025/06/27			
Synch. to Grid (or BC)	6:20 pm	2025/06/01	1:45 pm	2025/06/04	8:50 am	2025/06/28			
Fires in to BC (duration)	00:08:00	DD:HH:MM	00:08:55	DD:HH:MM	00:12:30	DD:HH:MM		DD:HH:MM	
Emissions below limit from BC (end date)	not > limit	not > limit	not > limit	not > limit	not > limit	not > limit			
Emissions below limit from BC (duration)	n/a	DD:HH:MM	n/a	DD:HH:MM	n/a	DD:HH:MM		DD:HH:MM	

North StackCont.	Event 5 Event 6 Unit 3 no event		Event 6	Event 7	Event 8
Unit No.			no event	no event	no event
Breaker Open (BO)	11:10 am	2025/06/13			
Draught Group (DG) Shut Down (SD)	9:30 pm	2025/06/13			
BO to DG SD (duration)	00:10:20	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM
Fires in time	1:00 am	2025/06/28			
Synch. to Grid (or BC)	5:35 pm	2025/06/28			
Fires in to BC (duration)	00:16:35	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM
Emissions below limit from BC (end date)	not > limit	not > limit			
Emissions below limit from BC (duration)	n/a	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM



North StackCont	Event 9	Event 10	Event 11	Event 12 no event	
Unit No.	no event	no event	no event		
Breaker Open (BO)					
Draught Group (DG) Shut Down (SD)					
BO to DG SD (duration)	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM	
Fires in time					
Synch. to Grid (or BC)					
Fires in to BC (duration)	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM	
Emissions below limit from BC (end date)					
Emissions below limit from BC (duration)	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM	

South Stack	Event 1	Event 2	Event 3	Event 4 no event	
Unit No.	no event	no event	no event		
Breaker Open (BO)					
Draught Group (DG) Shut Down (SD)					
BO to DG SD (duration)	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM	
Fires in time					
Synch. to Grid (or BC)					
Fires in to BC (duration)	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM	
Emissions below limit from BC (end date)					
Emissions below limit from BC (duration)	DD:HH:MM	DD:HH:MM	DD:HH:MM	DD:HH:MM	

7.2: Point Source emissions released during start-up (fires-in) and Shut-down (SD) for the month of June-2025 in  $mg/Nm^3$ 

[Include reference to once off test showing typical emissions rates during fires in and SD]

Atmospheric Emission License GPS/0015/2015/F02

#### **⊕**Eskom

## **8 EMERGENCY GENERATION**

#### ADDENDUM TO MONTHLY EMISSIONS REPORT

Emergency Generation [This is only required for stations that are requested to report on this information]

Table 8. Emergency Generation per unit for the month of June-2025

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control						
Emergency Hours declared including hours after stand down						
Hours over the Limit during Emergency Generation						

#### 9 COMPLAINTS REGISTER

Table 9. Complaints for the month of June-2025

Source Code / Name	Root Cause Analysis	Calculation of Impacts / emissions associated with the incident			Date measure will be implemented
(Insert name of affected person/sour ce)	(Insert root cause for incident)	(Insert emissions associated with incident)	(Insert dispersion model information where applicable)	(Insert mitiantion	(Insert date of implementation of mitigation method)

#### 10 S30 INCIDENT OR LEGAL CONTRAVENTION REGISTER

To be completed in the case of a S30 incident or a legal contravention:

Unit no	Incident Start Date	Incident End Date	Remedial action	Date S30 initial notification	Date S30 investigation		Date DEA Acceptabe	Comments / Reference No.
	- 40			sent	report sent	ment		



#### 11 General

South Stack off. The correlation test has expired and we're still awaiting PO approval before sending it to service providers. Testing will be planned based on plant conditions. The PM exceedance on 2 June was due to 400 leaking bags burnt during light-up, caused by a full dust hopper and fuel oil carryover. Gas reliability was zero as surrogate values were used for reporting. The gas issue was resolved at the end of June, and full calibration is pending before continuous use.

17/07/2025

SW MANE SY-

17/07/2025

**Environmental Department** 

Date

**Boiler Engineering** 

Date

General Manager

Date

Compiled by: Boiler Engineering Department

FFP System Engineer

For:

Department of Environmental Affairs and Tourism Chief Air Pollution Control Officer

Copies:

Eskom Environmental Management

D Herbst

K Langerman

Group Technology Engineering

R Rampiar

E. Patel

Grootvlie Power Station:

Engineering Manager
Operating Manager
Maintenance Manager
Unit Production Manager
Boiler Engineering Manager

System Engineer Environmental Officer Performance and Test Production Manager