

Ms Nompumelelo Simelane Nkangala District P. O Box 437 MIDDLEBURG 1050

By email: SimelaneNL@nkangaladm.gov.za

Ref: Kendal Power Station Annual Emissions Report

Dear Ms. Simelane

Date:

31 May 2025

Enquiries:

+27 13 647 6970

KENDAL POWER STATION'S ANNUAL EMISSIONS REPORT FOR THE FINANCIAL YEAR 2024/2025

This serves as the annual report required in terms of Section 7.6 in Kendal Power Station's Atmospheric Emission License, as well as in terms of other reporting requirements listed in the Minimum Emission Standards. The emissions are for Eskom's 2024/2025 financial year, which is from 1 April 2024 to 31 March 2025. Verified emissions of particulates, as measured by installed CEMS and for SO_2 and NO_x (as NO_2) from Eskom Research and Technology Division (RT&D) calculated data was used.

Name, description, and reference number of plant as specified in the AEL:

Name of facility	Eskom Holdings SOC Limited –Kendal Power Station			
Description of facility	Power Generation			
Reference number of plant	AEL License No: 17/AEL/MP312/11/15			





Emission Trends:


The emissions in the table below are that of the 2024/2025 financial year. Eskom Research and Technology Division (RT&D) calculated emissions data for **CO₂**, **N₂O**, **SO₂** & **NO₂** was used.


Table 1. General oversight of emissions at Kendal Power Station 2024/2025


Coal-fired emissions (tons/annum)	Fuel-oil emissions (tons/annum)	Total (tons/annum)
CO ₂ : 17995673 N ₂ O: 254.78	CO₂: 294814	CO ₂ : 18,290,487 N ₂ O: 254.78
PM: 21503.89		PM: 21503.89
SO ₂ : 156360 NO ₂ : 52065	SO₂: 3851.33	SO ₂ : 160,211.33 NO ₂ : 52065
	emissions (tons/annum) CO ₂ : 17995673 N ₂ O: 254.78 PM: 21503.89 SO ₂ : 156360	emissions (tons/annum) (tons/annum) CO2: 17995673 CO2: 294814 N2O: 254.78 PM: 21503.89 SO2: 156360 SO2: 3851.33


















Figure 1 to 6. Monthly Particulate Emissions in mg/Nm³ per unit for Kendal Power Station 2024/2025


Please note: Gaseous emissions, in particular, are largely dependent on the power generated by the power station, and thus the amount of coal burnt. Eskom Research and Technology Division (RT&D) calculated emissions data for CO2, N2O, SO2 & NO2 was used.



















Figure 7 to 12. Monthly SO₂ Emissions in mg/Nm³ per unit for Kendal Power Station 2024/2025














Figure 13 to 18. Monthly NO₂ Emissions in mg/Nm³ for Kendal Power Station 2024/2025




Figure 19. Monthly CO₂ Emissions in tons from Kendal Power Station 2024/2025




Figure 20. Monthly Energy sent out in GWh at Kendal Power Station 2024/2025

Figures showing compliance with the daily average emission limits of the respective pollutants have been presented to you in the monthly emission reports sent to your offices.

Monitoring Data Reliability

Table 2. General oversight of average monitoring data availability in percentage for Kendal Power Station 2024/2025 in terms of the number of full hours per annum that valid result were obtained for the CEMS in question (2024/2025)

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
PM	86.24	65.52	56.52	76.08	95.2	76.35
SO ₂	83.47	94.96	78.14	55.91	93.61	63.74
NOx	68.52	94.87	76.13	55.41	93.84	72.21

Compliance Audit Report(s):

The Eskom Generation Air Quality Centre of Excellence (AQ CoE) conducted an Atmospheric Emissions License (AEL) No. 17/4/AEL/MP312/11/15 compliance Review audit for Kendal Power Station on 1 August 2023.

Summary of the findings were as follows:

- AEL condition 4.1- While operating procedures and maintenance strategies for the SO3, DHP and ESP were indicated to be available and implemented, it was clear that the mitigation measures were not adequate to prevent and reduce atmospheric emissions. Within the review period (Q1_April to June 2023)- Kendal incurred emission limit non-compliances based on poorly maintained plants such as the DHP which negatively affected the abatement technology (ESP).
- AEL condition 4.2 deals with duty of care. The station has a procedure in place to demonstrate
 duty of care in terms of NEMA Section 28(3), however, from the extended non-compliance noted
 during the period under review (Q1), it was clear that the procedure was not followed to reduce
 and minimize the PM emissions.
- Under AEL condition 7.2 a non-compliance was raised, the station incurred 312 PM, 10 SO2, and NOx exceedances recorded in Q1. The station is implementing an emission recovery /turnaround plan to address emission non-compliance. However, some of these projects are delayed as per committed due dates, and revised dates are anticipated.
- Under AEL condition 7.4 it was found that all units had expired correlation tests.
- Under AEL condition 7.3 (sub-condition 7.3.1;7.3.2;7.3.3,7.3.9) it was found that the station did not take reasonable measures to control emissions during start-up after an outage still exceeded the emissions beyond the grace periods.

Major Upgrades Projects:

- 1. ESP refurbishment- Unit 2,3,4,5 & 6 completed, and unit 1 will be completed during the next outage.
- 2. SO3 plant tanks & common line refurbishment- Completed.
- 3. High frequency Transformers Installation on all units- Completed.
- 4. Refurbishment/replacement of primary & secondary Air heaters- Unit 2,3,4,5 & 6-Completed, unit 1 is outstanding and it will be done during the next outage.
- 5. Ash handling plant recovery GO scope of work-Completed on unit 2,3,4,5 & 6 and unit 1 will be executed during the next outage.

Greenhouse Gas Emissions:

Greenhouse gas emissions as CO_2 and N_2O have been reported on in table 1 above. These have been calculated.

Results of Spot Measurements or Correlation Tests:

Table 3. Overview of dates of last conducted CEMS verification tests for PM, SO₂ and NOx

Stack/Unit	PM	SO ₂	NOx	
1	13 th to 18 th of June 2024	14 th and the 17th of	14th and the 17th of	
		June 2024	June 2024	
2	03 rd and the 11th of May	28th and the 30th of May	28th and the 30th of	
	2023	2024	May 2024	
3	19 th March and the 04 th	3 rd to the 5 th of April	3rd to the 5th of April	
	April 2024	2024	2024	
4	23 rd February to 24 th	26 th February to the	26th February to the	
	March 2024	04 th of March 2024	04th of March 2024	
5	08th to the 15th of	9 th to the 15 th	9th to the 15th November	
	November 2023	November 2023	2023	
6	25 th to 5 th July 2024	27th of June to the 5th	27th of June to the	
		July 2024	5th	
			July 2024	

Please see attached appendices 1 to12 for the recent parallel tests and correlation tests. Conducted at Kendal Power Station.

An explanation of all instances where minimum emission standards were exceeded:

All of the exceedances within the grace period and those that exceeded the grace period are reported in monthly reports as submitted to your Office on a monthly basis.

Emission monitoring and reporting will continue on these units and the monthly reports will be submitted to the Licensing Authorities as required and in instances where the emission performance has improved or not improved, such will be displayed in the reports as submitted.

Summary of PM Emission Exceedance per month per unit for 2024/2025 year:

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
April	19	29	12	15	13	Unit off
May	22	9	6	8	20	15
June	4	22	2	3	Unit off	Unit off
July	2	21	0	5	11	4
August	9	21	Unit off	Unit off	22	Unit off
September	14	14	13	Unit off	29	0
October	28	4	14	2	21	22
November	26	Unit off	2	Unit off	24	17
December	Unit off	Unit off	21	13	29	2
January	21	Unit off	25	11	24	15
February	22	Unit off	20	4	19	5
March	21	13	13	10	20	12
Total	188	133	128	71	232	92

NAEIS reporting:

Kendal Power Station annual report on the NAEIS system is due on the 30th Of June 2025.

The rest of the information demonstrating compliance with the emission license conditions is supplied in the monthly emission reports sent to your office.

Hoping the above will meet your satisfaction.

Compiled by:

Tsakani Holeni

ENVIRONMENTAL SENIOR ADVISOR- KENDAL

Date: 20 06 2025

Supported by:

Solly Chokoe

ENVIRONMENTAL MANAGER- KENDAL

Date: 20/06/2025

Verified by: Date: 25/06/2025 BOILER ENGINEERING SYSTEM ENGINEER -KENDAL Validated by: Date: 30/06/20 25 Tendani Rasivhetshele **BOILER ENGINEERING MANAGER-KENDAL** Supported by: Date: 30/06/2025, Phindile Takane **ENGINEERING MANAGER-KENDAL** Approved by:

Date: on for rers

GENERAL MANAGER-KENDAL

Tshepiso Temo