	Technical and Generic Report	Matimba Power Station
---	-------------------------------------	------------------------------

Title: **Matimba Power Station May 2025 emissions report**

Document Identifier: **RP/247/061**

Plant Location: **Emission management**

Area of Applicability: **Matimba Power Station**

Functional Area Applicability: **Environment**

Revision: **1**

Total Pages: **30**

Report Date: **May 2025**

Disclosure Classification: **Controlled**

Compiled by



Kamogelo Kwata
Environmental Officer
(GIT)

Date: 2025-06-30


Reviewed by



Helry Ramahlare
Senior Advisor
Environment

Date: 2025/07/01


Functional Responsibility



MC Mamabolo
Environmental
Manager

Date: 01.07.2025

Authorized by



Obakeng Mabotja
General Manager

Date: 2025/07/01

Content

	Page
1. Report Summary	5
2. Emission information	6
2.1 Raw materials and products.....	6
2.2 Abatement technology.....	6
2.3 Emissions reporting.....	7
2.3.1 Particulate Matter Emissions.....	7
2.3.2 Gaseous Emissions	10
2.3.2.a SOx Emissions	10
2.3.2.b NOx Emissions.....	13
2.3.3 Total Volatile Organic Compounds	16
2.3.4 Greenhouse gas (CO ₂) emissions	17
2.4 Daily power generated.	17
2.5 Pollutant Tonnages	21
2.6 Operating days in compliance to PM AEL Limit	21
2.7 Operating days in compliance to SOx AEL Limit	21
2.8 Operating days in compliance to NOx AEL Limit	22
2.9 Reference values	22
2.10 Continuous Emission Monitors.....	22
2.10.1 Reliability.....	22
2.10.2 Changes, downtime, and repairs	24
2.10.3 Sampling dates and times.....	25
2.11 Units Start-up information	26
2.12 Emergency generation	27
2.13 Complaints register.	28
2.14 Air quality improvements and social responsibility conducted.	29
Air quality improvements.....	29
Social responsibility conducted.	29
2.15 Ambient air quality monitoring.....	29
2.16 Electrostatic precipitator and Sulphur plant status	29
2.17 General.....	30
3. Attachments.....	30
4. Report Conclusion	30
Table 1: Quantity of Raw Materials and Products used/produced for the month.....	6
Table 2: Abatement Equipment Control Technology Utilised.....	6
Table 3: Energy Source Material Characteristics.	7
Table 4: Total volatile compound estimates	16

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Table 5: Daily power generated per unit in MWh for the month of May 2025	17
Table 6: Pollutant tonnages for the month of May 2025.....	21
Table 7: Operating days in compliance with PM AEL limit of May 2025	21
Table 8: Operating days in compliance with SOx AEL limit of May 2025	21
Table 9: Operating days in compliance with NOx AEL limit of May 2025	22
Table 10: Reference values for data provided, May 2025.....	22
Table 11: Monitor reliability percentage (%)	22
Table 12: Average percentage (%) availability of monitors for the month of May 2025.....	23
Table 13: Dates of last full conducted CEMS verification tests for PM for unit 6.	25
Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO ₂ and NOx for unit 1, 5 and 6) ...	25
Table 15: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only.....	25
Table 16: Start-up information	26
Table 17: Emergency generation	27
Table 18: Complaints.....	28

Figures

Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of May 2025.....	7
Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of May 2025.....	8
Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of May 2025.....	9
Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of May 2025.....	9
Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of May 2025.....	10
Figure 6: SO ₂ daily average emissions against emission limit for unit 1 for the month of May 2025	11
Figure 7: SO ₂ daily average emissions against emission limit for unit 2 for the month of May 2025	11
Figure 8: SO ₂ daily average emissions against emission limit for unit 4 for the month of May 2025	12
Figure 9: SO ₂ daily average emissions against emission limit for unit 5 for the month of May 2025	12
Figure 10: SO ₂ daily average emissions against emission limit for unit 6 for the month of April 2025.....	13
Figure 11: NOx daily average emissions against emission limit for unit 1 for the month of May 2025	13
Figure 12: NOx daily average emissions against emission limit for unit 2 for the month of May 2025	14
Figure 13: NOx daily average emissions against emission limit for unit 4 for the month of May 2025	14
Figure 14: NOx daily average emissions against emission limit for unit 5 for the month of May 2025	15
Figure 15: NOx daily average emissions against emission limit for unit 6 for the month of May 2025	15
Figure 16: Unit 1 daily generated power in MWh for the month of May 2025	18

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Figure 17: Unit 2 daily generated power in MWh for the month of May 202518

Figure 18: Unit 4 daily generated power in MWh for the month of May 202519

Figure 19: Unit 5 daily generated power in MWh for the month of May 202519

Figure 20: Unit 6 daily generated power in MWh for the month of May 202520

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

1. Report Summary

Matimba Power Station was issued with an Atmospheric Emission License (H16/1/13-WDM05) in September 2022. The License requires the license holder to submit monthly reports to the Department. This report contains the required information as specified in the license for April 2025. The information recorded in the report is obtained from Matimba Emission Reporting tool V10.2024.



During the period under review, Matimba experienced one hundred and forty (140) exceedances of the daily particulate matter emission limit ($50\text{mg}/\text{Nm}^3$), one hundred and thirty-three (133) of these exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence and seven (7) exceedances occurred within the 48-hour grace period.

There were no exceedances of the monthly SOx limit ($3500\text{mg}/\text{Nm}^3$). There were no exceedances of the daily NOx emission limit ($750\text{mg}/\text{Nm}^3$).

Flue gas conditioning plant availability was below 90% for unit 1 and 4. Unit 1 SO_3 plant was on hold as the plant was still raising temperatures, SO_3 plant's availability 89%. Unit 4 SO_3 plant on hold due to low load, SO_3 plant's availability was 86%.

The consumption rates for fuel oil for the month of April 2025 exceeded the limit of 1200 tons by 1611.497 tons due to unit 6 light up and combustion support.

More information regarding above mentioned issues is provided in the relevant sections within the report.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2. Emission information

2.1 Raw materials and products

Table 1: Quantity of Raw Materials and Products used/produced for the month.

Raw Materials and Products used	Raw Material Type	Unit	Maximum Permitted Consumption Rate (Quantity)	Consumption Rate
	Coal	Tons/month	1 500 000	819 622
	Fuel Oil	Tons/month	1 200	1611.497
Production Rates	Product/ By-Product Name	Unit	Maximum Production Capacity Permitted (Quantity)	Production Rate
	Energy	MW	4000	1923.238
	Ash	Tons/month	547500	295 846.362

The consumption rates for fuel oil for the month of May 2025 exceeded the permitted maximum limits due to multiple units light up trips and combustion support.

2.2 Abatement technology

Table 2: Abatement Equipment Control Technology Utilised

Associated Unit	Technology Type	Minimum utilisation (%)	Efficiency (%)
Unit 1	Electrostatic Precipitator	100%	99.926%
Unit 2	Electrostatic Precipitator	100%	99.925%
Unit 3	Electrostatic Precipitator	100%	Off
Unit 4	Electrostatic Precipitator	100%	99.934%
Unit 5	Electrostatic Precipitator	100%	99.925%
Unit 6	Electrostatic Precipitator	100%	99.932%
Associated Unit	Technology Type	Minimum utilisation (%)	Actual Utilisation (%)
Unit 1	SO ₃ Plant	100%	89%
Unit 2	SO ₃ Plant	100%	98%
Unit 3	SO ₃ Plant	100%	Off
Unit 4	SO ₃ Plant	100%	86%
Unit 5	SO ₃ Plant	100%	94%
Unit 6	SO ₃ Plant	100%	96%

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Flue gas conditioning plant availability was below 90% for unit 1 and 4. Unit 1 SO₃ plant was on hold as the plant was still raising temperatures. Unit 4 SO₃ plant on hold due to low load.

Table 3: Energy Source Material Characteristics.

	Characteristic	Stipulated Range (Unit)	Monthly Average Content
Coal burned	Sulphur Content	1.6%	1.268%
	Ash Content	40%	36.095%

Energy source characteristics remained within the ranges stipulated in the license.

2.3 Emissions reporting

2.3.1 Particulate Matter Emissions

The emission monitors correlation and parallel tests were performed on unit 2,3 and 4 in June 2024 and the curves were applied on emissions calculations for April 2025. Unit 1, 5 and 6 emission calculations were done using the correlation/parallel tests curves from the spot test performed in August 2023. Unit 2 PM correlation curve applied is linear curve, Unit 3 and 4 PM correlation curve applied is polynomial curve.

Unit 1 Particulate Emissions




Figure 1: Particulate matter daily average emissions against emission limit for unit 1 for the month of May 2025

Interpretation: Unit 1 exceeded the daily particulate emission limit of 50mg/Nm³ on 1 to 20 of May 2025. All exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 Particulate Emissions




Figure 2: Particulate matter daily average emissions against emission limit for unit 2 for the month of May 2025

Interpretation: Unit 2 exceeded the daily particulate emission limit of 50mg/Nm³ on 1 to 31 May 2025. All exceedances occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

Unit 3 Particulate Emissions

Unit 3 is on outage

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 Particulate Emissions




Figure 3: Particulate matter daily average emissions against emission limit for unit 4 for the month of May 2025

Interpretation: Unit 4 exceeded the daily particulate emission limit of 50mg/Nm³ on 1 to 9 and 13 to 31 May 2025. Exceedances from 1 to 9 and 15 to 31 May 2025 occurred outside of the 48-hour grace period and were recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

Unit 5 Particulate Emissions




Figure 4: Particulate matter daily average emissions against emission limit for unit 5 for the month of May 2025

Interpretation: Unit 5 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 1, and 7 to 31 May 2025. Exceedances from 1 and 8 to 31 May 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 Particulate Emissions




Figure 5: Particulate matter daily average emissions against emission limit for unit 6 for the month of May 2025

Interpretation: Unit 6 Particulate matter exceeded the daily limit of 50 mg/Nm³ on 1 to 11 and 13 to 30 May 2025. The exceedances from 1 to 11 and 13 to 30 May 2025 occurred outside of the 48-hour grace period and was recorded on the Eskom incident management process as non-compliance to the Atmospheric Emissions Licence. The exceedances were due to high hopper levels causing electrostatic precipitators fields to trip and have low efficiency.

2.3.2 Gaseous Emissions

Gaseous emissions analyzers calibration for all 6 units were performed in April 2025 as per the Eskom emission standard requirement.


The quality assurance tests (QAL2) used for April 2025 emission calculations were performed in June 2024 for Unit 2,3 and 4. Unit 1,5 and 6 quality assurance curves utilized are spot tests performed in August 2023

2.3.2.a SO_x Emissions


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 1 SO₂ Emissions**Figure 6: SO₂ daily average emissions against emission limit for unit 1 for the month of May 2025**

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.

Unit 2 SO₂ Emissions**Figure 7: SO₂ daily average emissions against emission limit for unit 2 for the month of May 2025**

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


Unit 3 SO₂ Emissions

Unit 3 is on outage


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 4 SO₂ EmissionsFigure 8: SO₂ daily average emissions against emission limit for unit 4 for the month of May 2025

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


Unit 5 SO₂ EmissionsFigure 9: SO₂ daily average emissions against emission limit for unit 5 for the month of May 2025

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 6 SO₂ EmissionsFigure 10: SO₂ daily average emissions against emission limit for unit 6 for the month of April 2025

Interpretation: All daily averages below SO₂ emission monthly limit of 3500 mg/Nm³.


2.3.2.b NO_x EmissionsUnit 1 NO_x EmissionsFigure 11: NO_x daily average emissions against emission limit for unit 1 for the month of May 2025

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.


No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 2 NO_x EmissionsFigure 12: NO_x daily average emissions against emission limit for unit 2 for the month of May 2025

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

Unit 3 NO_x Emissions

Unit 3 is on outage


Unit 4 NO_x EmissionsFigure 13: NO_x daily average emissions against emission limit for unit 4 for the month of May 2025

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit 5 NO_x Emissions**Figure 14: NO_x daily average emissions against emission limit for unit 5 for the month of May 2025**

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.

Unit 6 NO_x Emissions**Figure 15: NO_x daily average emissions against emission limit for unit 6 for the month of May 2025**

Interpretation: All daily averages below NO_x emission limit of 750 mg/Nm³.


CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.3 Total Volatile Organic Compounds

Table 4: Total volatile compound estimates

		
CALCULATION OF EMISSIONS OF TOTAL VOLATILE COMPOUNDS FROM FUEL OIL STORAGE TANKS*		
Date:	Tuesday, 17 June 2025	
Station:	Matimba Power Station	
Province:	Limpopo Province	
Tank no.	1-4	
Description:	Outdoor fuel oil storage tank	
Tank Type:	Vertical fixed roof (vented to atmosphere)	
Material stored:	Fuel Oil 150	
<p align="center">MONTHLY INPUT DATA FOR THE STATION</p> <p align="center">Please only insert relevant monthly data inputs into the blue cells below</p> <p align="center">Choose from a dropdown menu in the green cells</p> <p align="center">The total VOC emissions for the month are in the red cells</p> <p align="center">IMPORTANT: Do not change any other cells without consulting the AQ CoE</p>		
MONTH:	May	
GENERAL INFORMATION:		
	Data	Unit
Total number of fuel oil tanks:	4	NA
Height of tank:	13.34	m
Diameter of tank:	9.53	m
Net fuel oil throughput for the month:	1611.497	
Molecular weight of the fuel oil:	166.00	Lb/lb-mole
METEROLOGICAL DATA FOR THE MONTH		
	Data	Unit
Daily average ambient temperature	19.51	°C
Daily maximum ambient temperature	28.42	°C
Daily minimum ambient temperature	12.06	°C
Daily ambient temperature range	15.04	°C
Daily total insolation factor	3.91	kWh/m ² /day
Tank paint colour	Grey/medium	NA
Tank paint solar absorbance	0.68	NA
FINAL OUTPUT:		
	Result	Unit
Breathing losses:	0.54 kg/month	
Working losses:	0.05 kg/month	
TOTAL LOSSES (Total TVOC Emissions for the month):	0.58 kg/month	
<p>*Calculations performed on this spreadsheet are taken from the USEPA AP-42- Section 7.1 Organic Liquid Storage Tanks - January 1996. This spreadsheet is derived from materials provided by Jimmy Peress, PE, Trittech Consulting Engineers, 85-93 Chevy Chase Street, Jamaica, NY 11432 USA, Tel - 718-454-3920, Fax - 718-454-6330, e-mail - PeressJ@nyc.rr.com.</p>		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.3.4 Greenhouse gas (CO₂) emissions

CO₂ emissions are reported in terms of the Greenhouse gas reporting regulations (GN 43712, GNR. 994/2020) and are not included in the monthly AEL compliance report.

2.4 Daily power generated.

Table 5: Daily power generated per unit in MWh for the month of May 2025

Date	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
2025/05/01	10231.7	9734.62	Unit off	10887.6	16.1346	8733.03
2025/05/02	10496	9140.31	Unit off	10480.4	Unit off	8634.6
2025/05/03	10655.5	9076.05	Unit off	11250.8	Unit off	7961.64
2025/05/04	10955.1	8619.3	Unit off	10659.7	Unit off	7958.73
2025/05/05	12245.2	8604.39	Unit off	10519.6	Unit off	7953.54
2025/05/06	11190.9	8110.74	Unit off	10480	9402.36	8372.57
2025/05/07	10692.6	8454.79	Unit off	10626.2	10506.7	7947.38
2025/05/08	10506.7	8924.22	Unit off	10802.8	10664.7	8343.58
2025/05/09	10902.8	8803.89	Unit off	5827.57	11371.1	8932.63
2025/05/10	10287.5	8198.73	Unit off	Unit off	10037.3	9078.18
2025/05/11	10654.4	8316.95	Unit off	Unit off	11213.7	9036.84
2025/05/12	11745.8	8998.96	Unit off	5011.76	13024.3	9541.31
2025/05/13	11615.6	8930.3	Unit off	8946.16	10130	10427.7
2025/05/14	10626.4	8763.67	Unit off	11200.5	10475.1	10079.6
2025/05/15	10831.6	8854.8	Unit off	11996.8	10837.6	9768.26
2025/05/16	10786.7	8856.01	Unit off	11602.6	10261.8	9763.5
2025/05/17	10481.9	8896.71	Unit off	9523.23	10267.9	9158.21
2025/05/18	10251.9	8951.5	Unit off	10545.8	10251.7	8905.87
2025/05/19	10262.8	8866.25	Unit off	11329.2	10201.2	9643.84
2025/05/20	6333.91	8719.98	Unit off	10922.6	10255.1	9598
2025/05/21	Unit off	9058.15	Unit off	10959	10241.2	10167.9
2025/05/22	Unit off	8951.22	Unit off	11940.9	10510.2	10679.6
2025/05/23	Unit off	9048.6	Unit off	10947.8	10305.8	10156.6
2025/05/24	Unit off	9057.45	Unit off	10948.7	10814.3	10019.6
2025/05/25	696.929	8967.61	Unit off	11608.5	12047.1	10524.7
2025/05/26	11775.4	9026.08	Unit off	11885.2	12115.7	10499.9
2025/05/27	12713	8844.24	Unit off	12298.1	12225.2	10432.8
2025/05/28	7864.96	8851.48	Unit off	12023	12328.5	10203.8
2025/05/29	12014.8	8900.58	Unit off	12004.3	12010.1	9794.27
2025/05/30	11481.7	8898.06	Unit off	11720.2	11821.8	9000.8
2025/05/31	11625	9078.72	Unit off	11940.6	10786.5	216.288

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 16: Unit 1 daily generated power in MWh for the month of May 2025




Figure 17: Unit 2 daily generated power in MWh for the month of May 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 18: Unit 4 daily generated power in MWh for the month of May 2025




Figure 19: Unit 5 daily generated power in MWh for the month of May 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.




Figure 20: Unit 6 daily generated power in MWh for the month of May 2025

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.5 Pollutant Tonnages

The emitted pollutant tonnages for May 2025 are provided in table 6.

Table 6: Pollutant tonnages for the month of May 2025

Associated Unit/Stack	PM (tons)	SO ₂ (tons)	NO _x (tons)
Unit 1	3 802.0	3 641.1	724.9
Unit 2	2 896.7	6 534.9	1 120.9
Unit 3	Off	Off	Off
Unit 4	2 056.2	6 469.6	1 365.8
Unit 5	1 759.5	2 108.9	442.9
Unit 6	386.1	3 276.8	603.6
SUM	10 900.5	22 031.3	4 258.1

2.6 Operating days in compliance to PM AEL Limit

Table 7: Operating days in compliance with PM AEL limit of May 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average PM (mg/Nm ³)
Unit 1	0	2	0	24	26	2 649.6
Unit 2	0	0	0	31	31	1 170.3
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	0	2	0	26	28	895.8
Unit 5	0	1	0	25	26	1 172.8
Unit 6	2	2	0	27	29	286.8
SUM	2	7	0	133	140	

2.7 Operating days in compliance to SO_x AEL Limit

Table 8: Operating days in compliance with SO_x AEL limit of May 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average SO ₂ (mg/Nm ³)
Unit 1	27	0	0	0	0	2 310.3
Unit 2	31	0	0	0	0	2 617.3
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	29	0	0	0	0	2 704.6
Unit 5	28	0	0	0	0	1 409.7
Unit 6	31	0	0	0	0	3 116.7
SUM	146	0	0	0	0	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.8 Operating days in compliance to NOx AEL Limit

Table 9: Operating days in compliance with NOx AEL limit of May 2025

Associated Unit/Stack	Normal	Grace	Section 30	Contravention	Total Exceedance	Average NOx (mg/Nm³)
Unit 1	27	0	0	0	0	459.3
Unit 2	31	0	0	0	0	449.0
Unit 3	Off	Off	Off	Off	Off	Off
Unit 4	29	0	0	0	0	572.0
Unit 5	28	0	0	0	0	303.1
Unit 6	31	0	0	0	0	564.8
SUM	146	0	0	0	0	

2.9 Reference values

Table 10: Reference values for data provided, May 2025

Compound / Parameter	Units of Measure	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Oxygen	%	8.74	7.91	Off	7.87	7.45	12.05
Moisture	%	4.02	6.29	Off	4.57	4.38	3.18
Velocity	m/s	24.7	32.0	Off	32.0	23.3	21.8
Temperature	°C	148.2	133.3	Off	121.4	121.4	181.2
Pressure	mBar	963.9	923.1	Off	922.6	903.0	915.4

2.10 Continuous Emission Monitors

2.10.1 Reliability

Table 11: Monitor reliability percentage (%)

Associated Unit/Stack	PM	SO ₂	NO
Unit 1	23.2	88.6	88.3
Unit 2	30.1	98.5	99.9
Unit 3	Off	Off	Off
Unit 4	31.4	99.7	92.4
Unit 5	10.5	99.4	81.5
Unit 6	81.0	98.8	98.8

Note: NOx emissions are measured as NO in PPM. Final NOx value is expressed as total NO2.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Continuous emission monitors were reliable for less than 80% of the reporting period for unit 1,2,4, and 5 PM. Unit 1 PM monitor reliability was low zero because the dust monitor was not calibrated, and the monitor kept maxing out of the monitor's range. Unit 2 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 4 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 5 PM monitor reliability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 1,2,4, 5 and 6 gaseous monitor reliability was above 80% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 1,2,4,5 and 6.

Table 12: Average percentage (%) availability of monitors for the month of May 2025.

Unit	SO ₂	NO _x	PM	CO ₂
1	88.6	88.3	23.2	76.9
2	98.5	99.9	30.1	100.0
3	Off	Off	Off	Off
4	99.7	92.4	31.4	0.0
5	99.4	81.5	10.5	100.0
6	98.8	98.8	81.0	98.7

Continuous emission monitors were available for less than 80% of the reporting period for unit 1,2,4, and 5 PM. Unit 1 PM monitor availability was low zero because the dust monitor was not calibrated, and the monitor kept maxing out of the monitor's range since. Unit 2 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 4 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 5 PM monitor availability was low due to the number of times the monitor kept maxing out of the monitors' range. Unit 1,2,4, 5 and 6 gaseous monitor availability was above 80% due to the SRM (Standard Reference Material) values from the parallel test used to calculate the gaseous emissions for unit 1,2,4,5 and 6.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document July be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.2 Changes, downtime, and repairs

Unit 1

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 2

- No adjustments done on the CEMs.
- No downtime or repairs done on the particulate monitors.

Unit 3

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 4

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 5

- No adjustments done on the CEMs.
- Correlation test to be done.

Unit 6

- No adjustments done on the CEMs.
- Correlation test to be done.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.10.3 Sampling dates and times**Table 13:** Dates of last full conducted CEMS verification tests for PM for unit 6.

Name of service provider:		Stacklabs Environmental Services CC		
Address of service provider:		10 Chisel Street Boltonia Krugersdorp 1739		
Stack/ Unit	PM	SO₂	NO_x	CO₂
6	2020/09/09 06h41	New sampling tests in table 14	New sampling tests in table 14	New sampling tests in table 14

Table 14: Dates of last conducted CEMS Spot verification tests for PM, SO₂ and NO_x for unit 1, 5 and 6)

Name of service provider:		Levego Environmental services		
Address of service provider:		Building R6 Pineland site Ardeer Road Modderfontein 1645		
Stack/ Unit	PM	SO₂	NO_x	CO₂
1	2023/08/01 19h33	2023/08/01 19:33	2023/08/01 19:33	2023/08/01 19:33
5	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30	2023/08/05 07:30
6	Dates in table 13 above	2023/08/05 15:52	2023/08/05 15:52	2023/08/05 15:52

Note: The CEMS Spot verification tests for PM, SO₂ and NO_x were performed in August 2023. PM spot verification test results for unit 6 failed and old curves are still in use.

Table 15: Dates of last full conducted CEMS verification tests for PM for unit 2, unit 3 and 4 only

Name of service provider:		Levego Environmental services		
Address of service provider:		Building R6 Pineland site Ardeer Road Modderfontein 1645		
Stack/ Unit	PM	SO₂	NO_x	CO₂
2	2024/07/02 08h50	2024/07/02 12h35	2024/07/02 12h35	2024/07/02 12h35
3	2024/06/23 16h34	2024/06/23 14h00	2024/06/23 14h00	2024/06/23 14h00
4	2024/06/29 16h05	2024/06/29 11h00	2024/06/29 11h00	2024/06/29 11h00

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.11 Units Start-up information

Table 16: Start-up information

Unit	1	
Fires in	2025/05/25	11h17
Synchronization with Grid	2025/05/25	19h19
Emissions below limit	2025/05/25	20h00
Fires in, to synchronization	8.2	HOURS
Synchronization to < Emission limit	0.41	HOURS

Unit	1	
Fires in	2025/05/28	07h26
Synchronization with Grid	2025/05/28	10h54
Emissions below limit	2025/05/29	16h00
Fires in, to synchronization	3.28	HOURS
Synchronization to < Emission limit	29.6	HOURS

Unit	4	
Fires in	2025/05/11	23h50
Synchronization with Grid	2025/05/12	09h50
Emissions below limit	2025/05/13	05h01
Fires in, to synchronization	10.0	HOURS
Synchronization to < Emission limit	19.11	HOURS

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

Unit	5	
Fires in	2025/05/05	15h45
Synchronization with Grid	2025/05/05	22h46
Emissions below limit	N/A	The unit did not go below the limit.
Fires in, to synchronization	7.1	HOURS
Synchronization to < Emission limit	N/A	HOURS

Unit	5	
Fires in	2025/05/05	15h45
Synchronization with Grid	2025/05/06	00h27
Emissions below limit	N/A	The unit did not go below the limit.
Fires in, to synchronization	8.42	HOURS
Synchronization to < Emission limit	N/A	HOURS

2.12 Emergency generation

Table 17: Emergency generation

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Emergency Generation hours declared by national Control	744	744	744	744	744	744
Emergency Hours declared including hours after standing down	621.720	744.000	Unit off	684.160	630.240	704.580
Days over the Limit during Emergency Generation	26	31	Unit off	28	26	29

During the period under review all Units were on emergency generation in force from 01 May 2025 until 31 May 2025.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.13 Complaints register.**Table 18:** Complaints

Source Name	Code/ Cause Analysis	Calculation of Impacts/ emissions associated with the incident	Dispersion modelling of pollutants where applicable	Measures implemented to prevent reoccurrence	Date by which measure will be implemented
Manketti lodge	Unavailability of ash evacuation plant	Not quantified	N/A	Ash plant and Dust handling plant recovery committees established	To be confirmed
Exxaro mine	Unavailability of ash evacuation plant	Not quantified	N/A	Ash plant and Dust handling plant recovery committees established	To be confirmed
Waterberg District Municipality Air Quality Officer	Unavailability of ash evacuation plant	Not quantified	N/A	Ash plant and Dust handling plant recovery committees established	To be confirmed
Marapong Community	Unavailability of ash evacuation plant	Not quantified	N/A	Ash plant and Dust handling plant recovery committees established	To be confirmed
Exxaro mine	Inadequate dust suppression resources	Not quantified	N/A	Application of chemicals for ash binding	To be confirmed
Onverwacht community	Unavailability of ash evacuation plant	Not quantified	N/A	Ash plant and Dust handling plant recovery committees established	To be confirmed

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.14 Air quality improvements and social responsibility conducted.

Air quality improvements

None

Social responsibility conducted.

None

2.15 Ambient air quality monitoring

Marapong ambient air quality monitoring station was relocated from the previous location to Ditheku primary school and commissioned to service on 20 March 2024. The May 2025 ambient air quality monitoring report is attached to this report as an addendum.

2.16 Electrostatic precipitator and Sulphur plant status

Unit 1

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 2

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 3

- Unit on outage.

Unit 4

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 5

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

Unit 6

- High hopper levels cause a decline in precipitator performance.
- The SO₃ plant is operating normally with no abnormalities observed.

SO₃ common plant

- The SO₃ common plant is operating normally with no abnormalities observed.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.

2.17 General

Name and reference number of the monitoring methods used:

1. Particulate and gas monitoring according to standards
 - a. BS EN 14181:2004 - Quality Assurance of Automated Measuring Systems
 - b. ESKOM internal standard 240-56242363 Emissions Monitoring and Reporting Standard

Sampling locations:

1. Stack one
 - a. Particulates:
 - i. S23° 40' 2.8" E027° 36' 34.8" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 2.8" E027° 36' 34.8" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues
2. Stack two
 - a. Particulates:
 - i. S23° 40' 14.8" E027° 36' 47.5" 175m from ground level and 75m from the top.
 - b. Gas:
 - i. S23° 40' 14.8" E027° 36' 47.5" 100m from ground level and 150m from the top.
 - c. Stack height
 - i. 250 meter consist of 3 flues

3. Attachments

- Fugitive dustfall out monitoring report and Ambient air quality report.
- Marapong ambient air quality report

4. Report Conclusion

The rest of the information demonstrating compliance with the emission license conditions is supplied in the annual emission report sent to your office.

Hoping the above will meet your satisfaction.

I hereby declare that the information in this report is correct.

Yours sincerely



GENERAL MANAGER: MATIMBA POWER STATION

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Ltd.